

# **ADAM 4000**

**Data Acquisition Modules  
User's Manual**

# **ADAM 4000 Series**

## **Data Acquisition Modules**

### **User's Manual**

## **Copyright Notice**

This document is copyrighted, 1997, by Advantech Co., Ltd. All rights are reserved. Advantech Co., Ltd., reserves the right to make improvements to the products described in this manual at any time without notice.

No part of this manual may be reproduced, copied, translated or transmitted in any form or by any means without the prior written permission of Advantech Co., Ltd. Information provided in this manual is intended to be accurate and reliable. However, Advantech Co., Ltd. assumes no responsibility for its use, nor for any infringements upon the rights of third parties, which may result from its use.

## **CE Notification**

The ADAM-4000 series developed by Advantech Co., Ltd. has passed the CE test for environmental specifications when operated within an industrial enclosure (ADAM-4950-ENC). Therefore, in order to protect the ADAM modules from being damaged by ESD (Electric Static Discharge), we strongly recommend that the use of CE-compliant industrial enclosure products when using any ADAM module.

## **Acknowledgments**

ADAM is a trademark of Advantech Co., Ltd.  
IBM and PC are trademarks of International Business  
Machines Corporation.

**Edition 10.7**  
**May 2008**

# Table of Contents

|  |             |
|--|-------------|
| <b>Chapter 1 Introduction .....</b>  | <b>1-1</b>  |
| <b>1.1 Overview .....</b>  | <b>1-2</b>  |
| <b>1.2 Applications .....</b>  | <b>1-4</b>  |
| <br>   |             |
| <b>Chapter 2 Installation Guideline .....</b>  | <b>2-1</b>  |
| <b>2.1 System Requirements to set up an ADAM network .....</b>                           | <b>2-2</b>  |
| <b>2.2 Basic configuration and hook-up .....</b>   | <b>2-6</b>  |
| <b>2.3 Baud rate and Checksum .....</b>  | <b>2-9</b>  |
| <b>2.4 Multiple Module Hookup .....</b>  | <b>2-11</b> |
| <b>2.5 Programming Example.....</b>  | <b>2-12</b> |
| <br>   |             |
| <b>Chapter 3 I/O Modules .....</b>   | <b>3-1</b>  |
| <b>3.1 ADAM-4011/4011D Thermocouple Input Modules .....</b>                              | <b>3-3</b>  |
| <b>3.2 ADAM-4012 Analog Input Module .....</b>   | <b>3-10</b> |
| <b>3.3 ADAM-4013 RTD Input Modules .....</b>   | <b>3-15</b> |
| <b>3.4 ADAM-4015 6-channel RTD Input Module .....</b>                                    | <b>3-17</b> |
| <b>3.5 ADAM-4015T 6-channel Thermistor Input Module .....</b>                            | <b>3-20</b> |
| <b>3.6 ADAM-4016 Analog Input/Output Module.....</b>                                     | <b>3-22</b> |
| <b>3.7 ADAM-4017/4017+/4018/4018M/4018+ 8-channel Analog Input<br/>    Modules .....</b> | <b>3-27</b> |
| <b>3.8 ADAM-4019+ 8-channel Universal Analog Input<br/>    Module .....</b>              | <b>3-37</b> |
| <b>3.9 ADAM-4021 Analog Output Module .....</b>  | <b>3-41</b> |
| <b>3.10 ADAM-4024 4-channel Analog Output Module .....</b>                               | <b>3-44</b> |
| <b>3.11 ADAM-4050 Digital I/O Module .....</b>   | <b>3-47</b> |
| <b>3.12 ADAM-4051 16-channel Isolated Digital Input Module .....</b>                     | <b>3-49</b> |
| <b>3.13 ADAM-4052 Isolated Digital Input Module .....</b>                                | <b>3-51</b> |
| <b>3.14 ADAM-4053 16-channel Digital Input Module .....</b>                              | <b>3-53</b> |
| <b>3.15 ADAM-4055 16-channel Isolated Digital I/O Module .....</b>                       | <b>3-56</b> |
| <b>3.16 ADAM-4056S 12-channel Sink Type Isolated Digital Output<br/>    Module .....</b> | <b>3-61</b> |

|  |      |
|--|------|
| 3.17 ADAM-4056SO 12-ch. Source Type Isolated Digital Output Module ..... | 3-63 |
| 3.18 ADAM-4060/4068 Relay Output Module .....                            | 3-65 |
| 3.19 ADAM-4069 8-channel Relay Output Module .....                       | 3-69 |
| 3.20 ADAM-4080/4080D Counter/Frequency Input Modules .....               | 3-72 |
| <br>   |      |
| Chapter 4 Command Set .....  | 4-1  |
| 4.1 Introduction.....  | 4-2  |
| 4.2 Syntax .....   | 4-2  |
| 4.3 I/O Module Commands Search Table .....                               | 4-4  |
| <br>   |      |
| Chapter 5 Analog Input Module Command Set .....                          | 5-1  |
| 5.1 Analog Input Command Set .....                                       | 5-2  |
| 5.2 Analog Input Data Logger Command Set .....                           | 5-34 |
| 5.3 Digital I/O, Alarm and Event Command Set .....                       | 5-47 |
| 5.4 Excitation Voltage Output Command Set .....                          | 5-61 |
| <br>   |      |
| Chapter 6 AO commands.....   | 6-1  |
| 6.1 Analog Output Module Command for ADAM-4021.....                      | 6-2  |
| 6.2 Analog Output Module Command for ADAM-4024.....                      | 6-19 |
| <br>   |      |
| Chapter 7 Digital IO, Relay & Counter commands.....                      | 7-1  |
| 7.1 Configuration, Counter Input and Display Command Set ...             | 7-2  |
| 7.2 Counter/Frequency Module Command.....                                | 7-28 |
| 7.2.1 Configuration, Counter Input and Display Command Set.....          | 7-28 |
| 7.2.2 Counter Setup Command Set.....                                     | 7-40 |
| 7.2.3 Digital Filter and Programmable Threshold Command Set....          | 7-49 |
| 7.2.4 Digital Output and Alarm Command Set.....                          | 7-60 |



|   |             |
|---|-------------|
| <b>Chapter 8 Calibration .....</b>  | <b>8-1</b>  |
| <b>8.1 Analog Input Module Calibration .....</b>  | <b>8-2</b>  |
| <b>8.2 Analog Input Resistance Calibration .....</b>                                      | <b>8-5</b>  |
| <b>8.3 Analog Input Thermistor module Calibration .....</b>                               | <b>8-7</b>  |
| <b>8.4 Analog Output Calibration .....</b>  | <b>8-13</b> |
| <br>  |             |
| <b>Appendix A Technical Specifications.....</b>   | <b>A-1</b>  |
| <b>A.1 ADAM-4011 Thermocouple Input Module .....</b>                                      | <b>A-2</b>  |
| <b>A.2 ADAM-4011D Thermocouple Input Module with LED<br/>  Display .....</b>              | <b>A-5</b>  |
| <b>A.3 ADAM-4012 Analog Input Module .....</b>  | <b>A-8</b>  |
| <b>A.4 ADAM-4013 RTD Input Module .....</b>   | <b>A-10</b> |
| <b>A.5 ADAM-4016 Strain Gauge Input Module .....</b>                                      | <b>A-12</b> |
| <b>A.6 ADAM-4017/4017+ 8-Channel Analog Input Module .....</b>                            | <b>A-14</b> |
| <b>A.7 ADAM-4018/4018+ 8-channel Analog Input Module .....</b>                            | <b>A-16</b> |
| <b>A.8 ADAM-4018M 8-channel Analog Input Data Logger .....</b>                            | <b>A-19</b> |
| <b>A.9 ADAM-4019+ 8-channel Universal Analog Input Module .....</b>                       | <b>A-22</b> |
| <b>A.10 ADAM-4021/4024 Analog Output Module .....</b>                                     | <b>A-24</b> |
| <b>A.11 ADAM-4050 Digital I/O Module.....</b>   | <b>A-28</b> |
| <b>A.12 ADAM-4051/4052 Isolated Digital Input Module .....</b>                            | <b>A-30</b> |
| <b>A.13 ADAM-4053 16-channel Digital Input Module .....</b>                               | <b>A-32</b> |
| <b>A.14 ADAM-4055 16-channel Digital I/O Module .....</b>                                 | <b>A-34</b> |
| <b>A.15 ADAM-4056S 12-channel Sink Type Isolated Digital Output<br/>  Module .....</b>    | <b>A-36</b> |
| <b>A.16 ADAM-4056SO 12-channel Source Type Isolated Digital Output<br/>  Module .....</b> | <b>A-38</b> |
| <b>A.17 ADAM-4060 Relay Output Module.....</b>  | <b>A-40</b> |
| <b>A.18 ADAM-4068/4069 8-channel Relay Output Module .....</b>                            | <b>A-42</b> |
| <b>A.19 ADAM-4080 Counter/Frequency Input Module .....</b>                                | <b>A-44</b> |
| <b>A.20 ADAM-4080D Counter/Frequency Input Module with LED<br/>  Display .....</b>        | <b>A-46</b> |
| <br>  |             |
| <b>Appendix B Data Formats and I/O Ranges .....</b>                                       | <b>B-1</b>  |
| <b>B.1 Analog Input Formats.....</b>  | <b>B-2</b>  |

|   |             |
|---|-------------|
| B.1.1 Engineering Units .....   | B-2         |
| B.1.2 Percent of FSR .....  | B-3         |
| B.1.3 Twos complement hexadecimal .....                               | B-4         |
| B.1.4 Ohms .....  | B-5         |
| <b>B.2 Analog Input Ranges.....</b>                                   | <b>B-6</b>  |
| <b>B.3 Analog Output Formats .....</b>                                | <b>B-11</b> |
| B.3.1 Engineering Units .....   | B-11        |
| B.3.2 Percent of Span .....   | B-11        |
| B.3.3 Hexadecimal .....   | B-11        |
| <b>B.4 Analog Output Ranges .....</b>                                 | <b>B-12</b> |
| <br>  |             |
| <b>Appendix C Technical Diagrams .....</b>                            | <b>C-1</b>  |
| <br>  |             |
| <b>C.1 ADAM Dimensions .....</b>                                      | <b>C-2</b>  |
| <b>C.2 Installation .....</b>   | <b>C-3</b>  |
| C.2.1 DIN-Rail Mounting .....   | C-3         |
| C.2.2 Panel Mounting .....  | C-5         |
| C.2.3 Piggyback Stack .....   | C-7         |
| <br>  |             |
| <b>Appendix D Utility Software .....</b>                              | <b>D-1</b>  |
| <br>  |             |
| <b>D.1 ADAM-4000 Utility Software .....</b>                           | <b>D-2</b>  |
| <b>D.2 The procedure for ADAM-4000 series installation guide.....</b> | <b>D-6</b>  |
| <br>  |             |
| <b>Appendix E RS-485 Network .....</b>                                | <b>E-1</b>  |
| <br>  |             |
| <b>E.1 Basic Network Layout .....</b>                                 | <b>E-3</b>  |
| <b>E.2 Line Termination .....</b>                                     | <b>E-5</b>  |
| <b>E.3 RS-485 Data Flow Control .....</b>                             | <b>E-7</b>  |
| <br>  |             |
| <b>Appendix F How to use the Checksum feature .....</b>               | <b>F-1</b>  |
| <br>  |             |
| <b>F.1 Checksum Enable/Disable .....</b>                              | <b>F-2</b>  |
| <br>  |             |
| <b>Appendix G ADAM-4000 I/O Modbus Mapping Table .....</b>            | <b>G-1</b>  |
| <br>  |             |
| <b>Appendix H Changing Configuration to Modbus Protocol .....</b>     | <b>H-1</b>  |

Introduction

1

# Introduction

---

## 1.1 Overview

The ADAM Series is a set of intelligent sensor-to-computer interface modules containing built-in microprocessor. They are remotely controlled through a simple set of commands issued in ASCII format and transmitted in RS-485 protocol. They provide signal conditioning, isolation, ranging, A/D and D/A conversion, data comparison, and digital communication functions. Some modules provide digital I/O lines for controlling relays and TTL devices.

### Software Configuration and Calibration

By merely issuing a command from the host computer, you can change an analog input module to accept several ranges of voltage input, thermocouple input or RTD input. All of the module's configuration parameters including I/O address, communication speed, HI and LO alarm, calibration parameters settings may be set remotely. Remote configuration can be done by using either the provided menu-based software or the command set's configuration and calibration commands. By storing configuration and calibration parameters in a nonvolatile EEPROM, modules are able to retain these parameters in case of power failure.

### Watchdog Timer

A watchdog timer supervisory function will automatically reset the ADAM modules in the event of system failure. Maintenance is thus simplified.

### Power Requirements

Although the modules are designed for standard industrial unregulated  $24 V_{DC}$  power supply, they accept any power unit that supplies power within the range of  $+10$  to  $+30 V_{DC}$ . The power supply ripple must be limited to  $5 V$  peak-to-peak, and the immediate ripple voltage should be maintained between  $+10$  and  $+30 V_{DC}$ .

### Connectivity and Programming

ADAM modules can connect to and communicate with all computers and terminals. They use RS-485 transmission standards, and communicate with ASCII format commands. The command set for every module type consists of approximately ten different commands.


The command set for input modules is larger because it incorporates alarm functions. All communications to and from the module are performed in ASCII, which means that ADAM modules can be virtually programmed in any high-level language.

## RS-485 Network

The RS-485 network provides lower-noise sensor readings, as modules can be placed much closer to the source. Up to 256 ADAM modules may be connected to an RS-485 multi-drop network by using the ADAM RS-485 repeater which extends the maximum communication distance up to 4,000 ft. The host computer is connected to the RS-485 network with one of its COM ports through the ADAM-452x module (RS-232 to RS-422/485 converter).

To boost the network's throughput, ADAM RS-485 repeater uses a logical RTS signal to manage the repeater's direction. The only two wires that are needed for the RS-485 network, DATA+ and DATA-, are inexpensive shielded twisted pair.

## Panel/DIN Rail mounting



# Introduction

---

ADAM modules can be mounted on any panels, brackets, or DIN rails. They can also be stacked together.

The RS-485 network, together with screw-terminal plug connectors, allows for system expansion, reconfiguration, and re-pair without disturbing field wiring.

## Protection against the environment

Since all these configurations are controlled by software, the protection provided by the packaging is very important. The plastic outer shell enhances resistance against corrosive materials, moisture, and vibrations. ADAM modules' low power requirements help them to operate in temperatures from 0 to 70 °C, and in humidity from 0 to 95% (non-condensing). They are compactly built using automated SMT technology. Therefore, they can be implemented in water-tight and explosion-proof industrial enclosures.

## 1.2 Applications

- Remote data acquisition
- Process monitoring
- Industrial process control
- Energy management
- Supervisory control
- Security systems
- Laboratory automation
- Building automation
- Product testing
- Direct digital control

Installation Guideline

2

# Installation Guideline

---

This chapter provides guidelines to what is needed to set up and install an ADAM network. A quick hookup scheme is provided that lets you configure modules before they are installed in a network. To help you connect ADAM modules with sensor inputs, several wiring examples are provided. At last, you will find a programming example using the ADAM command set at the end of this chapter.

Be sure to plan the layout and configuration of your network carefully before you start. Guidelines regarding layout are given in Appendix E: RS-485 Network.

## 2.1 System Requirements to set up an ADAM network

The following list gives an overview of what is needed to setup, install and configure an ADAM environment.

- ADAM modules
- A host computer, such as an IBM PC/AT compatible, that can output ASCII characters with a RS-232C or RS-485 port.
- Power supply for the ADAM modules (+10 to +30 V<sub>DC</sub>)
- ADAM Series Utility software
- ADAM Isolated RS-232/RS-485 Converter (optional)
- RS-232/RS-485 ADAM Repeater (optional)

### Host computer

Any computer or terminal that can output in ASCII format over either RS-232 or RS-485 can be connected as the host computer. When only RS-232 is available, an ADAM RS-232/RS-485 Converter is required to transform the host signals to the correct RS-485 protocol. The converter also provides opto-isolation and transformer-based isolation to protect your equipment.



### Power supply

For the ease of use in industrial environments, the ADAM modules are designed to accept industry standard +24 V<sub>DC</sub>, unregulated power. Operation is guaranteed when using any power supply between +10 and +30 V<sub>DC</sub>. Power ripples must be limited to 5 V peak to peak while the voltage in all cases must be maintained between +10 and +30 V<sub>DC</sub>. All power supply specifications are referenced at module connector. When modules are powered remotely, the effects of DC voltage drops must be considered.

All modules use on-board switching regulators to sustain good efficiency over the 10 to 30 V input range; therefore, we can assume that the actual drawn current is inversely proportional to the DC voltage. The following example shows how to calculate the required current that a power supply should provide.


Assume that a +24 V<sub>DC</sub> is used for five ADAM-4011 Analog Input Modules, and the distance between modules and power supply is not significant enough to cause a DC voltage drop. One ADAM-4011 module consumes a maximum of 1.2 Watts (W). The total required power will equal to  $5 \times 1.2 = 6$  W. A power supply of +24 V<sub>DC</sub> should therefore be able to supply a minimal current of  $6 / 24 = 0.25$  Amps.

Small systems may be powered by using wall-mounted modular power supplies. Also, when modules operate in long communication lines (>500 feet), it is often more reliable to obtain power locally through modular power supplies. These inexpensive units can be easily obtained from any electronic retail stores.

The power cables should be selected according to the length of the power lines and the number of modules connected. When implementing a network with long cables, the use of thicker wire is more suitable due to the limitation of DC voltage drop. Furthermore, long wires can also cause interference with communication wires.

## Installation Guideline

---



**Figure 2-1 Power Supply Connections**

We advise the following standard colors (as indicated on the modules) for each power line:

|     |     |       |
|-----|-----|-------|
| +Vs | (R) | Red   |
| GND | (B) | Black |

### Communication Wiring


We recommend the use of shielded-twisted-pair cable in the ADAM network for reducing interference purpose, but the cable has to comply with the EIA RS-485 standard. Furthermore, only one set of twisted-pair cable is required for transmitting Data. We advise the following standard colors (as indicated on the modules) for each the communication line:

|       |     |        |
|-------|-----|--------|
| DATA+ | (Y) | Yellow |
| DATA- | (G) | Green  |

### ADAM Utility Software

A menu-driven utility program is provided for ADAM module configuration, monitoring and, calibration. It also includes a terminal emulation program that lets you communicate through the ADAM command set. (See Appendix D, Utility Software and online help)

Notice: User can refer our help file to see more details for explanation of Utility operation.



### **ADAM Communication Speed**

In ADAM series, the baud rate can be configured from 1200 bps to 38.4 Kbps. However, the baud rate of all modules in an RS-485 network must be the same.

### **ADAM Isolated RS-232/RS485 Converter (optional): ADAM-452x**

When the host computer or terminal only has a RS-232 port, an ADAM Isolated RS-232/RS-485 Converter is required. Since this module is not addressable by the host, the baud rate must be reset using a switch inside the module. The factory default setting is 9600 baud.

### **ADAM Repeater (optional): ADAM-451x**

When communication lines exceed 4000 ft (1200 meter) or more than 32 ADAM modules are connected, a repeater should be implemented. In a network, up to eight Repeater modules can be connected allowing connection up to 255 ADAM modules. As with the Converter module, the Repeater module is not addressable by the host and the baud rate must be reset by changing the switch inside the module. The factory default setting is 9600 baud.

# Installation Guideline

---


## 2.2 Basic configuration and hook-up

Before placing a module in an existing network, the module should be configured. Though all modules are initially configured at the factory, it is recommended to check if the baud rate is set correctly beforehand.

### Default Factory Settings

Baud rate: 9600 Bit/sec.  
Address: 01 (hexadecimal)

The basic hook-up for module configuration is shown below.



**Figure 2-2 Basic Hook-up of ADAM Module to Host Switches**

The following items are required to configure a module: an ADAM converter module, a personal computer with RS-232 port (baud rate set to 9600) and the ADAM utility software.

### **Configuration with the ADAM Utility Software**

The easiest way to configure the ADAM module is by using the ADAM utility software. It is a user friendly structured menu program that will guide you through every step of the configuration. (See Appendix D, Utility Software)

### **Changing the protocol from ADAM ASCII to Modbus**

Some ADAM-4000 modules support both ADAM ASCII and Modbus protocols, and the factory default setting of these modules is ADAM ASCII protocol. If you would like to configure the modules to Modbus protocol, please refer to Appendix H which describes how to change the protocol in ADAM utility.

### **Configuration with the ADAM command set**

ADAM modules can also be configured by issuing direct commands through a terminal emulation program that is part of the ADAM utility software. The following example will guide you through the setup of an analog input module. Assume an ADAM-4011 Analog Input module still has its default settings (baud rate 9600 and address 01h), and you are being requested to send its default settings before any reconfiguration is made.

***NOTICE: An analog input module requires a maximum of 7 seconds to perform auto calibration and ranging after reboot or start up. During this time span, the module can not be addressed to perform any other actions.***

### **Example:**

Make sure that the module is properly connected and turn on all the connected devices. Then, start the terminal emulation program, and type in the following command:

```
$012(cr)
```

The command above requests the module with address 01 to send its configuration status

```
!01050600
```

## Installation Guideline

---

Module at address 01 responds that it is configured for an input range of +/-2.5 V, baud rate of 9600, integration time of 50 ms (60 Hz). The code also shows engineering units and no checksum checking or generation.

To change the configuration setting of the analog input module, the following command is issued:

```
%01070F0600(cr)
```

% = change configuration

01 = target module at address 00 to:

07 = change address to 07 hexadecimal

0F = set input range to Type K thermocouple

06 = set baud rate to 9600

00 = set integration time to 50 ms (60 Hz)

    disable checksum

    set data format to engineering units

(Please refer to Chapter 4, a full description of Command set syntax for an analog input module)

When the module received the configuration command, it will respond with its new address as shown below:

```
!07(cr)
```

Before giving more commands to the module, please wait for 7 seconds to let the new configuration settings to take effect.

***NOTICE: All reconfiguration except for changing baud rate and checksum values can be done dynamically, and the modules are not required to reset. However, all the connected devices are required to reset by turning power off and on after the baud rate or checksum values are changed. The baud rate or checksum values should be the same for all the connected devices after the reconfiguration. See the next page for a strategy in changing baud rate and checksum of the network.***

### 2.3 Baud rate and Checksum

ADAM modules contain EEPROMs to store configuration information and calibration constants. The EEPROM replaces the conventional array of switches and pots that are originally used for specifying baud rate, input and output range... etc.

Since there is no visual indication of a module's configuration status, it is impossible to know the baud rate, address and other settings just by looking at it. It might not be possible to establish communications with a module whose baud rate and address are unknown. To overcome this problem, most modules have an input terminal labeled INIT\*. Booting the module while connecting the INIT\* terminal with the module's GND terminal forces the configuration into a known state called the INIT\* state. Besides, some newer modules have INIT switch which you can set "Init" or "Normal" (See Figure 2.4). If you set the switch to "Init", then it becomes INIT\* state.

#### **INIT\* state defaults:**

Baud rate: 9600

Address: 00h

Checksum: disabled

Forcing the module in INIT\* state does not change any parameters in the module's EEPROM. When the module is in the INIT\* state with its INIT\* and GND terminals shorted, all configuration settings can be changed, and the module will respond to all other commands normally.

#### **Changing Baud rate and Checksum**

Baud rate and checksum settings have several things in common:


- They should be the same for all modules and host computer.
- Their settings can only be changed by putting a module in the INIT\* state.
- Changed settings can only take effect after a module is rebooted

To alter baud rate or checksum settings, you must perform the following steps:


## Installation Guideline

---

- Power on all components except the ADAM Module.
- Power the ADAM module on while shorting the INIT\* and GND terminals (See Figure 2-3) or set the INIT switch to “Init” (See Figure 2-4)



**Figure 2-3** *Grounding the INIT\* Terminal*



**Figure 2-4** *Set INIT switch to “Init”*

- Configure the checksum status and/or the baud rate.
- Switch the power OFF to the ADAM Module.
- Remove the grounding of the INIT\* terminal and turn on the module, or set the INIT switch to “Normal”.
- Check the settings (If the baud rate has changed, the settings on the host computer should be changed accordingly).



2.4 Multiple Module Hookup

The Figure below is an example of how ADAM modules are connected in a multiple module network:





Figure 2-5 Multi-module Connection

# Installation Guideline


## 2.5 Programming Example

The following example is a simple program written in Visual Basic 6.0 that demonstrates how to get temperature reading which is stored in the address of 01H from ADAM-4011 module.


**Step 1.** Using ADAM Utility to check the settings as the following below: “Address = 01H”, “Baud rate = 9600” and “Checksum = Disabled”.




**Step 2.** Run VB 6.0 and add a control via “Project/Component”.



## Step 3. Select “Microsoft Comm Control”




## Step 4. Add the Comm Control on the form.




# Installation Guideline


**Step 5.** Add three Command Buttons on the form as shown below




**Step 6.** Add one Label and one Text on the form as shown below.



**Step 7.** Click OPEN Button and type in the following codes. The source codes are listed at the end of this section.




**Step 8.** Click SEND Button and type in the following codes. The source codes are listed at the end of this section.




# Installation Guideline

**Step 9.** Click CLOSE Button and type in the following codes. The source codes are listed at the end of this section.



**Step 10.** Run the Project → Click OPEN to open COM1 → Click SEND to send the Get Temperature Reading Command. Now, you will find the reading the same as the displayed format shown below.



### Program Source Codes:

#### ♦ OPEN Command Button:

```
Private Sub Command1_Click()  
    ' Buffer to hold input string  
    Dim Instring As String  
    ' Use COM1.  
    MSComm1.CommPort = 1  
    ' 9600 baud, no parity, 8 data, and 1 stop bit.  
    MSComm1.Settings = "9600,N,8,1"  
    ' Tell the control to read entire buffer when Input  
    ' is used.  
    MSComm1.InputLen = 0  
    ' Open the port.  
    MSComm1.PortOpen = True  
End Sub
```

#### ♦ SEND Command Button:

```
Private Sub Command2_Click()  
    ' Send Get AI command to ADAM-4011 Module at address 01H.  
    MSComm1.Output = "#01" & Chr$(13)  
    ' Wait for data to come back to the serial port.  
    Do  
        DoEvents  
    Loop Until InStr(Buffer$, vbCr)  
    ' Read the response till the carriage return character.  
    Text1.Text = Buffer$  
    ' Display the reading.  
End Sub
```

#### ♦ CLOSE Command Button

```
Private Sub Command3_Click()  
    ' Close the serial port.  
    MSComm1.PortOpen = False  
End Sub
```

I/O Modules

3



# I/O Modules

---

## 3.0 The common specification of ADAM-4000 I/O Series

### Communication:

- RS-485 (2-wire) to host
- Speeds: 1200, 2400, 4800, 9600, 19200, 38400, 57600, 115200 bps (ADAM-4080, ADAM-4080D only support up to 38400 bps)
- Max. communication distance: 4000 feet (1.2 km)
- Power and communication LED indicator
- ASCII command/response protocol
- Communication error checking with checksum
- Asynchronous data format: **1** start bit, **8** data bits, **1** stop bit, **no** parity (**N, 8, 1**)
- Up to 256 multidrop modules per serial port
- Online module insertion and removal
- Transient suppression on RS-485 communication lines

### Power Requirement:

- Unregulated +10 ~ +30 V<sub>DC</sub>
- Protected against power reversal

### Mechanical:

- **Case** ABS+PC with captive mounting hardware
- **Plug-in screw** Accepts 0.5 mm<sup>2</sup> to 2.5 mm<sup>2</sup>,
- **Terminal block** #14 ~22 or #14~28 AWG

### Environment

- **EMI** Meets FCC Class A or CE
- **Operating Temperature** -10 ~ 70° C (14 ~ 158° F)
- **Storage Temperature** -25 ~ 85° C (-13 ~ 185° F)
- **Humidity** 5 ~ 95%, non-condensing

### **3.1 ADAM-4011/4011D Thermocouple Input Modules**

The ADAM-4011/4011D Thermocouple Input Modules use a microprocessor-controlled integrating A/D converter to convert sensor voltage, current or thermocouple signal into digital data. The digital data is then translated into either two's complement hexadecimal format or percentage of full-scale range (FSR) according to the module's configuration. When prompted by the host computer, the data is sent through a standard RS-485 interface.

The ADAM-4011/4011D Thermocouple Input Modules offer signal conditioning, A/D conversion, ranging, and RS-485 digital communication functions. They protect your equipment from power surges at the ground terminal by providing opto-isolation of the A/D input and transformer based isolation up to 3000 V<sub>DC</sub>. (ADAM-4011 has transformer-based isolation up to 500 V<sub>DC</sub>)

#### **Open Thermocouple Detection and Input Surge Protection (ADAM-4011D only)**

The ADAM-4011D provides an open thermocouple detection function. Users can use a simple command to detect whether the thermocouple is opened or closed. The module also provides surge protection on its input channel. Internal high-speed transient suppressor on its input channel protects the module from dangerous spikes and voltages.

#### **Front Panel LED Indicator (ADAM-4011D only)**

The 4½ digits LED display on the back of the ADAM-4011D lets you monitor the process readings right at their source. The module displays readings in a wide variety of formats as well as high-low alarm messages. The ADAM-4011D offers flexibility, easy installation, and direct availability of process data. For critical process monitoring, this module is the ideal choice.

#### **Digital Input/Output**

The ADAM-4011/4011D Thermocouple Input Modules also contain two digital outputs and one digital input. Outputs are open-collector transistor switches that may be controlled by the host computer. They can control solid-state relays, which may be used to control heaters, pumps, and other electrical powered equipment. The digital inputs may be read by the host computer and used to sense the state of a remote digital signal.

## I/O Modules

---

### Event counting

The event counter is connected to the Digital Input channel and can be used to keep track of the total amount of external low-speed pulses. Its accumulated maximal count is 65535. The count will maintain at 65535 even if the actual number of events exceeds 65535. The counter can be read or reset to zero by the host computer.

Since the Event counter's data are not stored in EEPROM, the event counter is cleared and set to zero after every reset or start up of the analog input module.

### Alarm signaling

Analog input modules include High and Low alarm functions. High and Low alarm limits may be downloaded into the module's EEPROM by the host computer.

The alarm functions can be enabled or disabled remotely. When the alarm function is enabled, both Digital Output channels are used to indicate the High and Low alarm state. Digital Output channel 1 (DO1) equals to High alarm state, and Digital Output channel 0 (DO0) equals to Low alarm state. The High and Low alarm states can be read at any time by the host computer.

Every A/D conversion will be followed by a comparison with the High and Low limit. When the input value exceeds one of these limits, the High or Low alarm state is set to ON.

There are two alarm mode options, Momentary and Latching. If the alarm is in Latching mode, the alarm will stay on even if the input value returns within the limits. An alarm in Latching mode can be turned OFF by giving a Clear Alarm command from the host computer. A Latching alarm is cleared by the module when the opposite alarm is set. When the module receives a value that is lower than the Low alarm limit, it will clear the High alarm and turn the Low alarm ON.

When the alarm is in Momentary mode, the alarm will be turned OFF as soon as the input value returns within the limits.

The arrangement of coupling High and Low alarm states with Digital Output lines may be utilized to build ON/OFF controllers that can operate without the involvement of host computer.

### Function Description for the ADAM-4011 Thermocouple Input Module

To provide a better understanding of the ADAM module functions, the following is a description of the module ADAM-4011 with the most extensive set of functions.

All analog input data first flow through the PGA (programmable gain amplifier). The amplifier can vary its gain from 1 to 128. The PGA then automatically adjusts the signal to a range from -2.5 V to +2.5 V. This ensures an optimal input voltage and resolution for the A/D converter.

The A/D conversion is supervised by the microprocessor that holds the calibration software. Two kinds of calibrations, Auto Zero and Auto Span calibrations, take place automatically in startup or reset. Normal calibration is used to adjust the signal according to calibration parameters defined by the user.

The digital 10 Hz filter provides a steady state output by using the  $\Delta$  function.

Before the data enter the microprocessor, they pass through an optical isolation device which prevents the chance of circuit damaging caused by power surges from the ground terminal.

The microprocessor has six basic functions:

- Linearization of T/C (Thermocouple)
- Communication software and command set
- Calibration software
- Alarm monitoring
- Event counting
- Management of the EEPROM device that holds the system parameters
- Data transformation

After data have been transformed to the right data format, they are being passed on to the RS-485 output port.

If an input value exceeds the High alarm setting or falls below the Low alarm setting, a flag is set in one of the Digital Output channels.

Finally, the on-board switching regulator accepts voltage between +10 and +30 V<sub>DC</sub>, and it has an isolation value of 500 V<sub>DC</sub> to protect your equipment from damages caused by power surges.

## ADAM-4011 Thermocouple Input Module




Figure 3-1 ADAM-4011 Thermocouple Input Module

Accepts:


- J, K, T, E, R, S and B thermocouples
- Millivolt inputs:  $\pm 15$  mV,  $\pm 50$  mV,  $\pm 100$  mV and  $\pm 500$  mV
- Volt inputs:  $\pm 1$  V and  $\pm 2.5$  V
- Current input:  $\pm 20$  mA (Requires a 125  $\Omega$  resistor)

Two digital output channels and one digital input channel are provided.

Depending on the module's configuration setting, it can forward the data to the host computer in one of the following formats:

- Engineering units ( $^{\circ}$ C, mV, V or mA)
- Percent of full-scale range (FSR)
- Two's complement hexadecimal

## ADAM-4011D Thermocouple Input Module



**Figure 3-2** ADAM-4011D Thermocouple Input Module with LED Display

Accepts:

- J, K, T, E, R, S and B thermocouples
- Millivolt inputs:  $\pm 15\text{ mV}$ ,  $\pm 50\text{ mV}$ ,  $\pm 100\text{ mV}$  and  $\pm 500\text{ mV}$
- Volt inputs:  $\pm 1\text{ V}$  and  $\pm 2.5\text{ V}$
- Current input:  $\pm 20\text{ mA}$  (Requires a 125 resistor)

Two digital output channels and one digital input channel are provided.

Depending on the module's configuration setting, it can forward the data to the host computer in one of the following formats:

- Engineering units ( $^{\circ}\text{C}$ ,  $\text{mV}$ ,  $\text{V}$ , or  $\text{mA}$ )
- Percent of full-scale range (FSR)
- Two's complement hexadecimal

# I/O Modules

## Application Wiring




Figure 3-3 ADAM-4011/4011D Thermocouple Input Wiring Diagram




Figure 3-4 ADAM-4011/4011D Millivolt and Volt Input Wiring Diagram







Figure 3-5 ADAM-4011/4011D Process Current Input Wiring Diagram



**Figure 3-6 ADAM-4011/4011D Digital Output Wiring Diagram  
Used with SSR (HI-LO alarm)**



**Figure 3-7 ADAM-4011/4011D Digital Input Wiring Diagram  
Used with TTL**



**Figure 3-8 ADAM-4011/4011D Digital Input Wiring Diagram  
Used with Dry contact**



### 3.2 ADAM-4012 Analog Input Module

The ADAM-4012 Analog Input Modules use a microprocessor-controlled integrating A/D converter to convert sensor voltage or current signals into digital data. The digital data are then translated into either two's complement hexadecimal format or percentage of full-scale range (FSR) according to the module's configuration. When prompted by the host computer, the data are sent through a standard RS-485 interface.

The ADAM-4012 Analog Input Modules offer signal conditioning, A/D conversion, ranging, and RS-485 digital communication functions. They protect your equipment from power surges at the ground terminal by providing opto-isolation of the A/D input and up to 3000 V<sub>DC</sub> transformer based isolation.

#### Digital Inputs/Outputs

The ADAM-4012 also contains two digital outputs and one digital input. Outputs are open-collector transistor switches that may be controlled by the host computer. They can control solid-state relays, which can be applied to heaters, pumps, and other electrical powered equipment. The digital inputs may be read by the host computer and used to sense the state of a remote digital signal.

#### Event counting

The event counter is connected to the Digital Input channel and can be used to keep track of the total amount of external low-speed pulses. Its accumulated maximal count is 65535. The number 65535 is held even if the actual number of events exceeds 65535. The counter can be read or reset to zero by the host computer.

Since the Event counter's data are not stored in EEPROM, the event counter is cleared and set to zero after every reset or start up of the analog input module.

### Alarm signaling

Analog input modules include High and Low alarm functions. High and Low alarm limits may be downloaded into the module's EEPROM by the host computer.

The alarm functions can be enabled or disabled remotely. When the alarm function is enabled, both Digital Output channels are used to indicate the High and Low alarm states. Digital Output channel 1 (DO1) equals to High alarm state, and Digital Output channel 0 (DO0) equals to Low alarm state. The High and Low alarm states can be read at any time by the host computer.

Every A/D conversion will be followed by a comparison with the High and Low limit. When the input value exceeds one of these limits, the High or Low alarm state is set to ON.

There are two alarm mode options, Momentary and Latching.


If the alarm is in Latching mode, the alarm will stay on even when the input value returns within the limits. It can also be turned OFF by issuing a Clear Alarm command from the host computer. A Latching alarm is cleared by the module when the opposite alarm is set.

When the module receives a value that is lower than the Low alarm limit, it will clear the High alarm and turn the Low alarm ON.

When the alarm is in Momentary mode, the alarm will be turned OFF as soon as the input value returns within the limits.

The arrangement of coupling High and Low alarm states with Digital Output lines may be utilized to build ON/OFF controllers that can operate without involving the host computer.

## ADAM-4012 Analog Input Module



**Figure 3-9 ADAM-4012 Analog Input Module**

Accepts:

- Millivolt inputs  $\pm 150$  mV and  $\pm 500$  mV
- Volt inputs:  $\pm 1$  V,  $\pm 5$  V and  $\pm 10$  V
- Current input:  $\pm 20$  mA (requires a 125 resistor)

Two digital output channels and one digital input channel are provided.

Depending on the module's configuration setting, it can forward the data to the host computer in one of the following formats:

- Engineering units (mV, V, or mA)
- Percent of full-scale range (FSR)
- Two's complement hexadecimal

Application Wiring




Figure 3-10 ADAM-4012 Millivolt and Volt Input Wiring Diagram




Figure 3-11 ADAM-4012 Process Current Input Wiring Diagram






Figure 3-12 ADAM-4012 Digital Output Wiring Diagram  
Used with SSR (HI-LO alarm)

## I/O Modules

---




**Figure 3-13 ADAM-4012 Digital Input Wiring Diagram Used with TTL**



**Figure 3-14 ADAM-4012 Digital Input Wiring Diagram Used with Dry contact**

## 3.3 ADAM-4013 RTD Module

The ADAM-4013 RTD Input Module supports one Pt or Ni RTD input channel for temperature measurement. This module can accept RTD sensors with two, three, or four wires. The module offers signal conditioning, A/D conversion, ranging, and RS-485 digital communication functions. It protects your equipment from power surges at the ground terminal by providing opto-isolation of the A/D input and up to 3000 V<sub>DC</sub> transformer based isolation.



**Figure 3-15 ADAM-4013 RTD Input Module**

Accepts:

- Input from platinum and nickel RTDs


Depending on the module's configuration setting, it can forward the data to the host computer in one of the following formats:

- Engineering units (°C)
- Percent of full-scale range (FSR)
- Two's complement hexadecimal

# I/O Modules

---

## Application Wiring




**Figure 3-16 ADAM-4013 RTD Inputs Wiring Diagram**

## 3.4 ADAM-4015 6-channel RTD Input Module

A RTD module is popularly used for temperature measurement. Unlike the traditional design, the ADAM-4015 RTD Input Module provides six RTD input channels for different types of RTD signal like as Pt, Ni, Balco. It is an effective solution in industrial & building automation. Normally, broken external wire will lead to an inaccurate current value; however, the ADAM-4015 provides a broken wire detecting function. Therefore, users can easily fix the broken wire problems. This module can accept RTD sensors that have two or three wires. After the V2.04 of ADAM-4015, ADAM-4015 can support the “BA1 -200~600°C”

*Please be noted that the pin 26 is defined as GND and it's reserved.*



**Figure 3-17 ADAM-4015 6-channel RTD Input Module**



## Application Wiring




Figure 3-18 ADAM-4015 RTD Input Module Wiring Diagram

## Technical specification of ADAM-4015

|   |  |
|---|--|
| <b>Channel Number</b>                   | 6 differential   |
| <b>Support Protocol</b>                 | ADAM ASCII and MODBUS/RTU  |
| <b>Input Type</b>                       | Pt100, Pt1000, BALCO500, Ni  |
| <b>Input Connections</b>                | 2 or 3 wires   |
| <b>Wire Burnout Detection</b>           | Yes  |
| <b>Input Type and Temperature Range</b> | Pt100: -50 to 150° C<br>0 to 100° C<br>0 to 200° C<br>0 to 400° C<br>-200 to 200° C<br><br>Pt1000: -40 to 160° C<br><br>Balco500: -30 to 120° C<br><br>Ni 50 RTD: -80 to 100° C<br><br>Ni 508 RTD: 0 to 100° C |
| <b>Isolation Voltage</b>                | 3000 V <sub>DC</sub>   |
| <b>Sampling Rate</b>                    | 10 sample/second (total)   |
| <b>Input Impedance</b>                  | 10 MΩ  |
| <b>Resolution</b>                       | 16-bit   |
| <b>Accuracy</b>                         | ±0.1% or better  |
| <b>CMR@50/60Hz</b>                      | 120 dB   |
| <b>NMR@50/60Hz</b>                      | 100 dB   |
| <b>Span Drift</b>                       | ± 25 ppm/°C  |
| <b>Zero Drift</b>                       | ± 3 μV/°C  |
| <b>Watchdog Timer</b>                   | System (1.6 second) and Communication  |
| <b>Power Input</b>                      | +10~+30 V <sub>DC</sub> (non-regulated)  |
| <b>Power Consumption</b>                | 1.2 W @ 24V <sub>DC</sub>  |

**Table 3-1 Technical specification of ADAM-4015**

# I/O Modules

## 3.5 ADAM-4015T 6-channel Thermistor Input Module

A Thermistor Module is popularly used for temperature measurement. Unlike the traditional design, the ADAM-4015T provides six thermistor input channels for thermistor signal. It is an effective solution in industrial & building automation. Normally, broken external wires will lead to an inaccurate current value. The ADAM-4015T provides a broken wire detecting function, so users can easily fix the problems.




Figure 3-19 ADAM-4015T 6-channel Thermistor Input Module

### Application Wiring




Figure 3-20 ADAM-4015T Thermistor Input Module Wiring Diagram

**Technical specification of ADAM-4015T**

|   |   |
|---|---|
| <b>Channel Number</b>                   | 6 differential  |
| <b>Support Protocol</b>                 | ADAM ASCII and MODBUS/RTU   |
| <b>Input Type</b>                       | Thermistor  |
| <b>Input Connections</b>                | 2 or 3 wires  |
| <b>Wire Burnout Detection</b>           | Yes   |
| <b>Input Type and Temperature Range</b> | Thermistor 3k 0~100°C (9.796K ohm ~ 203.8 ohm)<br>Thermistor 10k 0~100°C (29.49K ohm ~ 816.8 ohm) |
| <b>Isolation Voltage</b>                | 3000 V <sub>DC</sub>  |
| <b>Sampling Rate</b>                    | 10 sample/second (total)  |
| <b>Input Impedance</b>                  | 10 MΩ   |
| <b>Resolution</b>                       | 16-bit  |
| <b>Accuracy</b>                         | ±0.1% or better   |
| <b>CMR@50/60Hz</b>                      | 120 dB  |
| <b>NMR@50/60Hz</b>                      | 100 dB  |
| <b>Span Drift</b>                       | ± 25 ppm/°C   |
| <b>Zero Drift</b>                       | ± 3 μV/°C   |
| <b>Watchdog Timer</b>                   | System (1.6 second) and Communication   |
| <b>Power Input</b>                      | +10~+30 V <sub>DC</sub> (non-regulated)   |
| <b>Power Consumption</b>                | 1.2 W @ 24V <sub>DC</sub>   |

**Table 3-2 Technical specification of ADAM-4015T**

### 3.6 ADAM-4016 Analog Input/Output Module

A strain gauge input module uses a microprocessor-controlled integrating A/D converter to convert sensor voltage or current signals into digital data for load cell and stress measurement. The digital data are then translated into either, two's complement hexadecimal format or percentage of full-scale range (FSR) according to the module's configuration. When prompted by the host computer, the data are sent through a standard RS-485 interface.

The strain gauge input module offers signal conditioning, A/D conversion, ranging, and RS-485 digital communication functions. They protect your equipment from power surges at the ground terminal by providing opto-isolation of the A/D input and up to 3000 V<sub>DC</sub> transformer based isolation.

#### Excitation Voltage Output

A strain gauge input module can supply single channel voltage output for excitation. The module receives digital input from the host computer, and the format of the data is engineering units. It then uses its microprocessor-controlled D/A converter to convert the digital data into output signals.

Strain gauge input modules protect your equipment from power surges at the ground terminal by providing opto-isolation of the D/A output and up to 3000 V<sub>DC</sub> transformer-based isolation.

#### Digital Outputs

A strain gauge input module also contains four digital outputs. Outputs are open-collector transistor switches that may be controlled by the host computer. They can control solid-state relays which can be applied to heaters, pumps, and other electrical controlled equipments.

#### Alarm signaling

Strain Gauge input modules include High and Low alarm functions. High and Low alarm limits may be downloaded into the module's EEPROM by the host computer.

The alarm functions can be enabled or disabled remotely. When the alarm function is enabled, both Digital Output channels are used to indicate the High and Low alarm states. Digital Output channel 1 (DO1) equals to High alarm state and Digital Output channel 0 (DO0) equals to Low alarm state. The High and Low alarm state can be read at any time by the host computer.

Every A/D conversion will be followed by a comparison with the High and Low limits. When the input value exceeds one of these limits, the High or Low alarm state is set to ON.

There are two alarm mode options, Momentary and Latching. If the alarm is in Latching mode, the alarm will stay on even when the input value returns within limits. An alarm in Latching mode can be turned OFF by issuing a Clear Alarm command from the host computer. A Latching alarm is cleared by the module when the opposite alarm is set.

When the module receives a value that is lower than the Low alarm limit, it will clear the High alarm and turn the Low alarm ON.

When the alarm is in Momentary mode, the alarm will be turned OFF as soon as the input value returns to within limits.

The arrangement of coupling High and Low alarm states with Digital Output lines may be utilized to build ON/OFF controllers that can operate without the host computer involvement.

## ADAM-4016 Analog Input/Output Module




Figure 3-21 ADAM-4016 Analog Input/Output Module

Accepts:

- Millivolt inputs:  $\pm 15$  mV,  $\pm 50$  mV,  $\pm 100$  mV,  $\pm 500$  mV
- Current input:  $\pm 20$  mA

Excitation voltage output: 0 ~ 10 V

Four digital output channels are provided.

Depending on the module's configuration setting, it can forward the data to the host computer in one of the following formats:

- Engineering units (mV or mA)
- Percent of full-scale range (FSR)
- Two's complement hexadecimal

Application Wiring




Figure 3-22 ADAM-4016 Strain Gauge Voltage Input Wiring Diagram





Figure 3-23 ADAM-4016 Strain Gauge Current Input Wiring Diagram





**Figure 3-24 ADAM-4016 Digital Output Wiring Diagram Used with SSR**

### 3.7 ADAM-4017/4017+/4018/4018M/4018+ 8-channel Analog Input Modules

#### **ADAM-4017/4018 8-channel Analog Input Module**

The ADAM-4017/4018 is a 16-bit, 8-channel analog input module that provides programmable input ranges on all channels. This module is an extremely cost-effective solution for industrial measurement and monitoring applications. Its opto-isolated inputs provide 3000 V<sub>DC</sub> of isolation between the analog input and the module, and protect the module and peripherals from damaging due to high input-line voltages.

The ADAM-4017/4018 offers signal conditioning, A/D conversion, ranging and RS-485 digital communication functions. The module protects your equipment from power surges at the ground terminal by providing opto-isolation of A/D input and up to 3000 V<sub>DC</sub> transformer based isolation.

The ADAM-4017/4018 uses a 16-bit microprocessor-controlled sigma-delta A/D converter to convert sensor voltage or current into digital data. The digital data are then translated into engineering units. When prompted by the host computer, the module sends the data to the host through a standard RS-485 interface.

#### **ADAM-4018M 8-channel Analog Input Data logger**

The ADAM-4018M is a 16-bit, 8-channel analog input data logger featuring programmable input ranges on all channels. This reliable and easy to use analog input logger can store up to 38,000 measurements for a maximum duration of 20 years.

The ADAM-4018M can accept various analog inputs such as thermocouple, mV, V and mA. It also offers three configurable logging modes, standard log, event log, and mixed log. Optically isolated inputs provide 3000 V<sub>DC</sub> of isolation between the module and the analog input, and protect the module and peripherals from damaging due to high voltages on the input lines.

The ADAM-4018M is an extremely cost-effective solution for industrial measurement and monitoring applications.

### **ADAM-4017+ 8-channel Differential Analog Input Module**

Here comes a solution to the demand for more analog input channels. Similar to its counterpart, the ADAM-4017+ enables eight differential channels with multiple input ranges. This multi-channel/multi-range structure allows channels with different input ranges at the same time. For example, channel 1 can have the range  $\pm 5V$  meanwhile the others are  $\pm 10V$  and  $\pm 20\text{ mA}$ .


Instead of leaving two single-ended channels in ADAM-4017 module due to the limit number of pins, ADAM-4017+ uses a switch to switch AGND and INIT\* to Vin6- and Vin7- respectively to allow 8-channel input. Moreover, the ADAM-4017+ has been expanded to accept  $4 \sim 20\text{ mA}$ , so the user can employ it in various applications

### **ADAM-4018+ 8-channel Thermocouple Input Module**

Here comes a solution to the demand for more thermocouple input channels. Similar to its counterpart, the ADAM-4018+ enables eight differential channels with multiple input types. This multi-channel/multi-type structure allows synchronizing channels with different types of input. For example, channel 1 has K type of input meanwhile the others have R and S types.

ADAM-4018+ is an 8-channel T/C input module. Comparing with the universal analog input module ADAM-4019, it is more dedicated to T/C and  $4 \sim 20\text{ mA}$  inputs for those with special request. It improves ADAM-4018 with the traditional design of six differential and two single-ended channels. It also enhances the steadiness and reliability of the wiring. Normally, broken external wires will lead to an inaccurate current value. ADAM-4018+, however, provides burned-out detection that allows users to fix the problems easily. ADAM 4018+ has build in Shunt.

## ADAM-4017 8-channel Analog Input Module



**Figure 3-25 ADAM-4017 8-channel Analog Input Module**

Channels:

- Six differential, two single-ended

Accepts:

- Millivolt inputs:  $\pm 150$  mV and  $\pm 500$  mV
- Volt inputs:  $\pm 1$  V,  $\pm 5$  V, and  $\pm 10$  V
- Current input:  $\pm 20$  mA (requires a 120 resistor)

The module forwards the data to the host computer in engineering units (mV, V or mA)

## ADAM-4017+ 8-channel Differential Analog Input Module




Figure 3-26 ADAM-4017+ 8-ch. differential analog input module

### Jumper setting (ADAM-4017+)

#### 1. JP0~JP7

|                    |      |                     |      |      |      |      |      |      |
|--------------------|------|---------------------|------|------|------|------|------|------|
| JP0~JP7            |      | 20 mA Input Range   |      |      |      |      |      |      |
|                    |      | Voltage Input range |      |      |      |      |      |      |
| Mapping to Channel | Ch.0 | Ch.1                | Ch.2 | Ch.3 | Ch.4 | Ch.5 | Ch.6 | Ch.7 |
|                    | JP 0 | JP 1                | JP 2 | JP 3 | JP 4 | JP 5 | JP 6 | JP 7 |

- JP12 can Enable/Disable Watchdog Timer Function. The default setting is closed, i.e., Watchdog Timer Function Enabled. Please always keep JP12 closed and enable/disable the watchdog timer function in ADAM-utility.

---

**Technical specification of ADAM-4017+**

|                                   |  |
|-----------------------------------|--|
| Channel                           | 8  |
| Input Type                        | mV, V, mA  |
| Input Range                       | $\pm 150$ mV, $\pm 500$ mV, $\pm 1$ V, $\pm 5$ V, $\pm 10$ V,<br>$\pm 20$ mA, 4 ~ 20 mA<br>Current Input doesn't need an external resistor |
| Isolation Voltage                 | 3000 V <sub>DC</sub>   |
| Fault and Over-voltage protection | With stands over-voltage up to $\pm 35$ V  |
| Sampling Rate                     | 10 sample/sec (total)  |
| Input Impedance                   | Voltage: 20 M $\Omega$ , Current: 120 $\Omega$   |
| Accuracy                          | $\pm 0.1\%$ or better  |
| Power Consumption                 | 1.2 W @ 24V <sub>DC</sub>  |
| I/O Connector Type                | 10 pin plug-in terminal  |

**Table 3-3 Technical specification of ADAM-4017+**

## ADAM-4018 8-channel Analog Input Module




Figure 3-27 ADAM-4018 8-channel Thermocouple Input Module

Channels:

- Six differential, two single-ended

Accepts:

- J, K, T, E, R, S and B thermocouples
- Millivolt inputs:  $\pm 15$  mV,  $\pm 50$  mV,  $\pm 100$  mV and  $\pm 500$  mV
- Volt inputs:  $\pm 1$  V and  $\pm 2.5$  V
- Current input:  $\pm 20$  mA (requires a 125 resistor)

The module forwards the data to the host computer in engineering units ( $^{\circ}\text{C}$ , mV, V or mA)

## ADAM-4018M 8-channel Analog Input Data logger




Figure 3-28 ADAM-4018M 8-channel Analog Input Data Logger

Channels:

- Six differential, two single-ended

Accepts:

- J, K, T, E, R, S and B thermocouples
- Millivolt inputs:  $\pm 15$  mV,  $\pm 50$  mV,  $\pm 100$  mV,  $\pm 500$  mV
- Volt inputs:  $\pm 1$  V and  $\pm 2.5$  V
- Current input:  $\pm 20$  mA (requires a 125 resistor)

The module forwards the data to the host computer in engineering units ( $^{\circ}\text{C}$ , mV, V, or mA)

Storage Capacity:

- 128 KB flash memory



## ADAM-4018+ 8-channel Thermocouple Input Module




Figure 3-29 ADAM-4018+ 8-ch. thermocouple input module

|                    |  |                     |      |      |      |      |      |      |      |
|--------------------|--|---------------------|------|------|------|------|------|------|------|
| JP0~JP7            |  | 4~20 mA Input Range |      |      |      |      |      |      |      |
|                    |  | Voltage Input range |      |      |      |      |      |      |      |
| Mapping to Channel |  | Ch.0                | Ch.1 | Ch.2 | Ch.3 | Ch.4 | Ch.5 | Ch.6 | Ch.7 |
|                    |  | JP 0                | JP 1 | JP 2 | JP 3 | JP 4 | JP 5 | JP 6 | JP 7 |


### Technical specification of ADAM-4018+

|                          |   |
|--------------------------|---|
| Channel                  | 8   |
| Input Type               | Thermocouple  |
| Input range and T/C type | ±20 mA, 4~20 mA<br>J 0 ~ 760° C<br>K 0 ~ 1370° C<br>T -100 ~ 400° C<br>E 0 ~ 1000° C<br>R 500 ~ 1750° C<br>S 500 ~ 1750° C<br>B 500 ~ 1800° C |


|                                   |                                     |
|-----------------------------------|-------------------------------------|
| Isolation Voltage                 | 3000 V <sub>DC</sub>                |
| Fault and over-voltage protection | Withstands over voltage up to ±35 V |
| Sampling Rate                     | 10 sample/sec (total)               |
| Input Impedance                   | Voltage: 20 MΩ, Current: 120Ω       |
| Accuracy                          | ±0.1% or better                     |
| Power Consumption                 | 0.8 W @ 24V <sub>DC</sub>           |
| I/O Connector Type                | 10 pin plug-in terminal             |

**Table 3-4 Technical specification of ADAM-4018+**

## Application Wiring



**Figure 3-30 Current Input Wiring Diagram of ADAM-4017**



**Figure 3-31(a) ADAM-4017 Differential Input Wiring Diagram (Ch0 ~ Ch5)**

# I/O Modules




Figure 3-31(b) ADAM-4017 Single-ended Input Wiring Diagram (Ch6 and Ch7)




Figure 3-32 ADAM-4017+ Voltage and Current Input Wiring Diagram




Figure 3-33 ADAM-4018+ Thermocouple Input Wiring Diagram

### 3.8 ADAM-4019+ 8-channel Universal Analog Input Module

The ADAM-4019+ is universal analog input module to integrate with various AI modules into one. It not only reduces the hardware cost, but also simplifies the wiring complexity. Furthermore, the ADAM-4019+ provides the burnt-out detection functionality for 4~20mA and all thermocouple input.

# I/O Modules






Figure 3-34 ADAM-4019+ 8-channel Universal Analog Input

The jumper setting of ADAM-4019+ for input type selection:

|                    |  |                     |      |      |      |      |      |      |
|--------------------|--|---------------------|------|------|------|------|------|------|
| JP0~JP7            | <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> | 20mA Input Range    |      |      |      |      |      |      |
|                    | <input type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> | Voltage Input range |      |      |      |      |      |      |
| Mapping to Channel | Ch.0   | Ch.1                | Ch.2 | Ch.3 | Ch.4 | Ch.5 | Ch.6 | Ch.7 |
|                    | JP 0   | JP 1                | JP 2 | JP 3 | JP 4 | JP 5 | JP 6 | JP 7 |

**\*It is built the 120Ω resistor inside under current input mode**

Application Wiring



***\*It is built the 120  $\Omega$  resistor inside under current input mode***




Figure 3-35 ADAM-4019+ Universal Analog Input Wiring Diagram

## I/O Modules

---

### Technical specification of ADAM-4019+

|                                  |   |
|----------------------------------|---|
| Channel                          | 8   |
| Resolution                       | 16 bits   |
| Input Type                       | V, mV, mA, T/C  |
| Input type and temperature range | V: $\pm 1$ V, $\pm 2.5$ V, $\pm 5$ V, $\pm 10$ V<br>mV: $\pm 100$ mV, $\pm 500$ mV<br>mA: $\pm 20$ mA (with $120\ \Omega$ resistor)<br>4~20mA (with $120\ \Omega$ resistor)<br>Thermocouple:<br>J 0 to 760 °C<br>K 0 to 1370 °C<br>T -100 to 400 °C<br>E 0 to 1000 °C<br>R 500 to 1750 °C<br>S 500 to 1750 °C<br>B 500 to 1800 °C |
| Isolation Voltage                | 3000 V <sub>DC</sub>  |
| Sampling Rate                    | 10 samples/sec (total)  |
| Input Impedance                  | Voltage: 20 M $\Omega$ , Current: 120 $\Omega$  |
| Accuracy                         | $\pm 0.1\%$ or better   |
| Power Consumption                | 1.0W @ 24V <sub>DC</sub>  |
| I/O Connector Type               | 10 pin plug-in terminal   |
| Burn-out Detection               | 4~20mA and all thermocouple input   |

**Table 3-5 Technical specification of ADAM-4019+**

### 3.9 ADAM-4021 Analog Output Module

Analog output module receives its digital input through an RS-485 interface from the host computer. The format of the data is either two's complement hexadecimal format or percentage of full-scale range (FSR), depending on the module's configuration. It then uses its microprocessor-controlled D/A converter to convert the digital data into output signals.

You will get a true read-back of the analog output signal from the unit's ADC, which monitors the output independently. You can also specify slew rates and start up currents through the configuration software. The Analog Output Module can supply single-channel analog output in a range of voltages or currents.


Furthermore, it will protect your equipment from power surges at the ground terminal by providing opto-isolation of the D/A output and up to 3000 V<sub>DC</sub> transformer based isolation.

#### **Slew Rate**

The slew rate is defined as the discrepancy between the present number of milliamps (or Volts) per second and the required output currents (or voltages). An ADAM analog output module may be configured for a specific slew rate.



## ADAM-4021 Analog Output Module



**Figure 3-36 ADAM -4021 Analog Output Module**


Depending on its configuration settings the module accepts the following formats from the host computer:

- Engineering units
- Percent of full-scale range (FSR)
- Two's complement hexadecimal format,

Output types:

- Voltage: 0 ~ 10 V  
(Slew rate: 0.0625 to 64 V/sec)
- Currents: 0 ~ 20 mA, or 4 ~ 20 mA.  
(Slew rate: 0.125 to 128 mA/sec)

## Application Wiring



**Figure 3-37 ADAM-4021 Analog Output Wiring Diagram**

# I/O Modules

## 3.10 ADAM-4024 4-channel Analog Output Module

ADAM-4024 is a 4-channel analog output module with mixed type I/O. Under some circumstances, it is, however, a demand for multiple analog outputs to fulfill particular applications without many duplicate modules. ADAM-4024 is designed to achieve this purpose by integrating four A/O channels and four isolated D/I channels into only one module. The four digital input channels function as an interlock for emergency latch output.

ADAM-4024 inherited from ADAM-4021, but provide multi-range AO support, allows its four A/O channels working at the same time with different and more output ranges. For example, it can have 4~20 mA and  $\pm 10$  V at its output. To ensure the operation of machines and facilities, ADAM-4024 has the functionality of slew rate control. Output slope is programmable through ramping/clamping the slew rate. Unlike traditional mechanism, ADAM-4024 permits users to substitute its default value at the start up. Users can easily set up and configure the module to be more adaptive.




Figure 3-38 ADAM-4024 4-channel Analog Output Module

### Technical specification of ADAM-4024


- Resolution: 12-bit
- Output Type: mA, V
- Output Range: 0~20 mA, 4~20 mA, and  $\pm 10V$
- Isolation Voltage: 3000 V<sub>DC</sub>
- Output Impedance: 0.5  $\Omega$
- Accuracy:
  - ±0.1% of FSR for current output
  - ±0.2% of FSR for voltage output
- Zero Drift:
  - Voltage output:  $\pm 30 \mu V/^{\circ}C$
  - Current output:  $\pm 0.2 \mu A/^{\circ}C$
- Span Temperature Coefficient:  $\pm 25 \text{ ppm}/^{\circ}C$
- Output Slope Rate:
  - 0.125 ~ 128 mA/sec.
  - 0.0625 ~ 64 V/sec.
- Current Load Resistor: 0 to 500
- Built-in Watchdog Timer
- Isolation Digital Input
  - Channel: 4
  - Level 0: +1V max
  - Level 1: +10~30 V<sub>DC</sub>

# I/O Modules


## Application Wiring




**Voltage :**




**Current :**



**Power Supply :**




**Initial :**




**Isolation Input :**

*Type I : Input Active Low*




*Type II : Input Active High*



**Figure 3-39 ADAM-4024 Pin Define and Wiring Diagram**

## 3.11 ADAM-4050 Digital I/O Module

The ADAM-4050 features seven digital input and eight digital output channels. The outputs are open-collector transistor switches that you can control from the host computer. You can also use the switches to control solid-state relays, which can be applied to equipments such as heaters and pumps. The host computer can use the module's digital inputs to determine the states of limit, safety switches, and remote digital signals.



**Figure 3-40 ADAM-4050 Digital I/O Module**

Channels:

- 7 input channels
- 8 output channels

Digital Input:

- Logic level 0: +1 V max.
- Logic level 1: +3.5 ~ 30 V

Digital Output:

- Open collector to 30 V, 30 mA max. load

# I/O Modules

## Application Wiring




Figure 3-41 ADAM-4050 TTL Input Wiring Diagram




Figure 3-42 ADAM-4050 Contact Closure Input Wiring Diagram




Figure 3-43 ADAM-4050 Digital Output Wiring Diagram Used with SSR

## 3.12 ADAM-4051 16-channel Isolated Digital Input Module

The ADAM-4051 is a 16 channel Digital Input Module. It is built with 2500V<sub>DC</sub> optical isolation, and it is suitable for critical applications. The main difference from other modules is that ADAM-4051 accepts 10 ~ 50V input voltage to fit various digital signals like 12 V, 24 V, and 48 V. Moreover, users can read the current status from the LED indicators on the front panel.




Figure 3-44 ADAM-4051 16-channel Isolated Digital Input Module

- Channel: 16
- Optical Isolation: 2500 V<sub>DC</sub>
- Opto-isolator response time: 25 μs
- Over-voltage Protect: 70 V<sub>DC</sub>
- ESD (Electro Static Discharge): 2000 V<sub>DC</sub>
- LED Indicator: **On**: Active; **Off**: Non-active
- Input Voltage:
  - Dry Contact **Logic level 1**: close to GND, **Logic level 0**: open
  - Wet Contact **Logic level 1**: 10 ~ 50 V, **Logic level 0**: 3 V
- Power consumption: 1W @ 24 V<sub>DC</sub>
- I/O Connector Type: 13 pin plug-in terminal\*2



# I/O Modules

## Application Wiring




Figure 3-45 ADAM-4051 Dry Contact Wiring Diagram




Figure 3-46 ADAM-4051 Wet Contact Wiring Diagram

## 3.13 ADAM-4052 Isolated Digital Input Module

The ADAM-4052 provides eight digital input channels. Among these eight channels, six of them are fully independent isolated channels and the other two are isolated channels with a common ground. They all have  $5000\text{ V}_{\text{RMS}}$  isolation to prevent power surges from the input lines




Figure 3-47 ADAM-4052 Isolated Digital Input Module

Channels: 8

- 6 differential channels (fully independent isolated channels)
- 2 single-ended channels (isolated channels with common ground)

Digital Input:

- Logic level 0: +1 V max.
- Logic level 1: +3 ~ 30 V

# I/O Modules

---

## Application Wiring





Figure 3-48 ADAM-4052 Isolation Digital Input Wiring Ground




## I/O Modules

---

**Note:** There is one pin showing “INIT\*/DI15” on the connector of the ADAM-4053 module. You can configure the pin define by the jumper on PCB (refer to the image below to see its location):



**Jumper Setting:**



Application Wiring




Figure 3-50 ADAM-4053 Wet Contact Input Wiring Diagram




Figure 3-51 ADAM-4053 Contact Closure Input Wiring Diagram

# I/O Modules

## 3.15 ADAM-4055 16-channel Isolated Digital I/O Module

The ADAM-4055 offers 8 channel isolated digital input and 8 channel isolated digital output for critical applications. The inputs accept 10~50 V voltage, and the outputs can supply 5~40 V<sub>DC</sub> at the open collector. The ADAM-4055 is user friendly with built LED indicator for status reading.

Notice: we had updated the digital input dry/wet contact option by using jumper selection. The default setting is to support these two DI contacts both at the same time. However, a customer can also choose his or her needs by supporting only one. Please refer to the following wiring illustration figure 3-54b for more details




Figure 3-52 ADAM-4055 16-channel Digital I/O Module

Application Wiring:




Figure 3-53 ADAM-4055 Digital Output Wiring Diagram






Figure 3-54a ADAM-4055 Digital Input Dry Contact Wiring Diagram



# I/O Modules



**Figure 3-54b ADAM-4055 Digital Input Dry Contact Diagram (Internal)**



**Figure 3-55a ADAM-4055 Digital Input Wet Contact Wiring Diagram**




Figure 3-55b ADAM-4055 Digital Input Wet Contact Diagram (Internal)





Figure 3-56a ADAM-4055 Default Jumper Setting for the Digital Input Wiring  
(Support dry and wet contact digital input at the same time)

## I/O Modules

---



- Notice:
1. J1 setting is for digital input Dry contact
  2. J2 setting is for digital input Wet contact
  3. J1 & J2 of the default setting are closed individually to support dry and wet contact at the same time

**Figure 3-56b ADAM-4055 Default Jumper Setting for the Digital Input Wiring**

## 3.16 ADAM-4056S 12-channel Sink Type Isolated Digital Output Module

ADAM-4056S is a 12-channel sink type isolated digital output module. The isolated channels are designed for digital output for critical applications. Open collector outputs can provide from +5 to +40 V<sub>DC</sub>, and both ADAM ASCII and Modbus/RTU protocols are supported. LED indicators are used for status reading.




Figure 3-57 ADAM-4056S 12-channel Sink Type Isolated Digital Output Module

### Technical Specification of ADAM-4056S

- ◆ Number of Output Channel: 12
- ◆ Digital Output:
  - Open Collector from +5 ~ +40V, 200mA max. load (Sink)
- ◆ LED Indicator: **On**: Active, **Off**: Non-active
- ◆ Power Consumption: 1 W @ 24V<sub>DC</sub>
- ◆ Optical isolation: 5000 V<sub>DC</sub>
- ◆ Supports Modbus/RTU protocol
- ◆ I/O Connector Type: 10 pin plug-in terminal\*2
- ◆ Support Safety Value:
  - Force the DO channels to safety status when communication is in time-out and over pre-defined period.

# I/O Modules

## Application Wiring




Figure 3-58 ADAM-4056S Digital Output Wiring Diagram

## 3.17 ADAM-4056SO 12-channel Source Type Isolated Digital Output Module

ADAM-4056SO is a 12-channel source type isolated digital output module. The 12 isolated digital output channels are designed for critical applications. The digital output signals are sent in the range of 10 ~ 35 V<sub>DC</sub> with maximum 1A per channel, and both ADAM ASCII and Modbus/RTU protocols are supported. The LED indicators provide status reading of the module.





Figure 3-59 ADAM-4056SO 12-channel Source Type Isolated Digital Output Module

### Technical Specification of ADAM-4056SO

- ◆ Number of Output Channel: 12
- ◆ Digital Output: VCC: +10 ~ 35V<sub>DC</sub>, 1A per Channel ( Source)
- ◆ LED Indicator: **On**: Active, **Off**: Non-active
- ◆ Power Consumption: 1 W @ 24V<sub>DC</sub>
- ◆ Optical isolation: 5000 V<sub>DC</sub>
- ◆ Supports Modbus/RTU protocol
- ◆ I/O Connector Type: 10 pin plug-in terminal\*2
- ◆ Leakage current : 50 μ A
- ◆ Support Safety Value:  
Force the DO channels to safety status when communication is in time-out and over pre-defined period.

## Application Wiring



**Figure 3-60 ADAM-4056SO Digital Output Wiring Diagram**

## 3.18 ADAM-4060/4068 Relay Output Module

The ADAM Relay Output Module is a low-cost alternative to SSR modules. The ADAM-4060 Relay Output Module provides four relay channels; two of them are Form A, and two are Form C. The ADAM-4068 Relay Output Module provides eight channels. Four of the channels are Form A, and four are Form C. These two modules are excellent for ON/OFF control or low-power switching applications and they are able to support the safety value setting.

### ADAM-4060 4-channel Relay Output Module




Figure 3-61 ADAM-4060 4-channel Relay Output Module

Contact rating for Form A and Form C: (Resistive)

|           |               |
|-----------|---------------|
| <b>AC</b> | 0.6 A @ 125 V |
|           | 0.3 A @ 250 V |
| <b>DC</b> | 2 A @ 30 V    |
|           | 0.6 A @ 110 V |



## ADAM-4068 8-channel Relay Output Module




Figure 3-62 ADAM-4068 8-channel Relay Output Module

Contact Rating for Form A and Form C: (Resistive)

AC 125 V @ 0.6 A

250 V @ 0.3 A


DC 30 V @ 2 A

110 V @ 0.6 A


**NOTICE:** This electric current is under the load of resistance. If you try to use the load of inductance, the electric current would be less the above-mentioned value.

## Application Wiring


The following diagrams are examples of how to connect Form A and Form C relay output applications to your ADAM modules.




**Figure 3-63 ADAM-4060 Form A Relay Output Wiring Diagram**



**Figure 3-64 ADAM-4060 Form C Relay Output Wiring Diagram**



**Figure 3-65 ADAM-4068 Form C Relay Output Wiring Diagram**



**Figure 3-66 ADAM-4068 Form A relay output Wiring Diagram**

### 3.19 ADAM-4069 8-channel Relay Output Module

The ADAM-4069 Relay Output Module provides eight channels; four are Form A and the rest are Form C. This module is excellent for ON/OFF control or low-power switching applications.




Figure 3-67 ADAM-4069 Relay Output Module

## I/O Modules

---

### Specification:

- **Number of Relay Output Channel:** 8
- **Digital Output: (Source)**
  - 4 Form A , 4 Form C
  - AC 5A@240V
  - DC 5A@30V
  - ON/OFF : 5ms/ 5.6ms
- **Power Consumption:** 2.2 W
- **Supports Modbus/RTU protocol**
- **I/O Connector Type:** 13-pin plug-terminal \* 2
- **Support Safety Value:** Force the DO channels to safety status when communication is in time-out and over pre-defined period.

### Wiring:




Figure 3-68 ADAM-4069 Form C Relay Output




Figure 3-69 *ADAM-4069 Form A Relay Output*

## I/O Modules

---

### 3.20 ADAM-4080/4080D Counter/Frequency Input Modules

ADAM-4080/4080D Counter/frequency input module has two 32-bit counter input channels (counter 0 and counter 1) with built-in programmable timer for frequency measurement. These cost-effective modules let you monitor counter/frequency data as measurements are taken.

#### **Front Panel LED Indicator (ADAM-4080D only)**

The 5-digit LED display of the ADAM-4080D lets you monitor its counter data right at the source. The module's LED display shows counter values as well as high-low alarm messages when the counter exceeds its programmed limits (direct display).

Another option is to display the data sent by the host computer. The module first sends counter data to the host computer for conversion or calculation. The host computer then sends the data back to the ADAM-4080D and displays on the module's LED display (remote display).

#### **Signal Input Mode**

The ADAM-4080/4080D provides separate terminals for photo isolated input and non-isolated input to simplify the wiring. Opto-isolated input provides 2500 V<sub>RMS</sub> isolation to protect your equipment from power surges at the ground terminal. After you make the physical connections, program the module to identify which of its two input terminals should be activated (isolated or non-isolated terminals).

#### **Programmable Digital Filter**

The ADAM-4080/4080D module includes a unique programmable digital filter to reject noise from the input lines. You can specify separate time constant like minimum signal width at high level and minimum signal width at low level. This provides stable output readings.

#### **Programmable Threshold**

When the ADAM-4080/4080D is programmed for non-isolated input, you can set a high and low trigger level. Like the programmable digital filter, the programmable threshold rejects noise from the input lines and provides a stable input readings

### **External Control (Gate mode)**

Aside from the GND and counter terminal, each channel has a gate terminal to connect to an external gate signal. The gate signal (high or low) can trigger the counter from start or stop counting. The gate mode can be among these three options, low, high or disabled (low means that counting starts when the gate signal is low. It stops once the gate signal becomes high)

### **Programmable Alarm Output**

The ADAM-4080 module provides a configurable alarm for each counter. The ADAM-4080D provides high and low alarm functions for counter 0. When the counter reaches an alarm limit, it will trigger the built-in digital output of machine ON/OFF control. The alarm limits may be downloaded into the module's EEPROM by the host computer. The initial count value of ADAM-4080 module's counter can be configured in any values.

The alarm functions can be enabled or disabled remotely. When the alarm functions are enabled, digital output channels are used to indicate the alarm states. For ADAM-4080, digital output channel 0 equals to the alarm state of counter 0, and digital output channel 1 equals to the alarm state of counter 1. For ADAM-4080D, digital output channel 0 equals to the low alarm state of counter 0, and digital output channel 1 equals to the high alarm state of counter 0.

Every A/D conversion will be followed by a comparison of alarm limits. If the input value exceeds one of these limits, the corresponding alarm state is set to ON.

There are two alarm mode options, momentary and latching, for ADAM-4080D. If the alarm is in latching mode, the alarm will stay on even when the input value returns within the limits. An alarm in latching mode can be turned off by issuing a Clear Alarm command from the host computer. A latching alarm is cleared by the module when the opposite alarm is set. For example, the alarm is in latching mode and the high alarm is then turned ON. When the module receives a value that is lower than the low alarm limit, it will clear the high alarm and turn the low alarm ON.

When the alarm is in Momentary mode, the alarm will be turned OFF as soon as the input value returns within the limits.

The arrangement of coupling high and low alarm states with digital output lines may be utilized to build ON/OFF controllers that can operate without the host computer involvement.



## ADAM-4080 Counter/Frequency Input Modules




Figure 3-70 ADAM-4080 Counter/Frequency Input Module

Channels: 2 independent 32-bit counters (counter 0 and counter 1)

Input frequency: 50 kHz max.

Input mode: Isolated or non-isolated


**Isolation input level:**

- Logic level 0: +1 V max
- Logic level 1: +3.5 V to +30 V
- Input Impedance: 1.2 k $\Omega$

**Non-isolation input level** (programmable threshold):

- Logic level 0: 0 to +5V (default = 0.8 V)
- Logic level 1: 0 to +5V (default = 2.4 V)
- Input Impedance: 50 M $\Omega$

## ADAM-4080D Counter/Frequency Input Modules with LED Display



**Figure 3-71 ADAM-4080D Counter/Frequency Input Module with LED Display**

Channels: 2 independent 32-bit counters (counter 0 and counter 1)

Input frequency: 50 kHz max.

Input mode: Isolated or non-isolated


**Isolation input level:**

- Logic level 0: +1 V max
- Logic level 1: +3.5 V to +30 V
- Input Impedance: 1.2 k $\Omega$


**Non-isolation input level** (programmable threshold):

- Logic level 0: 0 to +5V (default = 0.8 V)
- Logic level 1: 0 to +5V (default = 2.4 V)
- Input Impedance: 50 M $\Omega$

## Application Wiring



**Figure 3-72 ADAM-4080/4080D Non-isolated Input**



**Figure 3-73 ADAM-4080/4080D Photo-isolated Input**

Command Set

4

# Command Set

---

## 4.1 Introduction

In order to avoid communication conflicts among devices trying to send data simultaneously, all the traffics are coordinated by the host computer. This action is initiated by the host computer using a command/response protocol.

When the modules are not transmitting, they are in listening mode. The host issues a command to a module with a specified address and waits for the module's response. If there is no response, a timeout aborts the sequence and returns the control to the host.

Changing ADAM's configuration might require the module to perform auto calibration before changes may take effect. This is the case when the range is modified especially. The module has to perform all stages of auto calibration which is also performed during the start up. When the calibration process is underway, the module does not respond to any other commands. The command set in the following pages includes the exact delays that might occur as modules are reconfigured.

## 4.2 Syntax

[delimiter character][address][command][data][checksum] [carriage return]

Every command begins with a delimiter character. There are four valid characters: a dollar sign \$, a pound sign #, a percentage sign % and an at sign @.

The delimiter character is followed by a two-character address (hexadecimal) that specifies the target module. The actual two-character command follows by the address. Depending on the command, an optional data segment may follows by a command string. Furthermore, an optional two-character checksum may be appended to the total string. Every command is terminated by a carriage return (cr).

**ALL COMMANDS SHOULD BE ISSUED IN UPPERCASE CHARACTERS!**

Before the command set is given, we provide an I/O module commands search table to help you find the commands that you wish to use. The command set is divided into the following three categories:

- Analog Input Module commands
- Analog Output Module commands
- Digital I/O, Relay Output and Counter/Frequency Module commands

Each Category starts with a command summary of a particular type of module. However, they are explained in more depth at Chapter 5, 6 & 7 with detailed datasheets of each individual commands.

Although commands in different subsections sometimes share the same format, the effect they have on a certain module can be completely different from others. For example, the configuration command %AANNNTCCFF affects analog input modules and analog output modules differently. The full command set for every module is listed below.

# Command Set

---

## 4.3 I/O Module Commands Search Table

ADAM-4011 Command Table

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANNTTCCFF    | Configuration          | Sets the address, input range, baud rate, data format, checksum status, and/or integration time for a specified analog input module | 5-4      |
| \$AA2          | Configuration Status   | Returns the configuration parameters for the specified analog input module  | 5-10     |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name       | Return the module name from the specified analog input module   | 5-13     |
| #AA            | Analog Data In         | Returns the input value from a specified analog input module in the currently configured data format                                | 5-14     |
| \$AA0          | Span Calibration       | Calibrates an analog input module to correct for gain errors  | 5-19     |
| \$AA1          | Offset Calibration     | Calibrates an analog input module to correct for offset errors  | 5-20     |
| #**            | Synchronized Sampling  | Orders all analog input modules to sample their input values and store them in special registers                                    | 5-21     |
| \$AA4          | Read Synchronized Data | Returns the value that was stored in the specified module's register after the #** command  | 5-22     |
| \$AA3          | CJC Status             | Returns the value of the CJC sensor for a specified analog input module   | 5-25     |
| \$AA9SNNNN     | CJC Offset Calibration | Calibrates the CJC sensor for offset errors   | 5-26     |

(Continued on following page)

**ADAM-4011 Command Table (Continued)**

| Command Syntax | Command Name                      | Command Description  | Page No. |
|----------------|-----------------------------------|--|----------|
| @AA DI         | Read Digital I/O and Alarm Status | The addressed module returns the state of its digital input channel, its two digital output channels and the status of its alarm | 5-50     |
| @AA DO(data)   | Set Digital Output                | Set the values of the module's two digital outputs (ON or OFF)   | 5-52     |
| @AA EAT        | Enable Alarm                      | Enables the alarm in either Momentary or Latching mode   | 5-54     |
| @AA HI(data)   | Set High Alarm                    | Downloads the High alarm limit value   | 5-56     |
| @AA LO(data)   | Set Low Alarm                     | Downloads the Low alarm limit value  | 5-57     |
| @AA DA         | Disable Alarm                     | Disables all alarm functions   | 5-58     |
| @AA CA         | Clear Latch Alarm                 | The latch alarm is reset   | 5-59     |
| @AA RH         | Read High Alarm                   | The addressed analog input module is asked to return its high alarm value  | 5-60     |
| @AA RL         | Read Low Alarm                    | The addressed analog input module is asked to return its low alarm value   | 5-61     |
| @AA RE         | Read Event Counter                | The addressed module is asked to return its event counter value  | 5-62     |
| @AA CE         | Clear Event Counter               | The event counter is set to 0  | 5-63     |



# Command Set

---

ADAM-4011D Command Table

| Command Syntax | Command Name                | Command Description   | Page No. |
|----------------|-----------------------------|---|----------|
| %AANNTTCFF     | Configuration               | Sets the address, input range, baud rate, data format, checksum status, and/or integration time for a specified analog input module | 5-4      |
| \$AA2          | Configuration Status        | Returns the configuration parameters for the specified analog input module  | 5-10     |
| \$AAF          | Read Firmware Version       | Return the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name            | Return the module name from the specified analog input module   | 5-13     |
| #AA            | Analog Data In              | Returns the input value from a specified analog input module in the currently configured data format                                | 5-14     |
| \$AA0          | Span Calibration            | Calibrates an analog input module to correct for gain errors  | 5-19     |
| \$AA1          | Offset Calibration          | Calibrates an analog input module to correct for offset errors  | 5-20     |
| ##             | Synchronized Sampling       | Orders all analog input modules to sample their input values and store them in special registers                                    | 5-21     |
| \$AA4          | Read Synchronized Data      | Returns the value that was stored in the specified module's register after the ## command   | 5-22     |
| \$AAB          | Open Thermocouple Detection | Ask the module to respond whether the thermocouple is open or not   | 5-24     |
| \$AA3          | CJC Status                  | Returns the value of the CJC sensor for a specified analog input module   | 5-25     |
| \$AA9SNNNN     | CJC Offset Calibration      | Calibrates the CJC sensor for offset errors   | 5-26     |

(Continued on following page)

**ADAM-4011D Command Table (Continued)**

| Command Syntax | Command Name                      | Command Description  | Page No. |
|----------------|-----------------------------------|--|----------|
| @AADI          | Read Digital I/O and Alarm Status | The addressed module returns the state of its digital input channel, its two digital output channels and the status of its alarm | 5-50     |
| @AADO(data)    | Set Digital Output                | Set the values of the module's two digital outputs (ON or OFF)   | 5-52     |
| @AAEAT         | Enable Alarm                      | Enables the alarm in either Momentary or Latching mode   | 5-54     |
| @AAHI(data)    | Set High Alarm                    | Downloads the High alarm limit value   | 5-56     |
| @AALO(data)    | Set Low Alarm                     | Downloads the Low alarm limit value  | 5-57     |
| @AADA          | Disable Alarm                     | Disables all alarm functions   | 5-58     |
| @AACA          | Clear Latch Alarm                 | The latch alarm is reset   | 5-59     |
| @AARH          | Read High Alarm                   | The addressed analog input module is asked to return its high alarm value  | 5-60     |
| @AARL          | Read Low Alarm                    | The addressed analog input module is asked to return its low alarm value   | 5-61     |
| @AARE          | Read Event Counter                | The addressed module is asked to return its event counter value  | 5-62     |
| @AACE          | Clear Event Counter               | The event counter is set to 0  | 5-63     |

## Command Set

---

### ADAM-4012 Command Table

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANNITCCFF    | Configuration          | Sets the address, input range, baud rate, data format, checksum status, and/or integration time for a specified analog input module | 5-4      |
| #AA            | Analog Data In         | Returns the input value from a specified analog input module in the currently configured data format                                | 5-14     |
| \$AA0          | Span Calibration       | Calibrates an analog input module to correct for gain errors  | 5-19     |
| \$AA1          | Offset Calibration     | Calibrates an analog input module to correct for offset errors  | 5-20     |
| ##             | Synchronized Sampling  | Orders all analog input modules to sample their input values and store them in special registers                                    | 5-21     |
| \$AA4          | Read Synchronized Data | Returns the value that was stored in the specified module's register after the ## command   | 5-22     |
| \$AA2          | Configuration Status   | Returns the configuration parameters for the specified analog input module  | 5-10     |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name       | Return the module name from the specified analog input module   | 5-13     |

(Continued on following page)

**ADAM-4012 Command Table (Continued)**

| Command Syntax | Command Name                      | Command Description  | Page No. |
|----------------|-----------------------------------|--|----------|
| @AADI          | Read Digital I/O and Alarm Status | The addressed module returns the state of its digital input channel, its two digital output channels and the status of its alarm | 5-50     |
| @AAD0(data)    | Set Digital Output                | Set the values of the module's two digital outputs (ON or OFF)   | 5-52     |
| @AAEAT         | Enable Alarm                      | Enables the alarm in either Momentary or Latching mode   | 5-54     |
| @AAHI(data)    | Set High Alarm                    | Downloads the High alarm limit value   | 5-56     |
| @AALO(data)    | Set Low Alarm                     | Downloads the Low alarm limit value  | 5-57     |
| @AADA          | Disable Alarm                     | Disables all alarm functions   | 5-58     |
| @AACA          | Clear Latch Alarm                 | The latch alarm is reset   | 5-59     |
| @AARH          | Read High Alarm                   | The addressed analog input module is asked to return its high alarm value  | 5-60     |
| @AARL          | Read Low Alarm                    | The addressed analog input module is asked to return its low alarm value   | 5-61     |
| @AARE          | Read Event Counter                | The addressed module is asked to return its event counter value  | 5-62     |
| @AACE          | Clear Event Counter               | The event counter is set to 0  | 5-63     |

## Command Set

---

### ADAM-4013 Command Table

| Command Syntax | Command Name           | Command Description  | Page No. |
|----------------|------------------------|--|----------|
| %AANNTCCFF     | Configuration          | Sets the address, baud rate, data format, checksum status, and/or integration time for a specified analog input module | 5-4      |
| #AA            | Analog Data In         | Returns the input value from a specified analog input module in the currently configured data format                   | 5-14     |
| \$AA0          | Span Calibration       | Calibrates an analog input module to correct for gain errors   | 5-19     |
| \$AA1          | Offset Calibration     | Calibrates an analog input module to correct for offset errors   | 5-20     |
| ##             | Synchronized Sampling  | Orders all analog input modules to sample their input values and store them in special registers                       | 5-21     |
| \$AA4          | Read Synchronized Data | Returns the value that was stored in the specified module's register after the ## command                              | 5-22     |
| \$AA2          | Configuration Status   | Returns the configuration parameters for the specified analog input module   | 5-10     |
| \$AAF          | Read Firmware Version  | Returns the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name       | Returns the module name from the specified analog input module   | 5-13     |

## ADAM-4015/ADAM-4015T Command Table

| Command Syntax | Command Name                             | Command Description  | Page No. |
|----------------|--|--|----------|
| %AANNTTCFF     | Configuration                            | Sets the address, baud rate, data format, checksum status, and/or integration time for a specified analog input module                 | 5-4      |
| \$AA2          | Configuration Status                     | Returns the configuration parameters for the specified analog input module   | 5-10     |
| \$AAF          | Read Firmware Version                    | Return the firmware version code from the specified analog input module  | 5-12     |
| \$AAM          | Read Module Name                         | Return the module name from the specified analog input module  | 5-13     |
| #AA            | Analog Data In                           | Returns the input value from a specified analog input module in the currently configured data format                                   | 5-14     |
| #AAN           | Read Analog Input from Channel N         | Returns the input value from a specified channel of analog input module in the currently configured data format                        | 5-16     |
| \$AA5VV        | Enable/Disable Channels for Multiplexing | Enable or disable the individual channels in an analog module  | 5-17     |
| \$AA6          | Read Channel Status                      | Get the enable/disable status of all channels in an analog module  | 5-18     |
| ##             | Synchronized Sampling                    | Orders all analog input modules to sample their input values and store them in special registers                                       | 5-21     |
| \$AA4          | Read Synchronized Data                   | Returns the value that was stored in the specified module's register after the ## command  | 5-22     |
| \$AAB          | Channel Diagnose                         | Diagnose channel status in over range, under range, and wire opening   | 5-24     |
| \$AA0Ci        | Single Channel Span Calibration          | Calibrates a specified channel to correct for gain errors  | 5-27     |
| \$AA1Ci        | Single Channel Offset Calibration        | Calibrates a specified channel to correct for offset errors  | 5-28     |
| \$AA7CiRr      | Single Channel Range Configuration       | Configure the input type and range of the specified channel in an analog input module  | 5-29     |
| \$AA8Ci        | Read Single Channel Range Configuration  | Get the input type and range of the specified channel in an analog input module  | 5-30     |
| \$AAxnnnn      | Watchdog Timer Setting                   | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 5-31     |
| \$AAy          | Read Watchdog Timer Setting              | Read the cycle time setting of communication WDT   | 5-32     |
| \$AAS0         | Internal Calibration                     | Internal self-calibration for offset and gain errors   | 5-33     |
| \$AAS1         | Reload default calibrating parameter     | Reload factory default calibrating parameter to overwrite current calibrating parameter  | 5-34     |

# Command Set

---

## ADAM-4016 Command Table

| Command Syntax | Command Name                          | Command Description   | Page No. |
|----------------|---------------------------------------|---|----------|
| %AANNTTCFF     | Configuration                         | Set the address, input range, baud rate, data format, checksum status and/or integration time for the specified analog input module | 5-4      |
| \$AA2          | Configuration Status                  | Return the configuration parameters for the specified analog input module   | 5-10     |
| \$AAF          | Read Firmware Version                 | Return the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name                      | Return the module name from the specified analog input module   | 5-13     |
| #AA            | Read Analog Input                     | Return the input value from the specified analog input module in the currently configured data format                               | 5-14     |
| \$AA0          | Span Calibration                      | Calibrate an analog input module to correct for gain errors   | 5-19     |
| \$AA1          | Offset Calibration                    | Calibrate an analog input module to correct for offset errors   | 5-20     |
| ##             | Synchronized Sampling                 | Orders all analog input modules to sample their input values and store them in special registers                                    | 5-21     |
| \$AA4          | Read Synchronized Data                | Returns the value that was stored in the specified module's register after the ## command   | 5-22     |
| \$AA6          | Get Excitation Voltage Output Value   | Returns either last value sent to specified module by \$AA7 command, or start-up output voltage                                     | 5-65     |
| \$AA7          | Excitation Voltage Output             | Direct output excitation voltage data to a specified module   | 5-66     |
| \$AAS          | Start-up Voltage Output Configuration | Stores a default value in a specified module. The output value will take effect upon at startup.                                    | 5-67     |
| \$AAE          | Trim Calibration                      | Trims specified module a number of units up or down   | 5-69     |
| \$AAA          | Zero Calibration                      | Tells the module to store parameters for zero calibration   | 5-70     |
| \$AAB          | Span Calibration                      | Tells the module to store parameters for span calibration   | 5-71     |

(Continued on following page)

**ADAM-4016 Command Table (Continued)**

| Command Syntax | Command Name                      | Command Description  | Page No. |
|----------------|-----------------------------------|--|----------|
| @AADI          | Read Digital I/O And Alarm Status | Ask the addressed module to return the state of its four digital output channels and the status of its alarm | 5-50     |
| @AADO(data)    | Set Digital Output Values         | Set the values of the module's four digital outputs (ON or OFF)  | 5-52     |
| @AAEAT         | Enable Alarm                      | Enable the alarm in either momentary or latching mode  | 5-54     |
| @AAHI(data)    | Set High Alarm Value              | Download the high alarm limit value  | 5-56     |
| @AALO(data)    | Set Low Alarm Value               | Download the low alarm limit value   | 5-57     |
| @AADA          | Disable Alarm                     | Disable all alarm functions  | 5-58     |
| @AACA          | Clear Latch Alarm                 | Reset the module's latch alarm to zero   | 5-59     |
| @AARH          | Read High Alarm Value             | Ask the addressed module to return its high alarm value  | 5-60     |
| @AARL          | Read Low Alarm Value              | Ask the addressed module to return its low alarm value   | 5-61     |



# Command Set

---

## ADAM-4017 Command Table

| Command Syntax | Command Name                             | Command Description   | Page No. |
|----------------|--|---|----------|
| %AANNTCCFF     | Configuration                            | Set the address, input range, baud rate, data format, checksum status and/or integration time for the specified analog input module | 5-4      |
| \$AA2          | Configuration Status                     | Return the configuration parameters for the specified analog input module   | 5-9      |
| \$AAF          | Read Channel Status                      | Return the firmware version code from the specified analog input module   | 5-11     |
| \$AAM          | Read Version                             | Return the module name from the specified analog input module   | 5-12     |
| #AA            | from Channel N                           | Return the input values from all channels of the specified analog input module  | 5-13     |
| #AAN           | Read Analog Input                        | Return the input value from channels number N of the specified analog input module  | 5-15     |
| \$AA5VV        | Configuration Status                     | Enables/disables multiplexing simultaneously for separate channels of the specified input module                                    | 5-16     |
| \$AA6          | Enable/disable Channels for Multiplexing | Ask the specified input module to return the status of all eight channels   | 5-17     |
| \$AA0          | Span Calibration                         | Calibrate the analog input module to correct for gain errors  | 5-18     |
| \$AA1          | Offset Calibration                       | Calibrate the analog input module to correct for offset errors  | 5-19     |

### ADAM-4017+ Command Table

| Command Syntax | Command Name                             | Command Description  | Page No. |
|----------------|--|--|----------|
| %AANN TTCFF    | Configuration                            | Set the address, input range, baud rate, data format, checksum status and/or integration time for the specified analog input module    | 5-4      |
| \$AA2          | Configuration Status                     | Return the configuration parameters for the specified analog input module  | 5-10     |
| \$AAF          | Read Version                             | Return the firmware version code from the specified analog input module  | 5-12     |
| \$AAM          | Read the Module Name                     | Return the module name from the specified analog input module  | 5-13     |
| #AA            | Read Analog Input from all Channels      | Return the input values from all channels of the specified analog input module   | 5-14     |
| #AAN           | Read Analog Input from Channel N         | Return the input value from channels number N of the specified analog input module   | 5-16     |
| \$AA5VV        | Enable/disable Channels for Multiplexing | Enables/disables multiplexing simultaneously for separate channels of the specified input module                                       | 5-17     |
| \$AA6          | Read Channel Status                      | Ask the specified input module to return the status of all eight channels  | 5-18     |
| \$AA0Ci        | Span Calibration                         | Gain error calibrate of assignment channel, User have to input the external standard source for calibrating process                    | 5-27     |
| \$AA1Ci        | Offset Calibration                       | Offset error calibrate of assignment channel, User have to input the external standard source for calibrating process                  | 5-28     |
| \$AA7CiRrr     | Input Range Setting                      | Input range setting individually   | 5-29     |
| \$AA8Ci        | Read Input Range                         | Get the input range of the assignment channel  | 5-30     |
| \$AAXnnnn      | Watchdog Timer Setting                   | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 5-31     |
| \$AAAY         | Read Watchdog Timer Setting              | Read the cycle time setting of communication WDT   | 5-32     |

## Command Set

---

ADAM-4017+

Input range and external calibrating input source for each input type

| Range bcode(Hex) | Input Range | Max. Signal | Min Signal | Displayed Resolution |
|------------------|-------------|-------------|------------|----------------------|
| 07               | 4~20 mA     | +20.000     | +4.000     | 1uA                  |
| 08               | +/-10 V     | +10.000     | -10.000    | 1mV                  |
| 09               | +/-5 V      | +5.0000     | -5.0000    | 100.00uV             |
| 0A               | +/-1 V      | +1.0000     | -1.0000    | 100.00uV             |
| 0B               | +/-500 mV   | +500.00     | -500.00    | 10uV                 |
| 0C               | +/-150 mV   | +150.00     | -150.00    | 10uV                 |
| 0D               | +/-20 mA    | +20.000     | -20.000    | 1uA                  |

## ADAM-4018 Command Table

| Command Syntax | Command Name                             | Command Description   | Page No. |
|----------------|--|---|----------|
| %AANNITCCFF    | Configuration                            | Set the address, input range, baud rate, data format, checksum status and/or integration time for the specified analog input module | 5-4      |
| \$AA2          | Configuration Status                     | Return the configuration parameters for the specified analog input module   | 5-10     |
| \$AAF          | Read Version                             | Return the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name                         | Return the module name from the specified analog input module   | 5-13     |
| #AA            | Read Analog Input from all Channels      | Return the input value from all channels of the specified analog module   | 5-14     |
| #AAN           | Read Analog Input from Channel N         | Return the input value from channels number N of the specified analog input module  | 5-16     |
| \$AA5VV        | Enable/disable Channels for Multiplexing | Enables/disables multiplexing simultaneously for separate channels of the specified input module                                    | 5-17     |
| \$AA6          | Read Channel Status                      | Ask the specified input module to return the status of all eight channels   | 5-18     |
| \$AA0          | Span Calibration                         | Calibrate the analog input module to correct for gain errors  | 5-19     |
| \$AA1          | Offset Calibration                       | Calibrate the analog input module to correct for offset errors  | 5-20     |
| \$AA3          | CJC Status                               | Returns the value of the CJC sensor for a specified analog input module   | 5-25     |
| \$AA9SNNNN     | CJC Offset Calibration                   | Calibrates the CJC sensor for offset errors   | 5-26     |

# Command Set

---

## ADAM-4018+ Command Table

| Command Syntax | Command Name                             | Command Description  | Page No. |
|----------------|--|--|----------|
| %AANNTTCCFF    | Configuration                            | Set the address, input range, baud rate, data format, checksum status and/or integration time for the specified analog input module                          | 5-4      |
| \$AA2          | Configuration Status                     | Return the configuration parameters for the specified analog input module  | 5-10     |
| \$AAF          | Read Version                             | Return the firmware version code from the specified analog input module  | 5-12     |
| \$AAM          | Read Module Name                         | Return the module name from the specified analog input module  | 5-13     |
| #AA            | Read Analog Input from all Channels      | Return the input value from all channels of the specified analog module  | 5-14     |
| #AAN           | Read Analog Input from Channel N         | Return the input value from channels number N of the specified analog input module   | 5-16     |
| \$AA5VV        | Enable/disable Channels for Multiplexing | Enables/disables multiplexing simultaneously for separate channels of the specified input module   | 5-17     |
| \$AA6          | Read Channel Status                      | Ask the specified input module to return the status of all eight channels  | 5-18     |
| \$AAB          | Get Operating Status                     | Get the channel operating status When bit value is 0, it mean this channel is in normal operating, when bit value is 1, it mean this channel is opening wire | 5-24     |
| \$AA3          | CJC Status                               | Returns the value of the CJC sensor for a specified analog input module  | 5-25     |
| \$AA9SNNNN     | CJC Offset Calibration                   | Calibrates an analog input module to adjust for offset errors of its CJC sensors   | 5-26     |
| \$AA0Ci        | Span Calibration                         | Gain error calibrate of assignment channel, User have to input the external standard source for calibrating process  | 5-27     |

(Continued on following page)

### ADAM-4018+ Command Table (Continued)

| Command Syntax | Command Name                  | Command Description  | Page No. |
|----------------|-------------------------------|--|----------|
| \$AA1Ci        | Offset Calibration            | Offset error calibrate of assignment channel, User have to input the external standard source for calibrating process                  | 5-28     |
| \$AA7CiRrr     | Input Range Setting           | Input range setting individually   | 5-29     |
| \$AA8Ci        | Read Input Range              | Get the input range of the assignment channel  | 5-30     |
| \$AAXnnnn      | Set Communication WDT         | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 5-31     |
| \$AAY          | Get Communication WDT Setting | Read the cycle time setting of communication WDT   | 5-32     |

### ADAM-4018+

Input range and external calibrating input source for each input type

| Range bcode(Hex) | Input Range         | Max. Signal | Min Signal | Displayed Resolution |
|------------------|---------------------|-------------|------------|----------------------|
| 06               | +/-20 mA            | +20.000     | -20.000    | 1uA                  |
| 07               | 4~20 mA             | +20.000     | +4.000     | 1uA                  |
| 14               | Type J Thermocouple |             |            |                      |
| 15               | Type K Thermocouple |             |            |                      |
| 16               | Type T Thermocouple |             |            |                      |
| 17               | Type E Thermocouple |             |            |                      |
| 18               | Type R Thermocouple |             |            |                      |
| 19               | Type S Thermocouple |             |            |                      |
| 20               | Type B Thermocouple |             |            |                      |

# Command Set

---

ADAM-4018M Command Table

| Command Syntax | Command Name                             | Command Description   | Page No. |
|----------------|--|---|----------|
| %AANNTTCCFF    | Configuration                            | Set the address, input range, baud rate, data format, checksum status and/or integration time for the specified analog input module               | 5-4      |
| \$AA2          | Configuration Status                     | Return the configuration parameters for the specified analog input module   | 5-10     |
| \$AAF          | Read Version                             | Return the firmware version code from the specified analog input module   | 5-12     |
| \$AAM          | Read Module Name                         | Return the module name from the specified analog input module   | 5-13     |
| #AAN           | Read Analog Input from Channel N         | Return the input value from channels number N of the specified analog input module  | 5-16     |
| \$AA5VV        | Enable/disable Channels for Multiplexing | Enables/disables multiplexing simultaneously for separate channels of the specified input module  | 5-17     |
| \$AA6          | Read Channel Status                      | Ask the specified input module to return the status of all eight channels   | 5-18     |
| \$AA0          | Span Calibration                         | Calibrate the analog input module to correct for gain errors  | 5-19     |
| \$AA1          | Offset Calibration                       | Calibrate the analog input module to correct for offset errors  | 5-20     |
| \$AA3          | CJC Status                               | Returns the value of the CJC sensor for a specified analog input module   | 5-25     |
| \$AA9SNNNN     | CJC Offset Calibration                   | Calibrates the CJC sensor for offset errors   | 5-26     |
| @AACCCSDMTTTT  | Set Memory Configuration                 | Set the channel storage status, standalone mode, data logger mode, storage type and sampling interval for the specified analog input data logger. | 5-37     |
| @AAD           | Read Memory Configuration                | Return the configuration parameters for the specified analog input data logger.   | 5-39     |
| @AASO          | Set Memory Operation Mode                | Start/stop the recording function of the memory module.   | 5-40     |

---

(Continued on following page)

**ADAM-4018M Command Table (Continued)**

|                 |                            |  |      |
|-----------------|----------------------------|--|------|
| @AAT            | Read Memory Operation Mode | Read the recording status of the memory module.                  | 5-41 |
| @AAL            | Event Record Count         | Read the number of stored event records in the memory module.    | 5-42 |
| @AAN            | Standard Record Count      | Read the number of stored standard records in the memory module. | 5-43 |
| @AARNNNN        | Read Record Content        | Read the contents of the specified record.                       | 5-44 |
| @AAACSDHHHTEIII | Set Alarm Limit            | Set the high/low alarm settings for the specified channel.       | 5-46 |
| @AABC           | Read Alarm Limit           | Read the high/low alarm settings for the specified channel.      | 5-48 |



## Command Set

---

### ADAM-4019+ Command Table

| Command Syntax | Command Name                             | Command Description  | Page No. |
|----------------|--|--|----------|
| %AANNTCCFF     | Configuration                            | Sets the address, baud rate, data format, checksum status, and/or integration time for a specified analog input module                                       | 5-4      |
| \$AA2          | Configuration Status                     | Returns the configuration parameters for the specified analog input module   | 5-10     |
| \$AAF          | Read Firmware Version                    | Return the firmware version code from the specified analog output module   | 5-12     |
| \$AAM          | Read Module Name                         | Return the module name from the specified analog output module   | 5-13     |
| #AA            | Analog Data In                           | Returns the input value from a specified analog input module in the currently configured data format   | 5-14     |
| #AAN           | Read Analog Input from Channel N         | Returns the input value from a specified channel of analog input module in the currently configured data format  | 5-16     |
| \$AA5VV        | Enable/Disable Channels for Multiplexing | Enable or disable the individual channels in an analog module  | 5-17     |
| \$AA6          | Read Channel Status                      | Get the enable/disable status of all channels in an analog module  | 5-18     |
| \$AAB          | Get Operating Status                     | Get the channel operating status When bit value is 0, it mean this channel is in normal operating, when bit value is 1, it mean this channel is opening wire | 5-24     |
| \$AA3          | CJC Status                               | Returns the value of the CJC sensor for a specified analog input module  | 5-25     |
| \$AA9SNNNN     | CJC Offset Calibration                   | Calibrates an analog input module to adjust for offset errors of its CJC sensors   | 5-26     |

(Continued on following page)

**ADAM-4019+ Command Table (Continued)**

| Command Syntax | Command Name                      | Command Description  | Page No. |
|----------------|-----------------------------------|--|----------|
| \$AA0Ci        | Single Channel Span Calibration   | Gain error calibrate of assignment channel, User have to input the external standard source for calibrating process                    | 5-27     |
| \$AA1Ci        | Single Channel Offset Calibration | Offset error calibrate of assignment channel, User have to input the external standard source for calibrating process                  | 5-28     |
| \$AA7CiRrr     | Input Range Setting               | Input range setting individually   | 5-29     |
| \$AA8Ci        | Read Input Range                  | Get the input range of the assignment channel  | 5-30     |
| \$AAXnnnn      | Set Communication WDT             | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 5-31     |
| \$AAY          | Get Communication WDT setting     | Read the cycle time setting of communication WDT   | 5-32     |

# Command Set

---

ADAM-4021 Command Table

| Command Syntax          | Command Name                                  | Command Description   | Page No. |
|-------------------------|---|---|----------|
| %AANNTCCFF              | Configuration                                 | Set the address, output range, baud rate, data format, slew rate and/or checksum status               | 6-3      |
| #AA(data)               | Analog Data Out                               | Directs output data to a specified module   | 6-6      |
| \$AA4                   | Start-up output current/voltage configuration | Stores a default output value in a specified module. The output value will take effect upon startup.  | 6-8      |
| \$AA3(number of counts) | Trim Calibration                              | Trims specified module a number of units up/down  | 6-9      |
| \$AA0                   | 4 mA Calibration                              | Tells the module to store parameters for 4 mA Calibration   | 6-11     |
| \$AA1                   | 20 mA Calibration                             | Tells the module to store parameters for 20 mA Calibration  | 6-12     |
| \$AA2                   | Configuration Status                          | Reads configuration of specified module   | 6-13     |
| \$AA6                   | Last Value Readback                           | Returns either last value sent to specified module by #AA command, or start-up output current/voltage | 6-14     |
| \$AA8                   | Current Readback                              | Returns measured value of the current/voltage flowing through current loop                            | 6-15     |
| \$AA5                   | Reset Status                                  | Checks if module has been reset since the last \$AA5 command  | 6-16     |
| \$AAF                   | Read Firmware Version                         | Return the firmware version code from the specified analog output module                              | 6-17     |
| \$AAM                   | Read Module Name                              | Return the module name from the specified analog output module  | 6-18     |

## ADAM-4024 Command Table

| Command Syntax            | Command Name                                  | Command Description   | Page No. |
|---------------------------|---|---|----------|
| %AANNTCCFF                | Configuration                                 | Set the address, output range, baud rate, data format, slew rate and/or checksum status               | 6-19     |
| #AACn(data)               | Analog Data Out                               | Directs output data to a specified module   | 6-20     |
| #AASCn(data)              | Set Startup Data                              | Set data As CHn StartUp Data  | 6-20     |
| #AAECn(data)              | Set Emergency Stop                            | Set data As CHn Emergency Stop Data   | 6-20     |
| ##                        | N/A   | Synchronous Sample ID1  | 6-20     |
| \$AA0Cn                   | 4 mA Calibration                              | Tells the module to store parameters for 4 mA Calibration   | 6-20     |
| \$AA1Cn                   | 20 mA Calibration                             | Tells the module to store parameters for 20 mA Calibration  | 6-20     |
| \$AA2                     | Configuration Status                          | Read back Module status   | 6-20     |
| \$AA3Cn(number of counts) | Trim Calibration                              | Trims specified module a number of units up/down  | 6-20     |
| \$AA4                     | Start-up output current/voltage configuration | Stores a default output value in a specified module. The output value will take effect upon startup.  | 6-20     |
| \$AA5                     | Reset Status                                  | Read Back Reset Times After Last \$AA5 CMD And Clear This ounter                                      | 6-20     |
| \$AA6Cn                   | Last Value Readback                           | Returns either last value sent to specified module by #AA command, or start-up output current/voltage | 6-20     |
| \$AA7CnRxx                | Set Output Type                               | Set CHn Output Type   | 6-20     |
| \$AA8Cn                   | Current Readback                              | Returns measured value of the current/voltage flowing through current loop                            | 6-21     |
| \$AAF                     | Read Firmware Version                         | Return the firmware version code from the specified analog output module                              | 6-21     |
| \$AAM                     | Read Module Name                              | Return the module name from the specified analog output module  | 6-21     |

(Continued on following page)

## Command Set

---

### ADAM-4024 Command Table (Continued)

| Command Syntax | Command Name                     | Command Description  | Page No. |
|----------------|----------------------------------|--|----------|
| \$AAACnZ       | EMS Flag setting                 | Enable/Disable (Z=1/0)<br>CHn EMS Flag   | 6-21     |
| \$AABCn        | Read EMS Flag                    | Read CHn EMS Flag  | 6-21     |
| \$AADCn        | Read startup data                | Read Back CHn StartUp Data   | 6-21     |
| \$AAECn        | Read emergency Stop              | Read Back CHn Emergency Stop Data  | 6-21     |
| \$AAG          | Reset Current Trim               | Reset Current Trim Data Variable To 0  | 6-21     |
| \$AAH          | Read Current Trim                | Read Current Trim Data Variable  | 6-21     |
| \$AAI          | Read IDI                         | Read IDI   | 6-21     |
| \$AANCn        | Read 4mA Calibration Parameter   | Read Back CHn 4mA Calibration Parameter  | 6-21     |
| \$AAOCn        | Read 20mA Calibration Parameter  | Read Back CHn 20mA Calibration Parameter   | 6-21     |
| \$AAPCn        | Clear 4mA Calibration Parameter  | Clear CHn 4mA Calibration Parameter/EEPROM   | 6-21     |
| \$AAQCn        | Clear 20mA Calibration Parameter | Clear CHn 20mA Calibration Parameter/EEPROM  | 6-21     |
| \$AAXnnnn      | Watchdog Timer Setting           | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 6-21     |
| \$AAAY         | Read Watchdog Timer Setting      | Read the cycle time setting of communication WDT   | 6-21     |

**ADAM-4050 Command Table**

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANNTTCFF     | Configuration          | Sets address, baud rate, and/or checksum status, to a digital I/O module                                    | 7-4      |
| \$AA6          | Digital Data In        | Returns the values of the digital I/O channels of the addressed module                                      | 7-6      |
| #AAB(data)     | Digital Data Out       | Writes specified values to either a single channel or all channels simultaneously                           | 7-8      |
| ##             | Synchronized Sampling  | Orders all digital I/O modules to sample their input values and store them in a special register            | 7-11     |
| \$AA4          | Read Synchronized Data | Return the value of a specified digital I/O module that was stored after an ## command was issued           | 7-12     |
| \$AA2          | Configuration Status   | Returns the configuration parameters of a specified digital I/O module                                      | 7-14     |
| \$AA5          | Reset Status           | Indicates whether a specified digital I/O module was reset after the last time the \$AA5 command was issued | 7-16     |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified digital I/O module                                      | 7-18     |
| \$AAM          | Read Module Name       | Return the module name from the specified Digital I/O module  | 7-19     |

## Command Set

---

ADAM-4051 Command Table

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANNTTCCFF    | Configuration          | Sets the address, baud rate, and/or checksum status to a digital I/O module   | 7-4      |
| #**            | Synchronized Sampling  | Orders all digital I/O modules to sample their input values and store them in special registers                               | 7-11     |
| \$AA2          | Configuration Status   | Returns the configuration parameters of a specified digital I/O module  | 7-14     |
| \$AA4          | Read Synchronized Data | Returns the value of a specified digital I/O module that was stored in the specified register after an #** command was issued | 7-12     |
| \$AA5          | Reset Status           | Indicates whether a specified digital I/O module was reset after the last time that \$AA5 command was issued                  | 7-16     |
| \$AA6          | Digital Data In        | Returns the values of the digital I/O channel in the addressed module   | 7-6      |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified digital I/O module  | 7-18     |
| \$AAM          | Read Module Name       | Return the module name from the specified digital I/O module  | 7-19     |

## ADAM-4052 Command Table

| Command Syntax | Command Name                | Command Description  | Page No. |
|----------------|-----------------------------|--|----------|
| %AANNTTCFF     | Configuration               | Sets address, baud rate, and/or checksum status, to a digital I/O module   | 7-4      |
| \$AA6          | Digital Data In             | Returns the values of the digital I/O channels of the addressed module   | 7-6      |
| #**            | Synchronized Sampling       | Orders all digital I/O modules to sample their input values and store them in a special register                                       | 7-11     |
| \$AA4          | Read Synchronized Data      | Return the value of a specified digital I/O module that was stored after an #** command was issued                                     | 7-12     |
| \$AA2          | Configuration Status        | Returns the configuration parameters of a specified digital I/O module   | 7-14     |
| \$AA5          | Reset Status                | Indicates whether a specified digital I/O module was reset after the last time the \$AA5 command was issued                            | 7-16     |
| \$AAF          | Read Firmware Version       | Return the firmware version code from the specified digital I/O module   | 7-18     |
| \$AAM          | Read Module Name            | Return the module name from the specified digital I/O module   | 7-19     |
| \$AAXnnnn      | Watchdog Timer Setting      | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 7-27     |
| \$AAY          | Read Watchdog Timer Setting | Read the cycle time setting of communication WDT   | 7-28     |



# Command Set

---

## ADAM-4053 Command Table

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANNTTCCFF    | Configuration          | Sets address, baud rate, and/or checksum status, to a digital I/O module                                    | 7-4      |
| \$AA6          | Digital Data In        | Returns the values of the digital I/O channels of the addressed module                                      | 7-6      |
| ##             | Synchronized Sampling  | Orders all digital I/O modules to sample their input values and store them in a special register            | 7-11     |
| \$AA4          | Read Synchronized Data | Return the value of a specified digital I/O module that was stored after an ## command was issued           | 7-12     |
| \$AA2          | Configuration Status   | Returns the configuration parameters of a specified digital I/O module                                      | 7-14     |
| \$AA5          | Reset Status           | Indicates whether a specified digital I/O module was reset after the last time the \$AA5 command was issued | 7-16     |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified digital I/O module                                      | 7-18     |
| \$AAM          | Read Module Name       | Return the module name from the specified digital I/O module  | 7-19     |

## ADAM-4055 Command Table

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANN TTCFF    | Configuration          | Sets the address, baud rate, and/or checksum status to a digital I/O module   | 7-4      |
| #AABB(data)    | Digital Data Out       | Writes specified values to either a single channel or all channels simultaneously   | 7-8      |
| ##             | Synchronized Sampling  | Orders all digital I/O modules to sample their input values and store them in special registers   | 7-11     |
| \$AA2          | Configuration Status   | Returns the configuration parameters of a specified digital I/O module  | 7-14     |
| \$AA4          | Read Synchronized Data | Returns the value of a specified digital I/O module that was stored in the specified register after an ## command was issued                            | 7-12     |
| \$AA5          | Reset Status           | Indicates whether a specified digital I/O module was reset after the last time that \$AA5 command was issued  | 7-16     |
| \$AA6          | Digital Data In        | Returns the values of the digital I/O channel in the addressed module   | 7-6      |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified digital I/O module  | 7-18     |
| \$AAM          | Read Module Name       | Return the module name from the specified digital I/O module  | 7-19     |
| \$AAX0TTTTDD   | Write Safty Value      | Force the DO channels to safety status when communication is time-out and over pre-defined period.  | 7-21     |
| \$AAX1         | Read Safty Value       | Read the time-out setting and pre-defined safety status of DO channels.   | 7-22     |
| \$AAX2         | Read Safty Flag        | Requests the Safty Flag of the addressed digital I/O module to see whether the safety value has been executed since Write Safety Value command was set. | 7-23     |

# Command Set

---

ADAM-4056S Command Table

| Command Syntax | Command Name                | Command Description   | Page No. |
|----------------|-----------------------------|---|----------|
| %AANNTTCCFF    | Configuration               | Sets the address, baud rate, and/or checksum status to a digital I/O module   | 7-4      |
| #AABB(data)    | Digital Data Out            | Writes specified values to either a single channel or all channels simultaneously   | 7-8      |
| \$AA2          | Configuration Status        | Returns the configuration parameters of a specified digital I/O module  | 7-14     |
| \$AA5          | Reset Status                | Indicates whether a specified digital I/O module was reset after the last time that \$AA5 command was issued  | 7-16     |
| \$AA6          | Digital Data In             | Returns the values of the digital I/O channel in the addressed module   | 7-6      |
| \$AAF          | Read Firmware Version       | Return the firmware version code from the specified digital I/O module  | 7-18     |
| \$AAM          | Read Module Name            | Return the module name from the specified digital I/O module  | 7-19     |
| \$AAX0TTTTDDDD | Write Safty Value           | Force the DO channels to safety status when communication is time-out and over pre-defined period.  | 7-21     |
| \$AAX1         | Read Safty Value            | Read the time-out setting and pre-defined safety status of DO channels.   | 7-22     |
| \$AAX2         | Read Safty Flag             | Requests the Safty Flag of the addressed digital I/O module to see whether the safety value has been executed since Write Safety Value command was set. | 7-23     |
| \$AAXnnnn      | Watchdog Timer Setting      | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable)                  | 7-27     |
| \$AAY          | Read Watchdog Timer Setting | Read the cycle time setting of communication WDT  | 7-28     |

## ADAM-4056SO Command Table

| Command Syntax | Command Name                            | Command Description   | Page No. |
|----------------|---|---|----------|
| %AANNTTCFF     | Configuration                           | Sets the address, baud rate, and/or checksum status to a digital I/O module   | 7-4      |
| #AABB(data)    | Digital Data Out                        | Writes specified values to either a single channel or all channels simultaneously   | 7-8      |
| \$AA2          | Configuration Status                    | Returns the configuration parameters of a specified digital I/O module  | 7-14     |
| \$AA5          | Reset Status                            | Indicates whether a specified digital I/O module was reset after the last time that \$AA5 command was issued  | 7-16     |
| \$AA6          | Digital Data In                         | Returns the values of the digital I/O channel in the addressed module   | 7-6      |
| \$AAF          | Read Firmware Version                   | Return the firmware version code from the specified digital I/O module  | 7-18     |
| \$AAM          | Read Module Name                        | Return the module name from the specified digital I/O module  | 7-19     |
| \$AAX0TTTTDDDD | Write Safty Value                       | Force the DO channels to safety status when communication is time-out and over pre-defined period.  | 7-21     |
| \$AAX1         | Read Safty Value                        | Read the time-out setting and pre-defined safety status of DO channels.   | 7-22     |
| \$AAX2         | Read Safty Flag                         | Requests the Safty Flag of the addressed digital I/O module to see whether the safety value has been executed since Write Safety Value command was set. | 7-23     |
| \$AAE0         | Read and Clear Over Current Status Flag | Read the Over Current Status Flag and Clear the Flag simultaneously   | 7-24     |
| \$AAXnnnn      | Watchdog Timer Setting                  | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable)                  | 7-27     |
| \$AAY          | Read Watchdog Timer Setting             | Read the cycle time setting of communication WDT  | 7-28     |

# Command Set

---

ADAM-4060/4068 Command Table

| Command Syntax | Command Name           | Command Description   | Page No. |
|----------------|------------------------|---|----------|
| %AANNTTCCFF    | Configuration          | Sets address, baud rate, and/or checksum status, to a digital I/O module  | 7-4      |
| \$AA6          | Digital Data In        | Returns the values of the digital I/O channels of the addressed module  | 7-6      |
| #AABB(data)    | Digital Data Out       | Writes specified values to either a single channel or all channels simultaneously   | 7-8      |
| #**            | Synchronized Sampling  | Orders all digital I/O modules to sample their input values and store them in a special register  | 7-11     |
| \$AA4          | Read Synchronized Data | Return the value of a specified digital I/O module that was stored after an #** command was issued  | 7-12     |
| \$AA2          | Configuration Status   | Returns the configuration parameters of a specified digital I/O module  | 7-14     |
| \$AA5          | Reset Status           | Indicates whether a specified digital I/O module was reset after the last time the \$AA5 command was issued   | 7-16     |
| \$AAF          | Read Firmware Version  | Return the firmware version code from the specified digital I/O module  | 7-18     |
| \$AAM          | Read Module Name       | Return the module name from the specified digital I/O module  | 7-19     |
| \$AAX0TTTTDDDD | Write Safty Value      | Force the DO channels to safety status when communication is time-out and over pre-defined period.  | 7-21     |
| \$AAX1         | Read Safty Value       | Read the time-out setting and pre-defined safety status of DO channels.   | 7-22     |
| \$AAX2         | Read Safty Flag        | Requests the Safty Flag of the addressed digital I/O module to see whether the safety value has been executed since Write Safety Value command was set. | 7-23     |

ADAM-4069 Command Table

| Command Syntax | Command Name                | Command Description  | Page No. |
|----------------|-----------------------------|--|----------|
| %AANN TTCCFF   | Configuration               | Sets address, baud rate, and/or checksum status, to a digital I/O module   | 7-4      |
| \$AA6          | Digital Data In             | Returns the values of the digital I/O channels of the addressed module   | 7-6      |
| #AABB(data)    | Digital Data Out            | Writes specified values to either a single channel or all channels simultaneously  | 7-8      |
| \$AA2          | Configuration Status        | Returns the configuration parameters of a specified digital I/O module   | 7-14     |
| \$AA5          | Reset Status                | Indicates whether a specified digital I/O module was reset after the last time the \$AA5 command was issued                            | 7-16     |
| \$AAF          | Read Firmware Version       | Return the firmware version code from the specified digital I/O module   | 7-18     |
| \$AAM          | Read Module Name            | Return the module name from the specified digital I/O module   | 7-19     |
| \$AAX0TTTTDDDD | Write Safty Value           | Force the DO channels to safety status when communication is time-out and over pre-defined period.                                     | 7-21     |
| \$AAX1         | Read Safty Value            | Read the time-out setting and pre-defined safety status of DO channels.  | 7-22     |
| \$AAP          | Read low power status       | The command requests the module at address AA to return the low power status of module   | 7-25     |
| \$AAS          | Set low power status        | The command requests the module at address AA to set and return the low power mode of module   | 7-26     |
| \$AAXnnnn      | Watchdog Timer Setting      | Set communication WDT cycle time from 0000 ~ 9999 (unit: 0.1 second. if value is 0000, the communication WDT function will be disable) | 7-27     |
| \$AAY          | Read Watchdog Timer Setting | Read the cycle time setting of communication WDT   | 7-28     |

## Command Set

---

ADAM-4080 Command Table

| Command Syntax | Command Name                    | Command Description   | Page No. |
|----------------|---------------------------------|---|----------|
| %AANNTCCFF     | Configuration                   | Sets the address, input mode, baud rate, checksum status and/or frequency gate time for a specified counter/ frequency module | 7-28     |
| \$AA2          | Configuration Status            | Returns configuration parameters from the specified counter/frequency module  | 7-30     |
| \$AAF          | Read Firmware Version           | Return firmware version code from the specified counter/frequency module  | 7-31     |
| \$AAM          | Read Module Name                | Return the module name from the specified counter/frequency module  | 7-32     |
| \$AABS         | Set Input Signal Mode           | Sets the input signal mode of the specified counter/frequency module to either non-isolated or photo-isolated input signals   | 7-33     |
| \$AAB          | Read Input Signal Mode          | Read the input signal mode of the specified counter/frequency module.   | 7-34     |
| #AAN           | Read Counter or Frequency Value | Returns the value of counter 0 or counter 1 from a specified counter/ frequency module in hex format                          | 7-35     |

(Continued on following page)

**ADAM-4080 Command Table (Continued)**

| Command Syntax | Command Name                   | Command Description  | Page No. |
|----------------|--------------------------------|--|----------|
| \$AAAG         | Set Gate Mode                  | Requests the specified counter/frequency module to set its gate mode to either high, low or disabled         | 7-40     |
| \$AAA          | Read Gate Mode                 | Requests the specified counter/frequency module to return the status of its gate mode                        | 7-41     |
| \$AA3N(data)   | Set Maximum Counter Value      | Sets the maximum value of counter 0 or counter 1 for the specified counter/frequency module                  | 7-42     |
| \$AA3N         | Read Maximum Counter Value     | Reads the maximum value of counter 0 or counter 1 of the specified counter/frequency module                  | 7-43     |
| \$AA5NS        | Start/Stop Counter             | The command orders the specified counter/frequency module to start or stop counting                          | 7-44     |
| \$AA5N         | Read Counter Start/Stop Status | The addressed counter frequency module returns its status indicating whether counting is enabled or disabled | 7-45     |
| \$AA6N         | Clear Counter                  | The command clears the counter 0 or counter 1 of the specified counter module                                | 7-46     |
| \$AA7N         | Read Overflow Flag             | The addressed module returns the status of the overflow flag of counter 0 or counter 1                       | 7-47     |

(Continued on following page)



# Command Set

---

## ADAM-4080 Command Table (Continued)

| Command Syntax | Command Name                                  | Command Description   | Page No. |
|----------------|---|---|----------|
| \$AA4S         | Enable/Disable Digital Filter                 | Enables or disables the digital filter of the addressed counter/frequency module                    | 7-49     |
| \$AA4          | Read Filter Status                            | The addressed counter frequency module returns the status of its digital filter                     | 7-50     |
| \$AA0H(data)   | Set Minimum Input Signal Width at High Level  | Sets the minimum input signal width at high level for a specified counter/frequency module          | 7-51     |
| \$AA0H         | Read Minimum Input Signal Width at High Level | Reads the minimum input signal width setting at high level for a specified counter/frequency module | 7-52     |
| \$AA0L(data)   | Set Minimum Input Signal Width at Low Level   | Sets the minimum input signal width at low level for a specified counter/frequency module           | 7-53     |
| \$AA0L         | Read Minimum Input Signal Width at Low Level  | Reads minimum input signal width setting at low level for a specified counter/frequency module      | 7-54     |
| \$AA1H(data)   | Set Non-isolated High Trigger Level           | Sets the high trigger level of non-isolated input signals for a specified counter/frequency module  | 7-55     |
| \$AA1H         | Read Non-isolated High Trigger Level          | Requests the addressed counter frequency module to return the high trigger level for non-           | 7-56     |
| \$AA1L(data)   | Set Non-isolated Low Trigger Level            | isolated input signals  | 7-57     |
| \$AA1L         | Read Non-isolated Low Trigger Level           | Sets the low trigger level of non-isolated input signals for a specified counter/frequency module   | 7-58     |

(Continued on following page)

## ADAM-4080 Command Table (Continued)

| Command Syntax | Command Name                          | Command Description   | Page No. |
|----------------|---------------------------------------|---|----------|
| @AAPN(data)    | Set Initial Count Value of Counter N  | Sets the initial count value of the module for counter 0 or counter 1                             | 7-61     |
| @AAGN          | Read Initial Count Value of Counter N | Reads the initial count value of counter 0 or counter 1   | 7-62     |
| @AAEAN         | Enable Alarm of Counter N             | Enable alarm for the specified counter 0 or counter 1   | 7-63     |
| @AADAN         | Disable Alarm of Counter N            | Disable alarm for the specified counter 0 or counter 1  | 7-64     |
| @AAPA(data)    | Set Alarm Limit Value of Counter 0    | Download the alarm limit value for counter 0 of the specified module                              | 7-65     |
| @AASA(data)    | Set Alarm Limit Value of Counter 1    | Download the alarm limit value for counter 1 of the specified module                              | 7-65     |
| @AARP          | Read Alarm Limit Value of Counter 0   | Ask the module to return the alarm limit value of counter 0                                       | 7-66     |
| @AARA          | Read Alarm Limit Value of Counter 1   | Ask the module to return the alarm limit value of counter 1                                       | 7-66     |
| @AADO (data)   | Set Digital Output Values             | Set the values of the module's two digital outputs (ON or OFF)                                    | 7-67     |
| @AADI          | Read Digital Output and Alarm Status  | Ask the module to return the status state of its two digital outputs and the status of its alarm. | 7-68     |

# Command Set

---

ADAM-4080D Command Table

| Command Syntax | Command Name                    | Command Description   | Page No. |
|----------------|---------------------------------|---|----------|
| %AANNTTCFF     | Configuration                   | Sets the address, input mode, baud rate, checksum status and/or frequency gate time for a specified counter/ frequency module                                 | 7-28     |
| \$AA2          | Configuration Status            | Returns configuration parameters from the specified counter/frequency module  | 7-30     |
| \$AAF          | Read Firmware Version           | Return firmware version code from the specified counter/frequency module  | 7-31     |
| \$AAM          | Read Module Name                | Return the module name from the specified counter/frequency module  | 7-32     |
| \$AABS         | Set Input Signal Mode           | Sets the input signal mode of the specified counter/frequency module to either non-isolated or photo-isolated input signals                                   | 7-33     |
| \$AAB          | Read Input Signal Mode          | Read the input signal mode of the specified counter/frequency module.   | 7-34     |
| #AAN           | Read Counter or Frequency Value | Returns the value of counter 0 or counter 1 from a specified counter/ frequency module in hex format  | 7-35     |
| \$AA8V         | Select LED Data Origin          | Select whether LED will display data from the counter/frequency module directly or from the host computer   | 7-36     |
| \$AA8          | Read LED Data Origin            | Returns the status of the LED Data origin. Origin is either direct from module or from host computer  | 7-37     |
| \$AA9(data)    | Send Data to LED                | The host computer sends data to the addressed module to display on its LED. This command is valid only after selecting to display host computer data (\$AA8V) | 7-38     |

(Continued on following page)

**ADAM-4080D Command Table (Continued)**

| Command Syntax | Command Name                   | Command Description  | Page No. |
|----------------|--------------------------------|--|----------|
| \$AAAG         | Set Gate Mode                  | Requests the specified counter/ frequency module to set its gate mode to either high, low or disabled        | 7-40     |
| \$AAA          | Read Gate Mode                 | Requests the specified counter/ frequency module to return the status of its gate mode                       | 7-41     |
| \$AA3N(data)   | Set Maximum Counter Value      | Sets the maximum value of counter 0 or counter 1 for the specified counter/frequency module                  | 7-42     |
| \$AA3N         | Read Maximum Counter Value     | Reads the maximum value of counter 0 or counter 1 of the specified counter/ frequency module                 | 7-43     |
| \$AA5NS        | Start/Stop Counter             | The command orders the specified counter/frequency module to start or stop counting                          | 7-44     |
| \$AA5N         | Read Counter Start/Stop Status | The addressed counter frequency module returns its status indicating whether counting is enabled or disabled | 7-45     |
| \$AA6N         | Clear Counter                  | The command clears the counter 0 or counter 1 of the specified counter module                                | 7-46     |
| \$AA7N         | Read Overflow Flag             | The addressed module returns the status of the overflow flag of counter 0 or counter 1                       | 7-47     |

(Continued on following page)

# Command Set

---

ADAM-4080D Command Table (Continued)

| Command Syntax | Command Name                                  | Command Description   | Page No. |
|----------------|---|---|----------|
| \$AA4S         | Enable/Disable Digital Filter                 | Enables or disables the digital filter of the addressed counter/frequency module                                | 7-49     |
| \$AA4          | Read Filter Status                            | The addressed counter frequency module returns the status of its digital filter                                 | 7-50     |
| \$AA0H(data)   | Set Minimum Input Signal Width at High Level  | Sets the minimum input signal width at high level for a specified counter/frequency module                      | 7-51     |
| \$AA0H         | Read Minimum Input Signal Width at High Level | Reads the minimum input signal width setting at high level for a specified counter/frequency module             | 7-52     |
| \$AA0L(data)   | Set Minimum Input Signal Width at Low Level   | Sets the minimum input signal width at low level for a specified counter/frequency module                       | 7-53     |
| \$AA0L         | Read Minimum Input Signal Width at Low Level  | Reads minimum input signal width setting at low level for a specified counter/frequency module                  | 7-54     |
| \$AA1H(data)   | Set Non-isolated High Trigger Level           | Sets the high trigger level of non-isolated input signals for a specified counter/frequency module              | 7-55     |
| \$AA1H         | Read Non-isolated High Trigger Level          | Requests the addressed counter frequency module to return the high trigger level for non-isolated input signals | 7-56     |
| \$AA1L(data)   | Set Non-isolated Low Trigger Level            | Sets the low trigger level of non-isolated input signals for a specified counter/frequency module               | 7-57     |
| \$AA1L         | Read Non-isolated Low Trigger Level           | Sets the low trigger level of non-isolated input signals for a specified counter/frequency module               | 7-58     |

(Continued on following page)

## ADAM-4080D Command Table (Continued)

| Command Syntax | Command Name                             | Command Description   | Page No. |
|----------------|--|---|----------|
| @AAEAT         | Enable Alarm                             | Enable the alarm in either momentary or latching mode   | 7-69     |
| @AADA          | Disable Alarm                            | Disable all alarm functions   | 7-70     |
| @AACA          | Clear Latch Alarm                        | The latch alarm is reset  | 7-71     |
| @AAPA(data)    | Set Low-Alarm Count Value of Counter 0   | Downloads the low-alarm count value for counter 0 of the specified counter/frequency module       | 7-72     |
| @AASA(data)    | Set High-Alarm Count Value of Counter 0  | Downloads the high-alarm count value for counter 0 of the specified counter/frequency module      | 7-73     |
| @AARP          | Read Low-Alarm Count Value of Counter 0  | Ask the addressed module to return its low-alarm count value for counter 0                        | 7-74     |
| @AARA          | Read High-Alarm Count Value of Counter 0 | Ask the addressed module to return its high-alarm count value for counter 0                       | 7-75     |
| @AADO(data)    | Set Digital Output Values                | Set the values of the module's two digital outputs(ON or OFF)                                     | 7-67     |
| @AADI          | Read Digital Output and Alarm Status     | Ask the module to return the status state of its two digital outputs and the status of its alarm. | 7-68     |

# Analog Input Module Command Set

# 5

## 5.1 Analog Input Common Command Set

| Command Syntax | Description   | I/O Module   |
|----------------|---|--|
| %AANNTCCF<br>F | Sets the address, input range, baud rate, data format, checksum status, and/or integration time for a specified analog input module | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016, 4017, 4017+, 4018, 4018+, 4018M, 4019+ |
| \$AA2          | Returns the configuration parameters for the specified analog input module  | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016, 4017, 4017+, 4018, 4018+, 4018M, 4019+ |
| \$AAF          | Returns the firmware version code from the specified analog input module  | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016, 4017, 4017+, 4018, 4018+, 4018M, 4019+ |
| \$AAM          | Returns the module name from the specified analog input module  | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016, 4017, 4017+, 4018, 4018+, 4018M, 4019+ |
| #AA            | Returns the input value from a specified analog input module in the currently configured data format                                | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016, 4017, 4017+, 4018, 4018+, 4019+        |
| #AAN           | Returns the input value from channel number n of the specified analog input module  | 4015, 4015T, 4017, 4017+, 4018, 4018+, 4018M, 4019+                                |
| #AA5VV         | Enables/disables multiplexing simultaneously for separate channels of the specified input module                                    | 4015, 4015T, 4017, 4017+, 4018, 4018+, 4018M, 4019+                                |
| \$AA6          | Ask the specified input module to return the status of all eight channels   | 4015, 4015T, 4017, 4017+, 4018+, 4018, 4018M, 4019+                                |
| \$AA0          | Calibrate the analog input module to correct for gain errors  | 4011, 4011D, 4012, 4013, 4016, 4017, 4018, 4018M                                   |
| \$AA1          | Calibrate the analog input module to correct for offset errors.   | 4011, 4011D, 4012, 4013, 4016, 4017, 4018, 4018M                                   |
| ###            | Orders all analog input modules to sample their input values and store them in special registers                                    | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016   |

(Continued on following page)



| Command Syntax | Command Description  | I/O Module                                 |
|----------------|--|--|
| \$AA4          | Returns the value that was stored in the specified module's register after the #** command | 4011, 4011D, 4012, 4013, 4015, 4015T, 4016 |
| \$AAB          | Ask the module to respond whether the wiring is open or closed                             | 4011D, 4015, 4015T, 4018+, 4019+           |
| \$AA3          | Returns the value of the CJC sensor for a specified analog input module                    | 4011, 4011D, 4018, 4018+, 4018M, 4019+     |
| \$AA9          | Calibrates the CJC sensor for offset errors  | 4011, 4011D, 4018, 4018+, 4018M 4019+      |
| \$AA0Ci        | Calibrates a specified channel to correct for gain errors                                  | 4015, 4015T, 4017+, 4018+, 4019+           |
| \$AA1Ci        | Calibrates a specified channel to correct for offset errors                                | 4015, 4015T, 4017+, 4018+, 4019+           |
| \$AA7CiRrr     | Configure the input type and range of the specified channel in an analog input module      | 4015, 4015T, 4017+, 4018+, 4019+           |
| \$AA8Ci        | Get the input type and range of the specified channel in an analog input module            | 4015, 4015T, 4017+, 4018+, 4019+           |
| \$AAXnnnn      | Communication Watchdog Timer Setting   | 4015, 4015T, 4017+, 4018+, 4019+           |
| \$AAY          | Read Communication Watchdog Timer Setting  | 4015, 4015T, 4017+, 4018+, 4019+           |
| \$AAS0         | Internal self-calibration for offset and gain errors                                       | 4015, 4015T                                |
| \$AAS1         | Reload factory default calibrating parameter to overwrite current calibrating parameter    | 4015, 4015T                                |

## %AANNTTCFF

**Name** C onfiguration command

**Description** Sets address, input range, baud rate, data format, checksum status, and/or integration time for an analog input module.

**Syntax** %AANNTTCFF(cr)

% is a delimiter character.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module you want to configure.

**NN** represents the new hexadecimal address of the analog input module. Range is from 00h to FFh.

**TT** represents the type (input range) code. (Note: 4015 and 4019 must be 00)

(Refer to Table 5-1 on Page 5-6)

**CC** represents the baud rate code.

(Refer to Table 5-2 on Page 5-8)

**FF** is a hexadecimal number that equals the 8-bit parameter representing the data format, checksum status and integration time. The layout of the 8-bit parameter is shown in Figure 5-1. Bits 2 through 5 are not used and are set to 0.

**(cr)** is the terminating character, carriage return (0Dh)




Figure 5-1 *Data format for FF (8-bit parameter)*

## %AANNTCCFF

**Response**      **!AA(cr)** if the command is valid.  
                  **?AA(cr)** if an invalid parameter was entered or if the INIT\* terminal was not grounded when attempting to change baud rate or checksum settings.  
                  There is no response if the module detects a syntax error or communication error or if the specified address does not exist.  
                  **!** delimiter character indicates a valid command was received.  
                  **?** delimiter character indicates the command was invalid  
                  **AA** (range 00-FF) represents the 2-character hexadecimal address of an analog input module.  
                  **(cr)** is the terminating character, carriage return (0Dh)

**Example**    command:    %2324050600(cr)  
                  response: !2      4(cr)

The ADAM-4011 module with address 23h is configured to a new address of 24h, an input range  $\pm 2.5$  V, baud rate 9600, integration time 50 ms (60 Hz), engineering units data format and no checksum checking or generation.

The response indicates that the command was received.

Wait 7 seconds to let the new configuration settings take effect before issuing a new command to the module.

**NOTICE:** *Only ADAM-4011, ADAM-4011D, ADAM-4012, ADAM-4013, ADAM-4016 and ADAM-4018+ support “% of FSR” and “two’s complement of hexadecimal” Data Format.*

**NOTICE:** *An analog input module requires a maximum of 7 seconds to perform auto calibration and ranging after it is reconfigured. During this time span, the module cannot be addressed to perform any other actions.*

**NOTICE:** *All configuration parameters can be changed dynamically, except checksum and baud rate parameters. They can only be altered when the INIT\* terminal is grounded. (Refer to Baud rate and Checksum configuration in Chapter 2, for the correct procedure)*

Table 5-1 *Input Range Codes (Type Codes)*

| Input Range Code (Hex) | Input Range for 4011, 4011D, 4018, 4018+<br>(Thermocouple and $\pm 20$ mA only), 4018M |
|------------------------|--|
| 00                     | $\pm 15$ mV  |
| 01                     | $\pm 50$ mV  |
| 02                     | $\pm 100$ mV   |
| 03                     | $\pm 500$ mV   |
| 04                     | $\pm 1$ V  |
| 05                     | $\pm 2.5$ V  |
| 06                     | $\pm 20$ mA  |
| 0E                     | Type J Thermocouple 0 ~ 760 °C   |
| 0F                     | Type K Thermocouple 0 ~ 1370 °C  |
| 10                     | Type T Thermocouple -100 ~ 400 °C  |
| 11                     | Type E Thermocouple 0 ~ 1000 °C  |
| 12                     | Type R Thermocouple 500 ~ 1750 °C  |
| 13                     | Type S Thermocouple 500 ~ 1750 °C  |
| 14                     | Type B Thermocouple 500 ~ 1800 °C  |

| Input Range Code(Hex) | Input Range for 4012,4017,4017+ |
|-----------------------|---------------------------------|
| 08                    | $\pm 10$ V                      |
| 09                    | $\pm 5$ V                       |
| 0A                    | $\pm 1$ V                       |
| 0B                    | $\pm 500$ mV                    |
| 0C                    | $\pm 150$ mV                    |
| 0D                    | $\pm 20$ mA                     |

Notice: The input range requires the usage of a 125  $\Omega$  current conversion resistor

| Input Range Code (Hex) | Input Range for 4016 |
|------------------------|----------------------|
| 00                     | $\pm 15$ mV          |
| 01                     | $\pm 50$ mV          |
| 02                     | $\pm 100$ mV         |
| 03                     | $\pm 500$ mV         |
| 06                     | $\pm 20$ mA          |

| Input Range Code (Hex) | Input Range for 4013                |
|------------------------|-------------------------------------|
| 20                     | Platinum, -100 ~ 100 °C, a=0.00385  |
| 21                     | Platinum, 0 ~ 100 °C, a=0.00385     |
| 22                     | Platinum, 0 ~ 200 °C, a=0.00385     |
| 23                     | Platinum, 0 ~ 600 °C, a=0.00385     |
| 24                     | Platinum, -100 ~ 100 °C, a=0.003916 |
| 25                     | Platinum, 0 ~ 100 °C, a=0.003916    |
| 26                     | Platinum, 0 ~ 200 °C, a=0.003916    |
| 27                     | Platinum, 0 ~ 600 °C, a=0.003916    |
| 28                     | Nickel, -80 ~ 100 °C                |
| 29                     | Nickel, 0 ~ 100 °C                  |

***ADAM-4015/4015T command codes against Input ranges table***

| Command Code (Hex) | Input Type         | Input Range   |
|--------------------|--------------------|---------------|
| 20                 | Platinum 100 (IEC) | -50 ~ 150 °C  |
| 21                 | Platinum 100 (IEC) | 0 ~ 100 °C    |
| 22                 | Platinum 100 (IEC) | 0 ~ 200 °C    |
| 23                 | Platinum 100 (IEC) | 0 ~ 400 °C    |
| 24                 | Platinum 100 (IEC) | -200 ~ 200 °C |
| 25                 | Platinum 100 (JIS) | -50 ~ 150 °C  |
| 26                 | Platinum 100 (JIS) | 0 ~ 100 °C    |
| 27                 | Platinum 100 (JIS) | 0 ~ 200 °C    |
| 28                 | Platinum 100 (JIS) | 0 ~ 400 °C    |
| 29                 | Platinum 100 (JIS) | -200 ~ 200 °C |
| 2A                 | Platinum 1000      | -40 ~ 160 °C  |
| 2B                 | BALCO 500          | -30 ~ 120 °C  |
| 2C                 | Ni 604             | -80 ~ 100 °C  |
| 2D                 | Ni 604             | 0 ~ 100 °C    |
| 30                 | Thermistor 3K      | 0 ~ 100 °C    |
| 31                 | Thermistor 10K     | 0 ~ 100 °C    |
| 33                 | Ni 508             | -50 ~ 200 °C  |

IEC RTD 1000,  $\alpha = 0.00385$

JIS RTD 1000,  $\alpha = 0.00391$

| Input Range Code (Hex) | Input Range for 4019+             |
|------------------------|-----------------------------------|
| 02                     | $\pm 100$ mV                      |
| 03                     | $\pm 500$ mV                      |
| 04                     | $\pm 1$ V                         |
| 05                     | $\pm 2.5$ V                       |
| 07                     | +4~20mA                           |
| 08                     | $\pm 10$ V                        |
| 09                     | $\pm 5$ V                         |
| 0D                     | $\pm 20$ mA                       |
| 0E                     | Type J Thermocouple 0 ~ 760 °C    |
| 0F                     | Type K Thermocouple 0 ~1370 °C    |
| 10                     | Type T Thermocouple -100 ~ 400 °C |
| 11                     | Type E Thermocouple 0 ~ 1000 °C   |
| 12                     | Type R Thermocouple 500 ~ 1750 °C |
| 13                     | Type S Thermocouple 500 ~ 1750 °C |
| 14                     | Type B Thermocouple 500 ~ 1800 °C |

**Table 5-2 Baud Rate Codes**

| Baud Rate Code (Hex) | Baud Rate |
|----------------------|-----------|
| 03                   | 1200 bps  |
| 04                   | 2400 bps  |
| 05                   | 4800 bps  |
| 06                   | 9600 bps  |
| 07                   | 19.2 kbps |
| 08                   | 38.4 kbps |

## \$AA2

**Name** Configuration Status command

**Description** The command requests the return of the configuration data from the analog input module at address AA.

**Syntax** **\$AA2(cr)**

\$ is a delimiter character.

AA (range 00-FF) represents the 2-character hexadecimal address of the analog input module that you want to interrogate.

2 is the Configuration Status command.

(cr) is the terminating character, carriage return (0Dh).

**Response** **!AATTCCFF(cr)** if the command is valid.

**?AA(cr)** if an invalid operation was entered.

There is no response if the module detects a syntax error or communication error or if the specified address does not exist.

! delimiter character indicates a valid command was received.

? delimiter character indicates the command was invalid.

AA (range 00-FF) represents the 2-character hexadecimal address of an analog input module.

TT represents the type code. Type code determines the input range.

CC represents the baud rate code.

FF is a hexadecimal number that equals the 8-bit parameter that represents the data format, checksum status and integration time. The layout of the 8-bit parameter is shown in figure 4-1. Bits 2 to 5 are not used, and are set to 0.

(cr) is the terminating character, carriage return (0Dh).

(Please refer to %AANNTTCCFF configuration command to see TT, CC and FF parameter definition)

## **\$AA2**

**Example com**            mand:    \$452(cr)  
                              response: !    45050600(cr)

The command asks the analog input module at address 45h to send its configuration data.

The analog input module at address 45h responds with an input range of 2.5 volts, a baud rate of 96 00 bps, an integration time of 50 ms (60 Hz), engineering units are the currently configured data format, and no checksum function or checksum generation.



## **\$AAF**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Firmware Version command   |
| <b>Description</b> | The command requests the analog input module at address AA to return the version code of its firmware.  |
| <b>Syntax</b>      | <p><b>\$AAF(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module that you want to interrogate.</p> <p><b>F</b> is the Read Firmware Version command.</p> <p><b>(cr)</b> is the terminating character, carriage return (ODh).</p>   |
| <b>Response</b>    | <p><b>!AA(Version)(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax error or communication error, or if the specified address does not exist.</p> <p><b>!</b> is a delimiter character indicating a valid command was received.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>(Version)</b> is the version code of the module's firmware at address AA.</p> <p><b>(cr)</b> is the terminating character, carriage return (ODh).</p> |

## **\$AAM**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Module Name command   |
| <b>Description</b> | The command requests the analog input module at address AA to return its name.   |
| <b>Syntax</b>      | <p><b>\$AAM (cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module that you want to interrogate.</p> <p><b>M</b> is the Read Module Name command.</p> <p><b>(cr)</b> is the terminating character, carriage return (ODh).</p>  |
| <b>Response</b>    | <p><b>!AA(Module Name)(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax error or communication error, or if the specified address does not exist.</p> <p><b>!</b> is a delimiter character indicating a valid command was received.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>(Module Name)</b> is the name of the module at address AA.</p> <p><b>(cr)</b> is the terminating character, carriage return (ODh).</p> |

## #AA

**Name** Analog Data In command

**Description** The command will return the input value from a specified (AA) module in the currently configured data format.

**Syntax** **#AA(cr)**

# is a delimiter character.

AA (range 00-FF) represents the 2-character hexadecimal address of an analog input module.

(cr) is the terminating character, carriage return (0Dh).

**Response** **>(data)(cr)**

There is no response if the module detects a syntax error or communication error or if the specified address does not exist.

> is a delimiter character.

(data) is the input value in the configured data format of the interrogated module.

(For data formats, see Appendix B).

(cr) is the terminating character, carriage return (0Dh).

## Example

command: #21(cr)

response: >+7.2111+7.2567+7.3125+7.1000  
+7.4712+7.2555+7.1234+7.5678 (cr)

The command interrogates the analog input module at address 21h for its input values of all channels.

The analog input module responds with channels from 0 to 7 with +7.2111 volts, +7.2567 volts, +7.3125 volts, +7.1000 volts, +7.4712 volts, +7.2555 volts, +7.1234 volts and +7.5678 volts.

## #AA

**Example**            command:    #DE(cr)  
r                    response:    >FF5D(cr)  
The analog input module at address DEh has an input value of FF 5D. (The configured data format of the analog input module is two's complement)

|       | Two's complement | % of Span | Engineering units |
|-------|------------------|-----------|-------------------|
| under | 0000             | -0000     | -0000             |
| over  | FFFF             | +9999     | +9999             |

**NOTICE:** *When modules measure Thermocouple or RTD input values that are outside their configured range they will send data that implies input out of bounds. The next table shows the values that the modules will return, depending on the configured data format and if the input value falls under or exceeds the configured range.*

*Only when modules are configured for Thermocouple or RTD, "input out of bounds" warning will occur. When analog input modules measure voltage or current that falls outside the configured range, they will return the actual measured input!*

In the next example the target module is configured for an input range of T/C type J (Input range: 0 ~ 760 °C) and for a data format in engineering units. The module measures an input value of 820 °C.

**Example**            command:    #D1(cr)  
                      response:    >+9999(cr)  
By returning a high value, +9 999, the module at address D1h indicates that the measured input value exceeds the configured range.

## #AAN

**Name** Read Analog Input from Channel N command

**Description** The command will return the input value from one of the eight channels of a specified (AA) module in the currently configured data format.

**Syntax** **#AAN(cr)**  
**#** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module.  
**N** identifies the channel you want to read. The value can range from 0 to 7 for 4017, 4018, 4018M, 4019. (The range of 4015 is from 0 to 5)  
**(cr)** is the terminating character, carriage return (0Dh).

**Response** **>(data)(cr)**  
There is no response if the module detects a syntax error or communication error or if the specified address does not exist.  
**>** is a delimiter character.  
**(data)** is the input value of the channel number N. Data consists of a + or - sign followed by five decimal digits with a fixed decimal point.  
**(cr)** is the terminating character, carriage return (0Dh).

**Example** command: #120(cr)  
response: >+1.4567(cr)

The command requests the analog input module at address 12h to return the input value of channel 0.

The analog input module responds that the input value of channel 0 is equal to +1.4567 volts.

## **\$AA5VV**

**Name** Enable/disable Channels for Multiplexing command  
**Description** Enables/disables multiplexing simultaneously for separate channels of a specified input module.

**Syntax** **\$AA5VV(cr)**  
**\$** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of analog input module.  
**5** is the Enable/disable Channels command.  
**VV** are two hexadecimal values. The values are interpreted by the module as two binary words (4-bit). The first word represents the status of channel 4~7, and the second word represents the status of channel 0~3. Value 0 means the channel is disabled, value 1 means the channel is enabled.  
**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AA(cr)** if the command is valid.  
**?AA(cr)** if an invalid operation was entered.  
There is no response if the module detects a syntax error or communication error or if the specified address does not exist.  
**!** delimiter character indicates a valid command was received.  
**?** delimiter character indicates the command was invalid.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of an analog input module.  
**(cr)** is the terminating character, carriage return (0Dh).

**Example**  
command: \$00581(cr)  
response: !00(cr)  
Hexadecimal 8 equals binary 1000, which enables channel 7 and disables channels 4, 5, and 6.  
Hexadecimal 1 equals binary 0001, which enables channel 0 and disables channel 1, 2, and 3.

## \$AA6

**Name** Read Channel Status command

**Description** Asks a specified input module to return the status of all channels.

**Syntax** **\$AA6(cr)**

**AA** (range 00-FF) represents the 2-character hexadecimal address of analog input module of which the channel status you want to send. The channel status defines whether a channel is enabled or disabled.

**6** is the Read Channel Status command.

**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AAVV(cr)** if the command is valid.

**?AA(cr)** if an invalid operation was entered.

There is no response if the module detects a syntax error or communication error or if the specified address does not exist.

**!** delimiter character indicates a valid command was received.

**?** delimiter character indicates the command was invalid.

**AA** (range 00-FF) represents the 2-character hexadecimal address of an analog input module.

**VV** are two hexadecimal values. The values are interpreted by the module as two binary words (4-bit). The first word represents the status of channel 4-7, and the second word represents the status of channel 0-3. Value 0 means the channel is disabled, value 1 means the channel is enabled.

**(cr)** is the terminating character, carriage return (0Dh).

**Example command:** \$026(cr)

**response:** !0 2FF(cr)

The command asks the analog input module at address 02 to send the status of its input channels. The analog input module at address 02 responds that all its multiplex channels are enabled (FF equals 1111 and 1111).

## **\$AA0**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Span Calibration command   |
| <b>Description</b> | Calibrates an analog input module to correct for gain errors.  |
| <b>Syntax</b>      | <b>\$AA0(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be calibrated.<br><b>0</b> is the Span Calibration command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>?</b> delimiter character indicates the command was invalid.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |

In order to successfully calibrate an analog input module's input range, a proper calibration input signal should be connected to the analog input module before and during the calibration. (See also Chapter 8, Calibration)

***NOTICE:*** *An analog input module requires a maximum of 7 seconds to perform auto calibration and ranging after it received a Span Calibration command. During this interval, the module can not be addressed to perform any other actions.*



**\$AA1**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Offset Calibration command  |
| <b>Description</b> | Calibrates an analog input module to correct for offset errors.   |
| <b>Syntax</b>      | <b>\$AA1(cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the analog input module you want to calibrate.<br>1 is the Offset Calibration command.<br>(cr) is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command is valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br>! delimiter character indicates a valid command was received.<br>? delimiter character indicates the command was invalid.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the analog input module.<br>(cr) represents terminating character, carriage return (0Dh). |

In order to successfully calibrate an analog input module's input range, a proper calibration input signal should be connected to the analog input module before and during the calibration. (See also Chapter 8, Calibration)

**NOTICE:** *An analog input module requires a maximum of 7 seconds to perform auto calibration and ranging after it received an Offset Calibration command. During this interval, the module can not be addressed to perform any other actions.*

**##**

**Name** Synchronous Sampling command

**Description** Orders all analog input modules to sample their input values and store the values in special registers.

**Syntax** ##

# is a delimiter character.

\*\* is the Synchronous Sampling command.

The terminating character, in the form of a carriage return (0Dh), is not required.

**Response** The analog input modules will send no response after executing the synchronous sampling command. In order to retrieve the data, a separate Read Synchronous Data command has to be issued for every analog input module.

The pound sign (#) followed by two asterisks (\*\*) does not represent an optional value, but is the actual command string.

## \$AA4

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Synchronized Data command  |
| <b>Description</b> | Returns the input value that was stored in the addressed module's register, after a Synchronized Sampling command <b>##*</b> was issued.  |
| <b>Syntax</b>      | <b>\$AA4(cr)</b><br><b>\$</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module from which data is to be sent.<br><b>4</b> is the Read Synchronized Data command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(status)(data)(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module that is responding.<br><b>(status)</b> will tell you if the data (data) from the last Synchronized Sampling command ( <b>##*</b> ) has already been sent. If status = 1, then the data has been sent for the first time since a Synchronized Sampling command was issued. If status = 0, then the data has been sent at least once before.<br><b>(data)</b> a value stored in a special register of the interrogated module in the configured data format. It has been sampled by the module after a Synchronized Sampling command. (For possible data formats, see Appendix B, Data Formats and I/O Ranges)<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |

## **\$AA4**

**Example com**            mand: \$074(cr)  
                              response: >071+5.8222(cr)

The command asks the analog input module at address 07h to send its analog input data.

The analog input module responds with status = 1, which means that this is the first time that the data has been sent and that the data = +5.8222 Volts.

(Configured data format of the analog input module in this case is engineering units.)

command: \$0 74(cr)  
response: >0 70+5.8222(cr)

The command asks the analog input module at address 07h to send its analog input data.

The analog input module responds with status = 0, which means that it has sent the same data at least once before, and data = + 5.8222 Volts. This could indicate that a previous Synchronized Sampling command was not received!

(Configured data format of the analog input module in this case is engineering units.)

**\$AAB**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Channel Diagnose command   |
| <b>Description</b> | Diagnose channel status in over range, under range, and wire opening.  |
| <b>Syntax</b>      | <p><b>\$AAB(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module to be detected.</p> <p><b>B</b> is the Channel Diagnose command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>ADAM-4011D:</b></p> <p><b>!AA0(cr)</b> if the module detects a closed thermocouple.</p> <p><b>!AA1(cr)</b> if the module detects an open thermocouple.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p><b>ADAM-4015/4015T/4018+/4019+:</b></p> <p><b>!AANN(cr)</b> if the command is valid when it applied with.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.</p> <p><b>NN</b> (range 00-FF) is a hexadecimal number that equals the 8-bit parameter, representing the status of an analog input channels. Bit value 0 means normal status; and bit value 1 means channel over range, under range, or open wiring.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p> |

**\$AA3**

|                         |   |
|-------------------------|---|
| <b>Name</b>             | CJC Status command  |
| <b>Description</b>      | Instructs the addressed analog input module to read its CJC (Cold Junction Compensation) sensor's and return the acquired data.   |
| <b>Syntax</b>           | <p><b>\$AA3(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which contains the CJC Status you wish to retrieve.</p> <p><b>3</b> is the CJC Status command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>         | <p><b>&gt;data(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>(data)</b> is the value that is retrieved by the module by reading its CJC sensor. The data format, in degrees Celsius, consists an "+" or "-" sign followed by five decimal digits and a fixed decimal point. The resolution of the data is 0.1 °C.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example command:</b> | <b>\$093(cr)</b>  |
| <b>response:</b>        | <b>&gt;+0036.8(cr)</b>  |
|                         | The command requests the analog input module at address 09h to read its CJC sensor and return the data. The analog input module at address 09h responds with: 36.8°C.   |

**\$AA9SNNNN**

|                    |   |
|--------------------|---|
| <b>Name</b>        | CJC Offset Calibration command  |
| <b>Description</b> | Calibrates an analog input module to adjust for offset errors of its CJC (Cold Junction Compensation) sensors.  |
| <b>Syntax</b>      | <p><b>\$AA9SNNNN(number of counts)(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which contains the CJC status you wish to retrieve.</p> <p><b>9</b> is the CJC Status command.</p> <p><b>S</b> sign, + or -, indicates whether to increase or decrease the CJC offset value.</p> <p><b>NNNN</b> (number of counts) is a four character hexadecimal “count” value. Each count equals approximately 0.009 °C. The value can range from 0000 to FFFF.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Example</b>     | <p>command: \$079+0042(cr)</p> <p>response: !0 7(cr)</p> <p>The command increases the CJC offset value of the analog input module at address 07h with 66 counts (42 hex) which equals about 0.6 °C.</p>   |

**NOTICE:** *An analog input module requires a maximum of 2 seconds to perform auto calibration and ranging after it received a CJC Calibration command. During this interval, the module can not be addressed to perform any other actions.*

**\$AA0Ci**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Single Channel Span Calibration command   |
| <b>Description</b> | The command calibrates a specified channel to correct for gain errors.  |
| <b>Syntax</b>      | <p><b>\$AA0Ci(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be calibrated.</p> <p><b>0</b> is the Single Channel Span Calibration command.</p> <p><b>Ci</b> represents the specified input channel you want to calibrate.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |

In order to successfully calibrate an analog input module's input range, a proper calibration input signal should be connected to the analog input module before and during the calibration. (See also Chapter 8, Calibration)

**NOTICE:** *An analog input module requires a maximum of 7 seconds to perform auto calibration and ranging after it received a Span Calibration command. During this interval, the module can not be addressed to perform any other actions.*



**\$AA1Ci**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Single Channel Offset Calibration command   |
| <b>Description</b> | The command calibrates a specified channel to correct for offset errors.  |
| <b>Syntax</b>      | <p><b>\$AA1Ci(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be calibrated.</p> <p><b>1</b> is the Single Channel Offset Calibration command.</p> <p><b>Ci</b> represents the specified input channel you want to calibrate.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$021C5(cr)</p> <p>response: !02(cr)</p> <p>The command calibrates channel 5 of the analog input module at address 02 for correcting offset errors.</p>   |

**\$AA7CiRrr**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Single Channel Range Configuration command  |
| <b>Description</b> | This command configures the input type and range of the specified channel in an analog input module.  |
| <b>Syntax</b>      | <p><b>\$AA7CiRrr(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be configured.</p> <p><b>7</b> is the Single Channel Range Configuration command.</p> <p><b>Ci</b> represents the specified input channel you want to configure.</p> <p><b>Rrr</b> represents the type and range you want to set. (Refer to Table 5-1 on Page 5-6 to check range codes)</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>                            |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$027C5R21(cr)</p> <p>response: !02(cr)</p> <p>The command configures the range of channel 5 in the analog input module at address 02 as Pt 100(IEC) 0 ~ 100 °C.</p>  |

**\$AA8Ci**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Single Channel Range Configuration command  |
| <b>Description</b> | This command read the input type and range configuration of the specified channel in an analog input module.   |
| <b>Syntax</b>      | <p><b>\$AA8Ci(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be read.</p> <p><b>8</b> is the Read Single Channel Range Configuration command.</p> <p><b>Ci</b> represents the specified input channel you want to read.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AAiRrr(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.</p> <p><b>Ci</b> represents the specified input channel you read.</p> <p><b>Rrr</b> represents the type and range setting in the specified channel.</p> <p>(Refer to Table 5-1 on Page 5-6 to check range codes)</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$028C5(cr)</p> <p>response: !02C5R21(cr)</p> <p>The command read the range of channel 5 in the analog input module at address 02. The response "R 21" means Pt100 (IEC) 0 ~ 100 °C.</p>   |

**\$AAXnnnn**

**Name** Watchdog Timer Setting command

**Description** This command sets the communication watchdog timer (WDT) cycle time.

**Syntax** **\$AAXnnnn(cr)**

**\$** is a delimiter character.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be read.

**X** is the Watchdog Timer Setting command.

**nnnn** (range 0000~9999) represents the specified value of communication cycle you want to set. (Unit: 0.1 second)

**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AA(cr)** if the command was valid.

**?AA(cr)** if an invalid operation was entered.

There is no response if the module detects a syntax error or communication error or if the specified address does not exist.

**!** delimiter character indicates a valid command was received.

**?** delimiter character indicates the command was invalid.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module.

**(cr)** represents terminating character, carriage return (0Dh).

**Example** command: \$02X1234(cr)

response: !02(cr)

The command sets the WDT cycle as 1234 in the input module at address 02.

**NOTICE:** *If the value of “nnnn” is 0000, the communication WDT function will be disable.*

**\$AA Y**

**Name** Read Communication Watchdog Timer Cycle Setting command

**Description** This command read the setting of communication watchdog timer (WDT) cycle time.

**Syntax** **\$AA Y(cr)**  
**\$** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be read.  
**Y** is the Read Communication WDT Cycle Setting command.  
**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AAnnnn(cr)** if the command was valid.  
**?AA(cr)** if an invalid operation was entered.  
 There is no response if the module detects a syntax error or communication error or if the specified address does not exist.  
**!** delimiter character indicates a valid command was received.  
**?** delimiter character indicates the command was invalid.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module.  
**nnnn** (range 0000~9999) represent the specified value of communication cycle you read. (Unit: 0.1 second)  
**(cr)** represents terminating character, carriage return (0Dh).

**Example** command: \$02Y(cr)  
 response: !020030(cr)  
 The command read the WDT cycle as 0030 in the input module at address 02.

**\$AAS0**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Internal Calibration command   |
| <b>Description</b> | This command executes internal self-calibration for offset and gain errors.  |
| <b>Syntax</b>      | <b>\$AAS0(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be calibrated.<br><b>S0</b> is the Internal Calibration command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>?</b> delimiter character indicates the command was invalid.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |

**\$AAS1**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Reload Default Calibrating Parameter command   |
| <b>Description</b> | Reload factory default calibrating parameter to overwrite current calibrating parameter.   |
| <b>Syntax</b>      | <b>\$AAS1(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be reloaded.<br><b>S1</b> is the Reload Calibrating Parameter command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>?</b> delimiter character indicates the command was invalid.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |

---

## 5.2 Analog Input Data Logger Command Set

| Command Syntax       | Command Name                  | Description   | I/O Module |
|----------------------|-------------------------------|---|------------|
| @AACCCSDMTT<br>TT    | Set Memory<br>Configuration   | Set the channel storage status, standalone mode, data logger mode, storage type and sampling interval for the specified analog input data logger. | 4018M      |
| @AAD                 | Read Memory<br>Configuration  | Return the configuration parameters for the specified analog input data logger.   | 4018M      |
| @AASO                | Set Memory<br>Operation Mode  | Start/stop the recording function of the memory module.   | 4018M      |
| @AAT                 | Read Memory<br>Operation Mode | Read the recording status of the memory module.   | 4018M      |
| @AAL                 | Event Record<br>Count         | Read the number of stored event records in the memory module.   | 4018M      |
| @AAN                 | Standard Record<br>Count      | Read the number of stored standard records in the memory module.  | 4018M      |
| @AARNNNN             | Read Record<br>Content        | Read the contents of the specified record.  | 4018M      |
| @AAACSDHHHH<br>TEIII | Set Alarm Limit               | Set the high/low alarm settings for the specified channel.  | 4018M      |
| @AABC                | Read Alarm Limit              | Read the high/low alarm settings for the specified channel.   | 4018M      |



**@AACCCSDMTTTT**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Memory Configuration command  |
| <b>Description</b> | Sets the channel storage status, standalone mode, data logger mode, storage type and sampling interval for the specified analog input data logger.  |
| <b>Syntax</b>      | <p><b>@AACCCSDMTTTT(cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.</p> <p><b>C</b> is the Set Memory Configuration command.</p> <p><b>CC</b> (range 00-FF) represents the data storage status of each channel. The ADAM-4018M has 8 channels, bit 0 representing channel 0, and bit 7 representing channel 7. A mask bit value of '1' enables data storage in the specified channel, while a mask bit value of '0' disables data storage.</p> |

|           |       |       |       |       |       |           |       |
|-----------|-------|-------|-------|-------|-------|-----------|-------|
| Channel 7 |       |       |       |       |       | Channel 0 |       |
| Bit 7     | Bit 6 | Bit 5 | Bit 4 | Bit 3 | Bit 2 | Bit 1     | Bit 0 |

**S** represents the standalone mode. In order for the ADAM-4018M to operate in the field, you must power on the memory module by setting this value to '1.' Otherwise, the data will not be recorded.

**D** represents the data logging mode. '0' enables Standard Mode, where all eight channels record the normal data according to the sampling interval. '1' enables Event Mode, where all eight channels record the data if its value is over the High Alarm limit or under the Low Alarm limit. '2' enables Mixed Mode, where channels 0 ~ 3 act as the standard logger and the channels 4 ~ 7 act as the event logger.

**M** represents the storage type. "0" represents writing to the end of memory. "1" represents circular memory mode.

**TTTT** (range 2-65535) represents the sampling interval in seconds.

**(cr)** is the terminating character, carriage return (0Dh).

**@AACCCSDMTTTT**

**Response**     **!AA(cr)** if the configuration is successful.  
                  **?AA(cr)** if the configuration fails.  
                  **!** and **?** are delimiter characters.  
                  **AA** (range 00-FF) represents the 2-character hexadecimal address of an analog input module.  
                  **(cr)** represents terminating character, carriage return (0Dh).

**Example**       command:    @0DCFF111012C(cr)  
                  response:   !0D(cr)

The ADAM-4018M module at address 0D is configured as such:

All eight data storage channels enabled  
Standalone mode enabled  
Event logger selected  
Circular memory mode  
Sampling interval 300 seconds

The response indicates the command is successful.

**@AAD**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Memory Configuration command   |
| <b>Description</b> | The command requests the configuration data from the analog input data logger at address AA.  |
| <b>Syntax</b>      | <p><b>@AAD (cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.</p> <p><b>D</b> is the Read Memory Configuration command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AACCSDMTTTT(cr)</b> if the command is valid.</p> <p>! is a delimiter character indicating a valid command was received.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.</p> <p><b>CC</b> (range 00-FF) represents the data storage status of each channel. The ADAM-4018M has 8 channels, bit 0 representing channel 0, and bit 7 representing channel 7. A mask bit value of '1' enables data storage in the specified channel, while a mask bit value of '0' disables data storage.</p> <p><b>Sr</b> represents the standalone mode. In order for the ADAM-4018M to operate in the field, you must power on the memory module by setting this value to '1.' Otherwise, the data will not be recorded.</p> <p><b>D</b> represents the data logging mode. '0' enables Standard Mode, where all eight channels record the normal data according to the sampling interval. '1' enables Event Mode, where all eight channels record the data if its value is over the High Alarm limit or under the Low Alarm limit. '2' enables Mixed Mode, where channels 0 ~ 3 act as the standard logger and the channels 4 ~ 7 act as the event logger.</p> <p><b>M</b> represents the storage type. "0" represents writing to the end of memory. "1" represents circular memory mode.</p> <p><b>TTTT</b> (range 2-65535) represents the sampling interval in seconds.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |

**@AASO**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Memory Operation Mode command  |
| <b>Description</b> | Sets the operation mode of the analog input data logger at address AA to Start or Stop.  |
| <b>Syntax</b>      | <b>@AASO(cr)</b><br>@ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br><b>S</b> is the Set Memory Operation Mode command.<br><b>O</b> represents the operation mode:<br>‘1’: enables the recording of data.<br>‘0’: disables the recording of data.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command is valid.<br><b>?AA(cr)</b> if an invalid parameter was entered. There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> is a delimiter character indicating a valid command was received.<br><b>?</b> is a delimiter character indicating the command was invalid.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @03S1(cr)<br>response: !03(cr)<br>The command enables the analog input data logger at address 03 to record data.<br>The response indicates that the command was received.   |

**@AAT**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Memory Operation Mode command   |
| <b>Description</b> | Request the memory operation status of the analog input data logger at address AA.   |
| <b>Syntax</b>      | <p><b>@AAT (cr)</b><br/> <b>@</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br/> <b>T</b> is the Read Memory Operation Mode command.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AAO(cr)</b> if the command is valid.<br/> <b>!</b> is a delimiter character indicating a valid command was received.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br/> <b>O</b> represents the operation mode:<br/> ‘1’: enables the recording of data.<br/> ‘0’: disables the recording of data.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @F3T(cr)<br/> response: !F31(cr)</p> <p>The command requests the memory operation status of the analog input data logger at address F3.<br/> The response indicates that data recording is enabled.</p>  |

**@AAL**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Event Record Count command  |
| <b>Description</b> | Request the number of event records stored in the analog input data logger at address AA.   |
| <b>Syntax</b>      | <b>@AAL (cr)</b><br>@ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br><b>L</b> is the Event Record Count command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AAHHHH(cr)</b> if the command is valid.<br>! is a delimiter character indicating a valid command was received.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br><b>HHHH</b> represents the 4-character hexadecimal number of event records stored in the analog input data logger at address AA.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @F3L(cr)<br>response: !F30096(cr)<br>The command requests the number of event records stored in the analog input data logger at address F3.<br>The module currently has 150 event records.   |

**@AAN**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Standard Record Count command  |
| <b>Description</b> | Request the number of standard records stored in the analog input data logger at address AA.   |
| <b>Syntax</b>      | <b>@AAN (cr)</b><br>@ is a delimiter character<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br><b>N</b> is the Standard Record Count command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>!AAHHHH(cr)</b> if the command is valid.<br>! is a delimiter character indicating a valid command was received.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br><b>HHHH</b> represents the 4-character hexadecimal number of data records stored in the analog input data logger at address AA.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @A3N(cr)<br>response: !A30320(cr)<br>The command requests the number of data records stored in the analog input data logger at address A3.<br>The module currently has 800 data records.  |

**@AARNNNN**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Record Content command   |
| <b>Description</b> | Request the content of record NNNN stored in the analog input data logger at address AA.  |
| <b>Syntax</b>      | <p><b>@AARNNNN (cr)</b></p> <p>@ is a delimiter character.</p> <p>AA (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.</p> <p>R identifies the Read Record Content command.</p> <p>NNNN represents the 4-character hexadecimal number of stored record index. Its value is from 0 to (total record number - 1).</p> <p>(cr) is the terminating character, carriage return (0Dh).</p> |


**NOTE:**

*NNNN is from 0 to 9470 for Standard Mode.*

*NNNN is from 0 to 4599 for Event Mode.*

*NNNN is from 0 to 7299 for Mixed Mode. (0-4999 are data records, 5000-7299 are event records)*

|                 |   |
|-----------------|---|
| <b>Response</b> | <p><b>!AACDHHHH(cr)</b> if the returned data are data records.</p> <p><b>!AACDHHHHTTTTTTT(cr)</b> if the returned data are event records.</p> <p>! is a delimiter character indicating a valid command was received.</p> <p>AA (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p>C represents the channel index. Its value is from 0 to 7.</p> <p>D represents the 4-bit binary number. Bit 0 represents the sign of the number HHHH. '0' means positive. '1' means negative. Bits 1 ~3 represents the decimal point of the number HHHH.</p> |
|-----------------|---|





**@AARNNNN**

**HHHH** represents the 4-character hexadecimal number of returned record stored in the analog input data logger at address AA.

**TTTTTTT** represents elapsed time.

**(cr)** is the terminating character, carriage return (0Dh).

**Example**

command: @F3**R**1000(cr)

response: !F30799AA00001000(cr)

The command requests the analog input data logger at address F3 to return its contents in the 1001st record.

The returned content is valid. The event data number is -39.338 for channel 0 in the 4096 seconds from the start of the module.

**@AAACSDHHHTEIII**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Alarm Limit command  |
| <b>Description</b> | Set high/low alarm limits for the channel C in the analog input data logger at address AA.   |
| <b>Syntax</b>      | <p><b>@AAACSDHHHTEIII(cr)</b></p> <p>@ is a delimiter character</p> <p>AA (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.</p> <p>A is the Set Alarm Limit command.</p> <p>C represents the channel index. Its value is from 0 to 7.</p> <p>S represents the sign of the high alarm limit.</p> <p>‘+’ is for positive, and ‘-’ is for negative.</p> <p>D represents the decimal point of the high alarm limit. Its value is from 0 to 5.</p> <p>HHHH represents the 4-character hexadecimal number of high alarm limit.</p> <p>T represents the sign of the low alarm limit.</p> <p>‘+’ is for positive, and ‘-’ is for negative.</p> <p>E represents the decimal point of the low alarm limit. Its value is from 0 to 5.</p> <p>IIII represents the 4-character hexadecimal number of low alarm limit.</p> <p>(cr) is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid parameter was entered. There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p>! is a delimiter character indicating a valid command was received.</p> <p>? is a delimiter character indicating the command was invalid.</p> <p>AA (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.</p> <p>(cr) is the terminating character, carriage return (0Dh).</p>  |

**@AAACSDHHHTEIII**

**Example**      command: @EFA0+20400+20100(cr)  
                  response: !EF(cr)

The command sets channel 0 of the analog input data logger at address EF as such:

high alarm limit = 10.24

low alarm limit = 2.56

The response indicates the command was received.

**@AABC**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Alarm Limit command   |
| <b>Description</b> | Request the alarm limits for the specified channel in the analog input data logger at address AA.  |
| <b>Syntax</b>      | <b>@AABC(cr)</b><br>@ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br><b>B</b> is the Read Alarm Limit command.<br><b>C</b> represents the channel index. Its value is from 0 to 7.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>!AASDHHHTEIII</b><br>! is a delimiter character indicating a valid command was received.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input data logger.<br><b>S</b> represents the sign of the high alarm limit.<br>‘+’ is for positive, and ‘-’ is for negative.<br><b>D</b> represents the decimal point of the high alarm limit. Its value is from 0 to 5.<br><b>HHHH</b> represents the 4-character hexadecimal number of high alarm limit.<br><b>T</b> represents the sign of the low alarm limit.<br>‘+’ is for positive, and ‘-’ is for negative.<br><b>E</b> represents the decimal point of the low alarm limit. Its value is from 0 to 5.<br><b>IIII</b> represents the 4-character hexadecimal number of low alarm limit.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |

### 5.3 Digital I/O, Alarm and Event Command Set

| Command Syntax | Command Name                      | Description   | I/O Module              |
|----------------|-----------------------------------|---|-------------------------|
| @AADI          | Read Digital I/O and Alarm Status | The addressed module returns the state of its digital input and digital output channels and the status of its alarm | 4011, 4011D, 4012, 4016 |
| @AADO(data)    | Set Digital Output Values         | Set the values of the module's digital outputs (ON or OFF)  | 4011, 4011D, 4012, 4016 |
| @AAEAT         | Enable Alarm                      | Enables the alarm in either Momentary or Latching mode  | 4011, 4011D, 4012, 4016 |
| @AAHI(data)    | Set High Alarm Value              | Downloads the High alarm limit value  | 4011, 4011D, 4012, 4016 |
| @AALO(data)    | Set Low Alarm Value               | Downloads the Low alarm limit value   | 4011, 4011D, 4012, 4016 |
| @AADA          | Disable Alarm                     | Disables all alarm functions  | 4011, 4011D, 4012, 4016 |
| @AACA          | Clear Latch Alarm                 | Resets the module's Latch alarm to zero   | 4011, 4011D, 4012, 4016 |
| @AARH          | Read High Alarm Value             | Ask the addressed module to return its high alarm value   | 4011, 4011D, 4012, 4016 |
| @AARL          | Read Low Alarm Value              | Ask the addressed module to return its low alarm value  | 4011, 4011D, 4012, 4016 |
| @AARE          | Read Event Counter                | Ask the addressed module to return its event counter value  | 4011, 4011D, 4012       |
| @AACE          | Clear Event Counter               | Reset the module's event counter to zero  | 4011, 4011D, 4012       |

**@AADI**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Digital I/O and Alarm State  |
| <b>Description</b> | The addressed analog input module is instructed to return the value of its digital input and output channels and the state of its alarm (Momentary or Latching).  |
| <b>Syntax</b>      | <p><b>@AADI(cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>DI</b> is the Read Digital I/O and Alarm Status command.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>ADAM-4011/4011D/4012:</b></p> <p><b>!AASOOI(cr)</b> if the command was valid</p> <p><b>ADAM-4016:</b></p> <p><b>!AASOO00(cr)</b> if the command was valid</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p>! delimiter character indicates a valid command was received.</p> <p><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.</p> <p><b>S</b> hexadecimal number that represents the alarm state (0h = disabled, 1h = MOMENTARY mode enabled, 2h = LATCH mode enabled).</p> <p><b>OO</b></p> <p><b>For ADAM-4011/4011D/4012:</b> it is a hexadecimal number representing the Digital Output port's channel 0 and 1 status (00h = D/O channels 0 and 1 are both OFF, 01h = channel 0 is ON, channel 1 is OFF, 02h = channel 0 is OFF, channel 1 is ON, 03h = channel 0 and 1 are both ON).</p> <p><b>For ADAM-4016:</b> it is a hexadecimal number representing the status of the four digital output channels. The corresponding table is shown in the following table:</p> |

**@AADI**

| Status Code | D00 | 001 | 002 | 003 |
|-------------|-----|-----|-----|-----|
| 00          | OFF | OFF | OFF | OFF |
| 01          | OFF | OFF | OFF | ON  |
| 02          | OFF | OFF | ON  | OFF |
| 03          | OFF | OFF | ON  | ON  |
| 04          | OFF | ON  | OFF | OFF |
| 05          | OFF | ON  | OFF | ON  |
| 06          | OFF | ON  | ON  | OFF |
| 07          | OFF | ON  | ON  | ON  |
| 08          | ON  | OFF | OFF | OFF |
| 09          | ON  | OFF | OFF | ON  |
| 0A          | ON  | OFF | ON  | OFF |
| 0B          | ON  | OFF | ON  | ON  |
| 0C          | ON  | ON  | OFF | OFF |
| 0D          | ON  | ON  | OFF | ON  |
| 0E          | ON  | ON  | ON  | OFF |
| 0F          | ON  | ON  | ON  | ON  |

**H** is a hexadecimal number representing the Digital input port's channel status (00h = Digital channel is Low, 01h = channel is High).

**(cr)** represents terminating character, carriage return (0Dh).

**Example code**

command: @15DI(cr)

response: !510001(cr)

The analog input module at address 15h is instructed to return digital I/O data and alarm status.

The module responds that both digital output channels are OFF, digital input is HIGH, and alarm state is Momentary.

**@AADO**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Digital Output command  |
| <b>Description</b> | Sets the values of the module's digital outputs (ON or OFF).  |
| <b>Syntax</b>      | <p><b>@AADO(data)(cr)</b><br/>@ is a delimiter character.<br/><b>AA</b> ( range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br/><b>DO</b> is the Set Digital Output command.<br/><b>(data)</b> is the two-character parameter that sets the state for the digital output bits of the module, as shown below:</p> <p><b>For ADAM-4011/4011D/4012:</b></p> <ul style="list-style-type: none"><li>00 all D/O bits are OFF</li><li>01 DO0 is ON, DO1 is OFF</li><li>02 DO0 is OFF, DO1 is ON</li><li>03 all bits are ON</li></ul> <p><b>For ADAM-4016:</b></p> <ul style="list-style-type: none"><li>00 DO0 and DO1 are OFF</li><li>01 DO0 is ON, DO1 is OFF</li><li>02 DO0 is OFF, DO1 is ON</li><li>03 DO0 and DO1 are ON</li><li>10 DO2 and DO3 are OFF</li><li>11 DO2 is ON, DO3 is OFF</li><li>12 DO2 is OFF, DO3 is ON</li><li>13 DO2 and DO3 are ON</li></ul> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.<br/><b>?AA(cr)</b> if an invalid parameter was entered.<br/>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br/><b>!</b> delimiter character indicates a valid command was received.<br/><b>?</b> delimiter character indicates the command was invalid.<br/><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.<br/><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>  |



**@AADO**

**Example** `co`      `mmand: @05D O01(cr)`  
`response: !0 5(cr)`

The analog input module at address 05h is instructed to set digital output channel 1 to ON and digital output channel 2 to OFF. The module confirms the settings.

**@AAEAT**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Enable Alarm command  |
| <b>Description</b> | The addressed analog input module is instructed to enable its alarm in either Latching or Momentary mode.   |
| <b>Syntax</b>      | <b>@AAEAT(cr)</b><br><b>@</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br><b>EA</b> is the Enable Alarm command.<br><b>T</b> indicates a alarm type and can have the value M = Momentary alarm state, or L = Latching alarm state.<br><b>(cr)</b> represents terminating character, carriage return (0Dh).                            |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @03EAL(cr)<br>response: !03(cr)<br>The analog input module at address 03h is instructed to enable its alarm in Latching mode.<br>The module confirms that the command has been received.   |

**NOTICE:** *An analog input module requires a maximum of 2 seconds after it received an Enable Alarm command to let the settings take effect. During this interval, the module can not be addressed to perform any other actions.*

**@AAHI**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set High Alarm Limit command  |
| <b>Description</b> | Downloads high alarm limit value into the addressed module.   |
| <b>Syntax</b>      | <p><b>@AAHI(data)(cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>HI</b> is the Set High Limit command.</p> <p><b>(data)</b> represents the value of the desired high limit setting. The format is always engineering units.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>                  |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p>! delimiter character indicates a valid command was received.</p> <p><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @04HI+080.00(cr)</p> <p>response: !04(cr)</p> <p>Presume the analog input module at address 04h is configured to accept T-type thermocouple input. The command will set the High alarm limit to 80°C.</p> <p>The module responds that the command has been received.</p>  |

**NOTICE:** *An analog input module requires a maximum of 2 seconds after it received an Set High Alarm command to let the settings take effect. During this interval, the module can not be addressed to perform any other actions.*

**@AALO**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Low Alarm Limit command   |
| <b>Description</b> | Downloads Low alarm limit value into the addressed module.  |
| <b>Syntax</b>      | <b>@AALO(data)(cr)</b><br>@ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br><b>LO</b> is the Set Low Limit command.<br><b>(data)</b> represents the value of the desired low limit setting. The format is always engineering units.<br><b>(cr)</b> represents terminating character, carriage return (0Dh).                               |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @04LO-020.00(cr)<br>response: !04(cr)<br>Presume the analog input module at address 04h is configured to accept T-type thermocouple input. The command will set the Low alarm limit to -20 °C.<br>The module responds that the command has been received.  |

**NOTICE:** *An analog input module requires a maximum of 2 seconds after it received an Set Low Alarm command to let the settings take effect. During this interval, the module can not be addressed to perform any other actions.*

**@AADA**

**Name** Disable Alarm command

**Description** Disables all alarm functions of the addressed analog input module.

**Syntax** **@AADA(cr)**  
**@** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of an analog input module.  
**DA** is the Disable Alarm command.  
**(cr)** represents terminating character, carriage return (0Dh).

**Response** **!AA(cr)** if the command was valid.  
 There is no response if the module detects a syntax error or communication error or if the specified address does not exist.

**!** delimiter character indicates a valid command was received.

**AA** represents the 2-character hexadecimal address of the responding analog input module.

**(cr)** represents terminating character, carriage return (0Dh).

**Example** command: @07DA(cr)  
 response: !07(cr)

The analog input module at address 07h is instructed to disable all alarm functions.

The module confirms its alarm functions have been disabled.

**NOTICE:** *An analog input module requires a maximum of 2 seconds after it received an Disable Alarm command to let the settings take effect. During this interval, the module can not be addressed to perform any other actions.*

## @AACA

|                    |  |
|--------------------|--|
| <b>Name</b>        | Clear Latch Alarm command  |
| <b>Description</b> | Both alarm states (High and Low) of the addressed analog input module are set to OFF, no alarm.  |
| <b>Syntax</b>      | <p><b>@AACA(cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>CA</b> is the Clear Latch Alarm command.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @05 CA(cr)</p> <p>response: !05(cr)</p> <p>The analog input module at address 05h is instructed to set both alarm states (High and Low) to OFF.</p> <p>The module confirms it has done so accordingly.</p>   |

**@AARH**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read High Alarm Limit command  |
| <b>Description</b> | The addressed module is asked to return its High alarm limit value.  |
| <b>Syntax</b>      | <p><b>@AARH(cr)</b><br/> <b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>RH</b> is the Read High Alarm Limit command.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command was valid.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.</p> <p><b>(data)</b> is the value of the High alarm limit in engineering units.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @07RH(cr)<br/> response: !07+2.0500(cr)</p> <p>Presume the analog input module at address 07h is configured to accept 5 V input. The command instructs the module to return its High alarm limit value. The module responds its High alarm limit value is 2.0500 V.</p>  |

---

**@AARL**

|                     |  |
|---------------------|--|
| <b>Name</b>         | Read Low Alarm Limit command   |
| <b>Description</b>  | The addressed module is asked to return its Low alarm limit value.   |
| <b>Syntax</b>       | <p><b>@AARL(cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>RL</b> is the Read Low Alarm Limit command.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>     | <p><b>!AA(data)(cr)</b> if the command was valid.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p>! delimiter character indicates a valid command was received.</p> <p><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.</p> <p><b>(data)</b> is the value of the Low alarm limit in engineering units.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example code</b> | <p>command: @05RL(cr)</p> <p>response: ! 05-0.3750(cr)</p> <p>Presume the analog input module at address 05h is configured to accept 1 V input. The command instructs the module to return its Low alarm limit value. The module responds its Low alarm limit value is -0.3750 V.</p>  |



**@AARE**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Event Counter command   |
| <b>Description</b> | The addressed module is instructed to return its event counter value.  |
| <b>Syntax</b>      | <p><b>@AARE(cr)</b></p> <p>@ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.</p> <p><b>RE</b> is the Reads Event Counter command.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command was valid.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p>! delimiter character indicates a valid command was received.</p> <p><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.</p> <p><b>(data)</b> represents the stored value, from '00000' to '65535' (The max value that can be held by the counter register is 65535). The number 65535 is held when the actual total counts exceed this number.</p> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @08RE(c r)</p> <p>response: !0832011(cr)</p> <p>The command instructs the module at address 08h to return its counter value. The module responds that its counter value equals 32011.</p>  |

---

**@AACE**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Clear Event Counter command   |
| <b>Description</b> | The addressed module is instructed to reset its event counter to zero.  |
| <b>Syntax</b>      | <b>@AACE(cr)</b><br>@ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog input module.<br><b>CE</b> is the Clear Event Counter command.<br><b>(cr)</b> represents terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>AA</b> represents the 2-character hexadecimal address of the responding analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @09CE(cr)<br>response: !09(cr)<br>The command instructs the module at address 09h to set its event counter to zero. The module responds that its counter has been reset.   |

## 5.4 Excitation Voltage Output Command Set

| Command Syntax | Command Name                          | Description  | I/O module |
|----------------|---------------------------------------|--|------------|
| \$AA6          | Get Excitation Voltage Output Value   | Returns either last value sent to specified module by \$AA7 command, or start-up output voltage. | 4016       |
| \$AA7          | Excitation Voltage Output             | Direct output excitation voltage data to a specified module                                      | 4016       |
| \$AAS          | Start-up Voltage Output Configuration | Stores a default value in a specified module. The output value will take effect upon startup.    | 4016       |
| \$AAE          | Trim Calibration                      | Trims specified module a number of units up/down   | 4016       |
| \$AAA          | Zero Calibration                      | Tells the module to store parameters for zero calibration  | 4016       |
| \$AAB          | Span Calibration                      | Tells the module to store parameters for span calibration  | 4016       |

---

**\$AA6**

|                          |  |
|--------------------------|--|
| <b>Name</b>              | Get Excitation Voltage Output Value command  |
| <b>Description</b>       | The addressed strain gauge input module is instructed to return the latest output value it received from Excitation Voltage Output command. If the module hasn't received an Excitation Voltage Output command since startup, it will return its Start-up Output value.  |
| <b>Syntax</b>            | <p><b>\$AA6(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.</p> <p><b>6</b> is the Get Excitation Voltage Output command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p>  |
| <b>Response</b>          | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.</p> <p><b>(data)</b> is the value that is returned by analog output channel. The format of the data is in engineering unit.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p> |
| <b>Example command:</b>  | <b>\$0A6(cr)</b>   |
| <b>Example response:</b> | <b>! 0A+03.000(cr)</b>   |
|                          | The command tells the strain gauge input module at address 0Ah to return the latest excitation voltage output value it received from an Excitation Voltage Output command. The strain gauge input module returns the value +03.000V.   |

**\$AA7**

**Name** Excitation Voltage Output command

**Description** Send a value to the analog output channel of the addressed strain gauge input module. Upon receipt, the analog output channel will output this value.

**Syntax** **\$AA7(data)(cr)**  
**\$** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.  
**7** is the Excitation Voltage Output command.  
**(data)** is the value that has to be output through the analog output channel. The data format is engineering unit and the range is between 0 ~ 10 V.  
**(cr)** is the terminating character, carriage return (0Dh)

**Response** **!AA(cr)** if the command is valid.  
**?AA(cr)** if a value was sent that is out of range.  
 There is no response if the module detects a syntax error or communication error or if the specified address does not exist.  
**!** delimiter character indicates a valid command was received.  
**?** delimiter character indicates the command was invalid.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.  
**(cr)** is the terminating character, carriage return (0Dh)

**Example command:** \$337+05.000(cr)  
**response:** !3 3(cr)

The command sends the value +05.000V to the analog output channel of the strain gauge input module at address 33h. The module responds that the command is valid. Its output data format is in engineering unit, the value is +05.000V.

---

## \$AAS

|                    |  |
|--------------------|--|
| <b>Name</b>        | Start-up Voltage Output Configuration command  |
| <b>Description</b> | Stores the present analog output value of the strain gauge input module with address AA in the module's non-volatile register. The output value will take effect upon start-up or after a brownout.  |
| <b>Syntax</b>      | <b>\$AAS(cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module whose analog output is to be set.<br>S is the Start-up Voltage Output Configuration command.<br>(cr) is the terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>!AA(cr)</b> if the command is valid.<br><b>?AA(cr)</b> if an invalid command was issued.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br>! delimiter character indicates a valid command was received.<br>? delimiter character indicates the command was invalid.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.<br>(cr) is the terminating character, carriage return (0Dh). |

**NOTICE:** *A strain gauge input module requires a maximum of 6 milliseconds after it received a Startup Voltage Output Configuration command to let the settings take effect. During this interval, the module can not be addressed to perform any other actions.*

**\$AAS**

**Example command:** \$0AS(cr)  
**response:** !0 A(cr)

Presume the present output value of the output channel of the strain gauge input module with address 0A is +05.000V. The command tells the module store the present output value, in its non-volatile memory. When the module is powered up or reset, its default output value will be +05.000V. The response of the strain gauge input module indicates that the command has been received.

**\$AAE**

**Name** Trim Calibration command

**Description** Trims the output voltage of the strain gauge input module a specified number of units up or down.

**Syntax** **\$AAE(number of counts)(cr)**  
**\$** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module to be calibrated.  
**E** is the Trim Calibration command.  
**(number of counts)** is the 2-character two's complement hexadecimal value that represents the number of counts by which to increase or decrease the output voltage. Each count equals approximately 1mV. Values range from 00 to 7F and from 80 to FF, where 00 represents 0 counts, 7F represents 127 counts, 80 represents -128 counts and FF represents -1 counts. Negative values decrease and positive values increase the output voltage according to the number of counts.  
**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AA(cr)** if the command is valid.  
 There is no response if the module detects a syntax error or communication error or if the specified address does not exist.  
**!** delimiter character indicates a valid command was received.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.  
**(cr)** is the terminating character, carriage return (0Dh).

**Example command:** \$07E14(cr)  
**response:** ! 07  
 The command tells the analog output of the strain gauge input module at address 07h to increase its output value by 20 (14h) counts which is approximately 20 mV. The strain gauge input module confirms the increase. In order to perform this trim calibration, a voltmeter should be connected to the module's output. (See also the zero calibration command and span calibration command of the strain gauge input module and Chapter 8, Calibration, for a detailed description.)



**\$AAA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Zero Calibration command  |
| <b>Description</b> | Stores the voltage output value of the addressed strain gauge input module as zero voltage reference.   |
| <b>Syntax</b>      | <p><b>\$AAA(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module whose output channel is to be calibrated.</p> <p><b>A</b> is the Zero Calibration command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |

Before issuing the Zero Calibration command, the analog output should be trimmed to the correct value with the Trim Calibration command. A voltmeter should be connected to the module's output channel. (See also the strain gauge input module's Trim Calibration command and Chapter 8, Calibration, for a detailed description.)

---

## \$AAB

|                    |   |
|--------------------|---|
| <b>Name</b>        | Span Calibration command  |
| <b>Description</b> | Stores the voltage output value of the addressed strain gauge input module as 10V reference.  |
| <b>Syntax</b>      | <p><b>\$AAB(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module whose output channel is to be calibrated.</p> <p><b>B</b> is the Span Calibration command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates a valid command was received.</p> <p><b>?</b> delimiter character indicates the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the strain gauge input module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> <p>Before issuing the Span Calibration command, the analog output should be trimmed to the correct value with the Trim Calibration command. A voltmeter should be connected to the module's output channel. (See also the strain gauge input module's Trim Calibration command and Chapter 8, Calibration, for a detailed description.)</p> |

# Analog Output Module Command Set

# 6

## 6.1 Analog Output Module Command for ADAM-4021

| Command Syntax              | Command Name                                     | Description   | I/O Module |
|-----------------------------|--|---|------------|
| %AANNTTCFF                  | Configuration                                    | Sets the address, output range, baud rate, data format, slew rate and/or checksum status              | 4021       |
| #AA(data)                   | Analog Data Out                                  | Directs output data to a specified module   | 4021       |
| \$AA4                       | Start-Up Output Current or Voltage Configuration | Stores a default output value in a specified module. The output value will take effect upon startup   | 4021       |
| \$AA3<br>(number of counts) | Trim Calibration                                 | Trims specified module a number of units up/down  | 4021       |
| \$AA0                       | 4 mA Calibration                                 | Tells the module to store parameters for 4mA Calibration  | 4021       |
| \$AA1                       | 20 mA Calibration                                | Tells the module to store parameters for 20 mA Calibration  | 4021       |
| \$AA2                       | Configuration Status                             | Reads the configuration of specified module   | 4021       |
| \$AA6                       | Last Value Readback                              | Returns either last value sent to specified module by #AA command, or start-up output current/voltage | 4021       |
| \$AA8                       | Current Readback                                 | Returns measured value of the current/voltage flowing through current loop                            | 4021       |
| \$AA5                       | Reset Status                                     | Checks if module has been reset since the last \$AA5 command  | 4021       |
| \$AAF                       | Read Firmware Version                            | Returns the firmware version code from the specified analog output module                             | 4021       |
| \$AAM                       | Read Model Name                                  | Return the module name from specified analog output module  | 4021       |

**%AANNTCCFF**

- Name** Configuration command
- Description** Sets address, input range, baud rate, data format, checksum status, and/or integration time for an analog output module.
- Syntax** **%AANNTCCFF(cr)**  
**%** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address that is to be configured.  
**NN** represents the new hexadecimal address of the analog output module. Range is from 00h to FFh.  
**TT** represents the type codes (output range codes).  
(See Table 6-2 on next page)  
**CC** represents the baud rate codes.  
(See Table 6-1 on next page)  
**FF** is a hexadecimal number that equals to 8-bit parameter representing the status of data format, slew rate, and checksum. The layout of the 8-bit parameter is shown in Figure 6-1. Bit 7 is not used and must be set to 0.  
**(cr)** is the terminating character, carriage return (0Dh).




Figure 6-1 *Data format for FF (8-bit parameter)*

**Note:** Only ADAM-4021 supports “% of FSR” and “two’s complement of hexadecimal” Data Format.

**%AANNTTCFF**

**Response**      **!AA(cr)** if the command is valid.  
**?AA(cr)** if an invalid parameter was entered or the INIT\* terminal was not grounded when changing baud rate or checksum settings was attempted.  
 There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.  
**!** delimiter character indicates that a valid command is received.  
**?** delimiter character indicates that the command is invalid.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of an analog output module.  
**(cr)** is the terminating character, carriage return (0Dh).

**Table 6-1 Baud Rate Codes**

| Baud Rate Code (Hex) | Baud Rate |
|----------------------|-----------|
| 03                   | 1200 bps  |
| 04                   | 2400 bps  |
| 05                   | 4800 bps  |
| 06                   | 9600 bps  |
| 07                   | 19.2 Kbps |
| 08                   | 38.4 Kbps |

**Table 6-2 Output Range Codes (Type Codes)**

| Output Range Code (Hex) | Output Range for ADAM-4021 |
|-------------------------|----------------------------|
| 30                      | 0 to 20 mA                 |
| 31                      | 4 to 20 mA                 |
| 32                      | 0 to 10 V                  |

**NOTICE:** *An analog output module requires a maximum of 20 milliseconds to perform auto calibration and ranging after it is reconfigured. During this time span, the module can not be addressed to perform any other actions.*

**NOTICE:** *All configuration parameters can be changed dynamically, except the checksum and baud rate parameters. They can only be altered when the INIT\* terminal is grounded. (Refer to Baud rate and Checksum in Chapter 2).*

**%AANNTTCFF**

**Example**      command: %310A310610(cr)  
                  response: !24(cr)

The analog input module is configured from addresses 31h to a new address 0Ah, output range 4 to 20 mA, baud rate 9600, engineering units data format, a slew rate of 1.0 mA/sec and no checksum checking.

The response indicates that the command has been received.

**#AA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Analog Data Out command   |
| <b>Description</b> | Send a value to the address of analog output module. Then, the analog output module will output this value.   |
| <b>Syntax</b>      | <p><b>#AA(data)(cr)</b></p> <p># is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog output module.</p> <p><b>(data)</b> is the value that has to be outputted through the analog output module. The Range and value depend on the module's configured data format. The possible formats are engineering units or % of FSR or hexadecimal. (Please refer to Appendix B, Data Formats and I/O Ranges.)</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>&gt;(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if the sent value was out of range. Note that when the analog output module receives such a value, it will try to use a value which is close to the one received and within the module's configured range.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>&gt;</b> is a delimiter character.</p> <p><b>?</b> delimiter character indicates that the command is invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog output module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |



**#AA****Example**

command: #3315.000(cr)

response: &gt;(cr)

The command sends the value 15 mA, which is converted to engineering units, to the address 33h of the analog output module. The analog output module responds with an output value of 15 mA which represents a valid command.

command: #0A+030.00(cr)

response: &gt;(cr)

The module is configured for an output range of 4 to 20 mA and a percent of span data format. The command sends the value 8.8 mA ( $4 \text{ mA} + 0.30 \times 16 \text{ mA} = 8.8 \text{ mA}$ ) which is 30% of the span to the address 0Ah of analog output module. The analog output module responds with an output value of 8.8 mA which represents a valid command.

command: #1B7FF(cr)

response: &gt;(cr)

The command sends the hexadecimal value 7FF to the analog output module at address 1Bh. The module is configured to a 0 to 20 mA output range and a hexadecimal data format. It will output with a value of 10 mA ( $((7FFH/FFFH) \times 20 \text{ mA} = 10 \text{ mA})$ ).

**\$AA4**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Start-up Voltage/Current Output Configuration command  |
| <b>Description</b> | Stores the present output value of an analog output module at address AA in the module's non-volatile register. The output value will take effect at start-up or after a brownout.   |
| <b>Syntax</b>      | <p><b>\$AA4(cr)</b></p> <p>\$ is a delimiter character.</p> <p>AA (range 00-FF) represents the 2-character hexadecimal address of the analog output module whose output current is to be set.</p> <p>4 is the Start-up Output Current Configuration command.</p> <p>(cr) is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p>! delimiter character indicates that a valid command was received.</p> <p>? delimiter character indicates that the command was invalid.</p> <p>AA (range 00-FF) represents the 2-character hexadecimal address of the analog output module.</p> <p>(cr) is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$0A4(cr)</p> <p>response: !0A(cr)</p> <p>Presume the present output value of the analog output module at address 0A is 9.4 mA. The command tells the analog output module to store the present output value into non-volatile memory. When the module is at start-up or reset, its default output value will be 9.4mA. The response of the analog output module indicates that the command has been received.</p>   |

***NOTICE: An analog output module requires a maximum of 6 milli-seconds after it received a Startup Voltage/Current Output Configuration command to let the settings take effect . During this interval, the module can not be addressed to perform any other actions.***

**\$AA3**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Trim Calibration command   |
| <b>Description</b> | Trim the address of analog output module for a specific number of units up or down.  |
| <b>Syntax</b>      | <p><b>\$AA3(number of counts)(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address which is to be calibrated.</p> <p><b>3</b> is the Trim Calibration Command.</p> <p><b>(number of counts)</b> is the 2-character two's complement hexadecimal value that represents the number of counts increasing or decreasing the output current. Each count equals to approximately 1.5 <math>\mu</math>A. Values range from 00 to 5F and A1 to FF (hexadecimal). The 00 represents 0 counts, 5F represents +95 counts, A1 represents -95 counts and FF represents -1 count. Negative values decrease the output current according to the number of counts. On the other hand, the positive values do the opposite.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates that a valid command was received</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog output module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |

**\$AA3****Example**

command: \$07314(cr)

response: !07(cr)

The command tells the analog output module at address 07h to increase its output value by 20 (14h) counts which are approximately 30  $\mu$ A.

The analog output module confirms the increase.

In order to perform this trim calibration, a millimeter or a resistor and voltmeter should be connected to the module's output. (Please see the 4 mA Calibration command and 20 mA Calibration command of the analog output module's command set. Please also refer to Chapter 8, Calibration for a detailed description.)

**\$AA0**

|                    |  |
|--------------------|--|
| <b>Name</b>        | 4 mA Calibration command   |
| <b>Description</b> | Stores the current output value 4 mA for reference in the specified address in analog output module.   |
| <b>Syntax</b>      | <p><b>\$AA0(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address whose data are to be sent.</p> <p><b>0</b> is the 4 mA Calibration command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates that a valid command was received.</p> <p><b>?</b> delimiter character indicates that the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the responding 2-character hexadecimal address of the analog output module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |

Before issuing the 4 mA Calibration command, the analog output module should be trimmed to the correct value with the Trim Calibration command. A millimeter or a resistor and voltmeter should be connected to the module's output. (Please refer to the analog output module's Trim Calibration command and Chapter 8, Calibration, for a detailed description.)

**\$AA1**

|                    |  |
|--------------------|--|
| <b>Name</b>        | 20 mA Calibration command  |
| <b>Description</b> | Stores the current output value of the addressed analog output module as 20 mA reference.  |
| <b>Syntax</b>      | <b>\$AA1(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address whose data are to be sent.<br><b>1</b> is the 20 mA Calibration command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid command was issued.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> delimiter character indicates that a valid command was received.<br><b>?</b> delimiter character indicates that the command was invalid.<br><b>AA</b> (range 00-FF) represents the responding 2-character hexadecimal address of the analog output module.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).<br><br>Before issuing the 20 mA Calibration command, the analog output module should be trimmed to the correct value with the Trim Calibration command. A millimeter or a resistor and voltmeter should be connected to the module's output. (Please refer to the analog output module's Trim Calibration command and Chapter 8, Calibration, for a detailed description.) |

**\$AA2**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Configuration Status command   |
| <b>Description</b> | Instruct the analog output module to return its configuration data.   |
| <b>Syntax</b>      | <p><b>\$AA2(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address for status reading.</p> <p><b>2</b> is the Read Configuration Status command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AATTCCFF(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates that a valid command was received.</p> <p><b>?</b> delimiter character indicates that the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog output module.</p> <p><b>TT</b> represents the type of code, which determines the output range.</p> <p><b>CC</b> represents the baud rate code.</p> <p><b>FF</b> is a hexadecimal number that equals to 8-bit parameter representing the data format, slew rate, and checksum status.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p> <p>Please refer to %AANNTTCCFF Configuration command (Page 6-3 and 6-4) for TT, CC and FF parameter definition.</p> |
| <b>Example</b>     | <p>command: \$452(cr)</p> <p>response: !45300614(cr)</p> <p>The command asks the analog output module at address 45h to send its configuration data.</p> <p>The analog output module at address 45h responds with output range 0 to 20 mA, baud rate 9600, engineering units as the currently configured data format, slew rate 2 mA per second, and no checksum checking.</p>  |

**\$AA6**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Last Value Readback command  |
| <b>Description</b> | The analog output module is instructed to return the latest output value that it has received from the Analog Data Out command. If the module hasn't received any Analog Data Out commands since startup, it will return to its Start-up Output value.   |
| <b>Syntax</b>      | <p><b>\$AA6(cr)</b></p> <p>\$ is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address whose value you want to return.</p> <p><b>6</b> is the Last Value Readback command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates that a valid command was received.</p> <p><b>?</b> delimiter character indicates that the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog output module.</p> <p><b>(data)</b> is the value that is returned by the analog output module. The format of the data depends on the module's configured data format.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$0A6(cr)</p> <p>response: !0A03.000(cr)</p> <p>The command requests the analog output module at address 0Ah to return the last output value that it has received from an Analog Out command.</p> <p>The analog output module returns the value 3.000 mA.</p>  |



**\$AA8**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Current Readback command  |
| <b>Description</b> | The addressed analog output module is instructed to measure the current flowing through its current/voltage loop and return the measured data in the module's configured data format. The value returned may be a rough estimate of the real value.   |
| <b>Syntax</b>      | <p><b>\$AA8(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog output module that you want to retrieve the data from. The data are current/voltage loop.</p> <p><b>8</b> is the Current feedback command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates that a valid command was received.</p> <p><b>?</b> delimiter character indicates that the command was invalid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog output module.</p> <p><b>(data)</b> is the value returned by the analog output module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$0A8(cr)</p> <p>response: !0A18.773(cr)</p> <p>The command tells the analog output module at address 0Ah to measure its current loop and return the measured value.</p> <p>The analog output module returns the value 18.773 mA.</p>   |

**\$AA5**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Reset Status command  |
| <b>Description</b> | Checks the Reset Status of the analog output module to see whether it has been reset since the last Reset Status command was issued.  |
| <b>Syntax</b>      | <p><b>\$AA5(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog output module who's Reset Status is to be returned.</p> <p><b>5</b> is the Reset Status command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AAS(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid command was issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> delimiter character indicates that a valid command was received.</p> <p><b>?</b> delimiter character indicates that the command was valid.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog output module.</p> <p><b>S</b> represents the Status bit which is returned by the analog output module. If S=1, the module is in reset mode since a Reset Status command had been issued already. If S=0, the module has not been reset since the last Reset Status command was not issued.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$395(cr)</p> <p>response: !391(cr)</p> <p>The analog output module at address 39h was reset or powered up after the last execution of the Reset Status command. When the command is executed once more, the analog output module will reply with !390(cr)</p>  |

**\$AAF**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Firmware Version command  |
| <b>Description</b> | The command requests the analog output module at address AA to return the version code of its firmware.  |
| <b>Syntax</b>      | <b>\$AAF (cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you want to access.<br><b>F</b> is the Read Firmware Version command.<br><b>(cr)</b> is the terminating character, carriage return (ODh).   |
| <b>Response</b>    | <b>!AA(Version)(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or if the specified address does not exist.<br><b>!</b> is a delimiter character indicating that a valid command was received.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog output module.<br><b>(Version)</b> is the version code of the module's firmware at address AA.<br><b>(cr)</b> is the terminating character, carriage return (ODh). |

**\$AAM**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Module Name  |
| <b>Description</b> | The command requests the analog output module at address AA to return its name  |
| <b>Syntax</b>      | <b>\$AAM (cr)</b><br><b>\$</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you want to access.<br><b>M</b> is the Read Module Name command.<br><b>(cr)</b> is the terminating character, carriage return (ODh)   |
| <b>Response</b>    | <b>!AA(Module Name)(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character indicating that a valid command was received.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of an analog output module.<br><b>(Module Name)</b> is the name of the module at address AA.<br>For example, 4021<br><b>(cr)</b> is the terminating character, carriage return (ODh). |

## 6.2 Analog Output Module Command for ADAM-4024

## ADAM-4024 Command Review:

| Command Set  | Function  | Response      | Example   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
|--------------|---|---------------|---|----|----------|----|----------|----|----------|----|-----------|----|-----------|----|-----------|----|------------|--|---------|---------|----|-------------|-------------|----|--------------|--------------|----|-------------|-------------|----|------------|------------|----|-----------|------------|----|-----------|------------|----|-----------|------------|----|-----------|------------|----|-----------|-------------|----|------------|-------------|----|------------|-------------|----|------------|--------------|-----|-------------|
| %AANNTCCFF   | Module Configuration : Set Address, Baud Rate, Check Sum<br><br><b>AA</b> : Current Module Address<br><b>NN</b> : New Module Address<br><b>TT</b> : Not Used For ADAM-4024 (Must Be 00)<br><b>CC</b> : Baud Rate Index<br><table border="1"> <tr><td>03</td><td>1200 bps</td></tr> <tr><td>04</td><td>2400 bps</td></tr> <tr><td>05</td><td>4800 bps</td></tr> <tr><td>06</td><td>9600 bps</td></tr> <tr><td>07</td><td>19200 bps</td></tr> <tr><td>08</td><td>38400 bps</td></tr> <tr><td>09</td><td>57600 bps</td></tr> <tr><td>0A</td><td>115200 bps</td></tr> </table> <b>FF</b> : Control the parameter listed below<br>Bit 7: Reserved<br>Bit 6: Check Sum: 0-Disable 1-Enable<br>Bit 5 – 2 : Slew Rate (see table below)<br>Bit 1 – 0 : Reserved<br>Slew Rate:<br><table border="1"> <thead> <tr> <th></th> <th>Voltage</th> <th>Current</th> </tr> </thead> <tbody> <tr><td>00</td><td>immediately</td><td>immediately</td></tr> <tr><td>01</td><td>0.0625 V/sec</td><td>0.125 mA/sec</td></tr> <tr><td>02</td><td>0.125 V/sec</td><td>0.25 mA/sec</td></tr> <tr><td>03</td><td>0.25 V/sec</td><td>0.5 mA/sec</td></tr> <tr><td>04</td><td>0.5 V/sec</td><td>1.0 mA/sec</td></tr> <tr><td>05</td><td>1.0 V/sec</td><td>2.0 mA/sec</td></tr> <tr><td>06</td><td>2.0 V/sec</td><td>4.0 mA/sec</td></tr> <tr><td>07</td><td>4.0 V/sec</td><td>8.0 mA/sec</td></tr> <tr><td>08</td><td>8.0 V/sec</td><td>16.0 mA/sec</td></tr> <tr><td>09</td><td>16.0 V/sec</td><td>32.0 mA/sec</td></tr> <tr><td>0A</td><td>32.0 V/sec</td><td>64.0 mA/sec</td></tr> <tr><td>0B</td><td>64.0 V/sec</td><td>128.0 mA/sec</td></tr> </tbody> </table> | 03            | 1200 bps  | 04 | 2400 bps | 05 | 4800 bps | 06 | 9600 bps | 07 | 19200 bps | 08 | 38400 bps | 09 | 57600 bps | 0A | 115200 bps |  | Voltage | Current | 00 | immediately | immediately | 01 | 0.0625 V/sec | 0.125 mA/sec | 02 | 0.125 V/sec | 0.25 mA/sec | 03 | 0.25 V/sec | 0.5 mA/sec | 04 | 0.5 V/sec | 1.0 mA/sec | 05 | 1.0 V/sec | 2.0 mA/sec | 06 | 2.0 V/sec | 4.0 mA/sec | 07 | 4.0 V/sec | 8.0 mA/sec | 08 | 8.0 V/sec | 16.0 mA/sec | 09 | 16.0 V/sec | 32.0 mA/sec | 0A | 32.0 V/sec | 64.0 mA/sec | 0B | 64.0 V/sec | 128.0 mA/sec | !AA | %0203000600 |
| 03           | 1200 bps  |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 04           | 2400 bps  |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 05           | 4800 bps  |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 06           | 9600 bps  |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 07           | 19200 bps   |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 08           | 38400 bps   |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 09           | 57600 bps   |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 0A           | 115200 bps  |               |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
|              | Voltage   | Current       |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 00           | immediately   | immediately   |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 01           | 0.0625 V/sec  | 0.125 mA/sec  |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 02           | 0.125 V/sec   | 0.25 mA/sec   |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 03           | 0.25 V/sec  | 0.5 mA/sec    |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 04           | 0.5 V/sec   | 1.0 mA/sec    |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 05           | 1.0 V/sec   | 2.0 mA/sec    |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 06           | 2.0 V/sec   | 4.0 mA/sec    |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 07           | 4.0 V/sec   | 8.0 mA/sec    |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 08           | 8.0 V/sec   | 16.0 mA/sec   |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 09           | 16.0 V/sec  | 32.0 mA/sec   |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 0A           | 32.0 V/sec  | 64.0 mA/sec   |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| 0B           | 64.0 V/sec  | 128.0 mA/sec  |   |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| #AACn(data)  | Direct Output CHn Data  | !AACn (data)  | #02C2+07.456<br>#02C1-03.454<br>#02C0+11.234    |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |
| #AASCn(data) | Set data As CHn Start Up Data   | !AASCn (data) | #02SC2+07.456<br>#02SC1-03.454<br>#02SC0+11.234 |    |          |    |          |    |          |    |           |    |           |    |           |    |            |  |         |         |    |             |             |    |              |              |    |             |             |    |            |            |    |           |            |    |           |            |    |           |            |    |           |            |    |           |             |    |            |             |    |            |             |    |            |              |     |             |

**ADAM-4024 Command Review: (Continued)**

| Command Set  | Function  | Response      | Exam ple   |
|--------------|---|---------------|--|
| #AAECn(data) | Set data As CHn Emergency Stop Data   | !AAECn (data) | #02EC2 +07.456<br>#02EC1 -03.454<br>#02EC0 +11.234 |
| ##           | Synchronous Sample IDI  | No Response   | ##   |
| \$AA0Cn      | Set Current Trim Data As CHn 4m A Calibration Parameter/EEPROM  | !AA           | \$020C2  |
| \$AA1Cn      | Set Current Trim Data As CHn 20m A Calibration Parameter/EPROM  | !AA           | \$021C2  |
| \$AA2        | Read Back Module Status   | !AATTCFF      | \$022  |
| \$AA3Cn(m)   | Set Trim Data For CHn<br>m :0 ~ 127<br>And If Negative Then Add 0x80 (m =xx )<br>Ex.m=89 → -9 m=09 → +9   | !AA           | \$02308  |
| \$AA4        | Read Back The IDI Input By Synchronous Command (##)   | !AAx          | \$024  |
| \$AA5        | Checks the Reset Status of the analog output module to see whether it has been reset since the last Reset Status command was issued.  | !AAS          | \$025  |
| \$AA6Cn      | Read Back CHn Last Output Value   | !AA(data)     | \$026C2  |
| \$AA7CnRxx   | Set CHn Output Type<br><b>AA</b> : Current Module Address<br><b>Cn</b> : Channel<br><b>C</b> : Prefix Command String<br>n = 0,1,2,3<br><b>Rxx</b> : Output Type (Range)<br><b>R</b> : Prefix Command String<br>xx = 32    -10 V ~ +10 V<br>xx = 30    0 ~ 20 mA<br>xx = 31    4 ~ 20 mA | !AA           | \$027C2R32   |

### ADAM-4024 Command Review: (Continued)

| Command Set | Function   | Response         | Example              |
|-------------|--|------------------|----------------------|
| \$AA8Cn     | Read Back CHn Output Range   | !AACnxx          | \$027C2              |
| \$AAACnZ    | Enable/Disable (Z=1/0) CHn EMS Flag  | !AA              | \$02AC21<br>\$02AC20 |
| \$AABCn     | Read CHn EMS Flag  | !AACn1<br>!AACn0 | \$02BC2              |
| \$AADCn     | Read Back CHn StartUp Data   | !AA(data)        | \$02DC2              |
| \$AAECn     | Read Back CHn Emergency Stop Data  | !AA(data)        | \$02EC2              |
| \$AAF       | Read Firmware Version  | !AAAx.xx         | \$02F                |
| \$AAG       | Reset Current Trim Data Variable To 0  | !AA              | \$02G                |
| \$AAH       | Read Current Trim Data Variable  | !AAxx (xx=m)     | \$02H                |
| \$AAI       | Read IDI   | !AAx             | \$02I                |
| \$AAM       | Read Module Name   | !AA4024          | \$02M                |
| \$AANCn     | Read Back CHn 4mA Calibration Parameter  | !AAxx            | \$02NC2              |
| \$AAOCn     | Read Back CHn 20mA Calibration Parameter   | !AAxx            | \$02OC2              |
| \$AAPCn     | Clear CHn 4mA Calibration Parameter / EEPROM   | !AA              | \$02PC2              |
| \$AAQCn     | Clear CHn 20mA Calibration Parameter / EEPROM  | !AA              | \$02QC2              |
| \$AAX0nnn   | This command set the communication watchdog timer (WDT) cycle time.<br><b>AA</b> : (range 00-FF) 2-character hexadecimal address of the analog input module which is to be read.<br><b>X0</b> : the setting WDT command.<br><b>Nnnn</b> : (range 0000-9999) the specified value of communication cycle you want to set. (Unit: 0.1 second) | !AA              | \$02X01234           |
| \$AAX1      | Read Communication Watchdog Timer Cycle Setting.<br><b>AA</b> : (range 00-FF) 2-character hexadecimal address of the analog input module which is to be read.<br><b>X1</b> : the reading WDT cycle command.  | !AA              | \$02X1               |

Digital I/O, Relay output and  
Counter/Frequency Command Set

7



## 7.1 Digital I/O and Relay Output Module Command

| Command Syntax | Description  | I/O Module  |
|----------------|--|---|
| %AANNTTCCFF    | Sets the address, input range, baud rate, and/or checksum status to a digital I/O module                           | 4050, 4051, 4052, 4053, 4055, 4056S, 4056SO, 4060, 4068, 4069 |
| \$AA6          | Returns the values of digital I/O channels of the addressed module   | 4050, 4051, 4052, 4053, 4055, 4056S, 4056SO, 4060, 4068, 4069 |
| #AAB(data)     | Writes specified values to either a single channel or all channels simultaneously                                  | 4050, 4055, 4056S, 4056SO, 4060, 4068, 4069,                  |
| ##             | Orders all digital I/O modules to sample their input values and store them in a special register                   | 4050, 4051, 4052, 4053, 4055, 4060, 4068                      |
| \$AA4          | Returns the value that was stored in the specified digital I/O module that was stored after an ## command          | 4050, 4051, 4052, 4053, 4055, 4060, 4068                      |
| \$AA2          | Returns the configuration parameters for the specified digital I/O module  | 4050, 4051, 4052, 4053, 4055, 4056S, 4056SO, 4060, 4068, 4069 |
| \$AA5          | Indicates whether a specified digital I/O module was reset after the last time the \$AA5 command was issued        | 4050, 4051, 4052, 4053, 4055, 4056S, 4056SO, 4060, 4068, 4069 |
| \$AAF          | Return firmware version code from the specified digital I/O module   | 4050, 4051, 4052, 4053, 4055, 4056S, 4056SO, 4060, 4068, 4069 |
| \$AAM          | Return the module name from the specified digital I/O module   | 4050, 4051, 4052, 4053, 4055, 4056S, 4056SO, 4060, 4068, 4069 |
| @AA            | Returns the values of the digital I/O channel in the addressed module. This command is the same with \$AA6 command | 4056S, 4056SO   |
| \$AAX0TTTTDDDD | Force the DO channels to safety status when communication is time-out and over pre-defined period.                 | 4055, 4056SO, 4056SO, 4060, 4068, 4069                        |
| \$AAX1         | Read the time-out setting and pre-defined safety status of DO channels.  | 4055, 4056SO, 4056SO, 4060, 4068, 4069                        |


(Continued on next page)

---

| Command Syntax | Description   | I/O Module                      |
|----------------|---|---------------------------------|
| \$AAX2         | Requests the Safty Flag of the addressed digital I/O module to see whether the safety value has been executed since Write Safety Value command was set. | 4055, 4056S, 4056SO, 4060, 4068 |
| \$AAE0         | Read the Over Current Status Flag and Clear the Flag simultaneously   | 4056SO                          |
| \$AAP          | The command requests the module at address AA to return the low power status of module  | 4069                            |
| \$AAS          | The command requests the module at address AA to set and return the low power mode of module  | 4069                            |

## %AANTTCCFF

- Name** Configuration command
- Description** Configure address, baud rate and/or checksum status of the digital I/O module.
- Syntax** **%AANTTCCFF(cr)**  
**%** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address which is to be configured.  
**NN** represents the new hexadecimal address ranging from 00h to FFh of the digital I/O module.  
**TT** represents the type of code that is always set to 40 for a digital I/O module.  
**CC** represents the baud rate code.  
(Refer to Table 7-1 on next page)  
**FF** is a hexadecimal number that equals to a 8-bit parameter that represents the checksum and protocol status.  
Bits 3 through 5 and bit 0, 1, 7 are not used and are being set to 0. (Refer to Figure 7-1 below)  
Bit 6 is the selection of checksum and bit 2 is the selection of protocol. (0: advantech; 1: modbus). (Modbus protocol is supported by ADAM-4052, 4051, 4055, 4056S, 4056SO, 4068 only)  
**(cr)** is the terminating character, carriage return (0Dh).



**Figure 7-1 Data format for FF (8-bit parameter)**

## %AANNTTCFF

**Response**      **!AA (cr)** if the command is valid.  
                  **?AA(cr)** if an invalid parameter was entered or the INIT\* terminal was not grounded when changing baud rate or checksum settings were attempted.

There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.

**!** is a delimiter character which indicates a received valid command.

**?** is a delimiter character which indicates an invalid command.

**AA** (range 00-FF) represents the 2-character hexadecimal address of a digital I/O module.

**(cr)** is the terminating character, carriage return (0Dh).

**Example**      command: %2324400600(cr)  
                  response: !24(cr)

The command tries to configure module by changing address 23h to address 24h, assigning baud rate 9600, setting no checksum checking and supporting Advantech protocol. The response indicates that the configuration was successful.

**Table 7-1 Baud Rate Codes**

| Baud Rate Code (Hex) | Baud Rate  |
|----------------------|------------|
| 03                   | 1200 bps   |
| 04                   | 2400 bps   |
| 05                   | 4800 bps   |
| 06                   | 9600 bps   |
| 07                   | 19.2 kbps  |
| 08                   | 38.4 kbps  |
| 09                   | 57.6 kbps  |
| 0A                   | 115.2 kbps |

**NOTICE:** *All configuration parameters can be changed dynamically, except checksum and baud rate parameters. They can only be altered when the INIT\* terminal is grounded. (Please Refer to Baud rate and Checksum, in Chapter 2 for the correct procedure.)*

## **\$AA6**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Digital Data In command  |
| <b>Description</b> | This command requests the specified (AA) module to return the status of its digital input channels and feedback value from its digital output channels.  |
| <b>Syntax</b>      | <p><b>\$AA6(cr)</b><br/>\$ is a delimiter character.<br/>AA (range 00-FF) represents the 2-character hexadecimal address of the module.<br/>6 is the Digital Data In command.<br/>(cr) is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!(dataOutput)(dataInput)00(cr)</b><br/>if the command was valid. (ADAM-4050)</p> <p><b>!(dataInput)00(cr)</b><br/>if the command was valid. (ADAM-4051)</p> <p><b>!(dataInput)0000(cr)</b><br/>if the command was valid. (ADAM-4052)</p> <p><b>!(dataInput)(dataInput) 00 (cr)</b><br/>if the command was valid. (ADAM-4053)</p> <p><b>!(dataOutput)(dataInput)00(cr)</b><br/>if the command was valid. (ADAM-4055)</p> <p><b>!(dataOutput)00(cr)</b><br/>if the command was valid. (ADAM-4056S/4056SO)</p> <p><b>!(dataOutput)0000(cr)</b><br/>if the command was valid. (ADAM-4060/4068)</p> <p><b>?AA(cr)</b> if an invalid command has been issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p>! delimiter character indicates that a valid command was received. ? delimiter character indicates that the command was invalid.</p> <p>AA (range 00-FF) represents the responding 2-character hexadecimal address of the module.</p> <p>(dataOutput) two-character hexadecimal value which is either the feedback of a digital output channel or a relay. For ADAM-4056S and ADAM-4056SO, it is four-character hexadecimal for representing 12 channel digital output.</p> |

**\$AA6**

**(dataInput)** two-character hexadecimal value representing the input values of the digital I/O module.

**(cr)** is the terminating character, carriage return (0Dh).

**Example**

command: \$336(cr)

response: !112200(cr)

This example is for ADAM-4050. The first two characters, 11h (00010001), of the response indicates that digital output channels 0 and 4 are ON and channels 1, 2, 3, 5, 6, 7 are OFF. The second two characters of the response, 22h (00100010), indicates that digital input channels 1 and 5 are HIGH and channels 0, 2, 3, 4, 6, 7 are LOW.

command: \$036(cr)

response: !BEDE00(cr)

This example is for ADAM-4053. The first two characters, BEh (10111110), of the response indicates that digital input channels 8 and 14 are LOW and channels 9, 10, 11, 12, 13 and 15 are HIGH. The second two characters, DEh (11011110), of the response indicates that digital input channels 0 and 5 are LOW and channels 1, 2, 3, 4, 6, 7 are HIGH.

command: \$056(cr)

response: !017A00(cr)

This example is for ADAM-4056S or ADAM-4056SO. The first character of the response is always 0. The next three characters, 17A (000101111010), are the status of 12 channel digital outputs. The detail status is as below.

|                                  |    |    |   |   |   |   |   |   |   |   |   |   |
|----------------------------------|----|----|---|---|---|---|---|---|---|---|---|---|
| Digital value                    | 0  | 0  | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 0 | 1 | 0 |
| ADAM-4056S/4056SO<br>Channel no. | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |

## #AABB

**Name** Digital Data Out command

**Description** The command either sets a single digital output channel or sets all digital output channels simultaneously.

**Syntax** **#AABB(data)(cr)**

# is a delimiter character.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the output value.

**BB** is used to indicate whether all channels will be set or a single channel will be set. In the last case, BB will also indicate which channel it is. Writing data (a byte) to all channels should make both characters to be zero (BB=00). Writing data (a bit) to a single channel, however, will make the first character 1 and the second character ranging from 0 to B. The second character indicates the channel number.

**(data)** is the hexadecimal representation of the digital output value(s). Two characters are for ADAM-4050, ADAM-4055, ADAM-4060 and ADAM-4068. Four characters are for ADAM-4056S and 4056SO.

### ADAM-4050, 4055, 4060 and 4068:

**When writing to a single channel** (bit), the first character is always 0. The value of the second character will be either 0 or 1.

**When writing to all channels** (byte), both characters are significant (range 00h-FFh). The digital equivalent of these two hexadecimal characters represents the value of the channels.

The amount of channels on ADAM-4050, ADAM-4055, ADAM-4060 and ADAM-4068 differ. The value 7A representation for 8 channeled ADAM-4050, ADAM-4055 and ADAM-4068 would be the following:

|                                 |   |   |   |   |   |   |   |   |
|---------------------------------|---|---|---|---|---|---|---|---|
| Digital Value:                  | 0 | 1 | 1 | 1 | 1 | 0 | 1 | 0 |
| ADAM-4050/4055/4068 channel no. | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |

Since the ADAM-4060 only has four output channels, all the relevant values lie between 00h and 0Fh. The value 0Ah for the ADAM-4060 would represent the following:

|                       |   |   |   |   |   |   |   |   |
|-----------------------|---|---|---|---|---|---|---|---|
| Digital Value:        | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| ADAM-4060 channel no. | - | - | - | - | 3 | 2 | 1 | 0 |

**ADAM-4056S and 4056SO:**

**When writing to a single channel** (bit), the first three characters are always 0. The value of the last character is either 0 or 1.

**When writing to all channels** (byte), the first character zero is irrelevant, but the rest are significant (range 000h-FFFh). The digital equivalent of last three hexadecimal characters represents the value of channels.

For example: 017A

First character is always 0

2nd~4th character means the the channel values 17A.

|                               |    |    |   |   |   |   |   |   |   |   |   |   |
|-------------------------------|----|----|---|---|---|---|---|---|---|---|---|---|
| Digital value                 | 0  | 0  | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 0 | 1 | 0 |
| Adam-4056S/4056SO channel no. | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |

**(cr)** is the terminating character, carriage return (0Dh).

**Response**

**>(cr)** if the command was valid.

**?AA(cr)** if an invalid command has been issued.

There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.

**>** is a delimiter character which indicates a valid command.

**?** is a delimiter character which indicates an invalid command.

**AA** (range 00-FF) represents the responding 2-character hexadecimal address of the module.

**(cr)** is the terminating character, carriage return (0Dh).



## #AABB

### Examples

command: #140005(cr)

response: >(cr)

An output byte with value 05h (00000101) is sent to the digital I/O module at address 14h (Either ADAM-4050 or ADAM-4060). Its channel 0 and 2 will be set to ON. Other channels are set to OFF.

command: #151201(cr)

response: >(cr)

An output bit with value 1 is sent to channel 2 at address 15h of a digital I/O module (Either ADAM-4050 or ADAM-4060).

Channel 2 of the digital I/O module is set to ON.

command: #1400017A(cr)

response: >(cr)

An output byte with value 017Ah (0000000101111010) is sent to the digital I/O module at address 14h (Either ADAM-4056S or ADAM-4056SO). Its channel 1, 3, 4, 5, 6, and 8 will be set to ON. Other channels are set to OFF.

command: #15120001(cr)

response: >(cr)

An output bit with value 1 is sent to channel 2 of a digital I/O module at address 15h (Either ADAM-4056S or ADAM-4056SO). Channel two of the digital I/O module is set to ON.

**\*\*\***

|                    |   |
|--------------------|---|
| <b>Name</b>        | Synchronized Sampling command   |
| <b>Description</b> | Orders all (analog or digital) input modules to sample their input values and store them into a special register.   |
| <b>Syntax</b>      | <p><b>***</b></p> <p><b>#</b> is a delimiter character.</p> <p><b>**</b> is the Synchronized Sampling command.</p> <p>The terminating character, in the form of a carriage return (0Dh), is not required.</p> |
| <b>Response</b>    | The digital I/O modules will not respond to the Synchronized Sampling command. In order to retrieve the data, you must execute a Read Synchronized Data command for every module separately.                  |

## **\$AA4**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Synchronized Data command   |
| <b>Description</b> | The addressed digital I/O module is instructed to return the value that was stored in its register by a Synchronized Sampling command.   |
| <b>Syntax</b>      | <b>\$AA4(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of returning data.<br><b>4</b> is the Read Synchronized Data command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>!(status)(dataOutput)(dataInput)00(cr)</b><br>if the command was valid. (ADAM-4050)<br><b>!(status)(dataInput)00(cr)</b><br>if the command was valid. (ADAM-4051)<br><b>!(status)(dataInput)0000(cr)</b><br>if the command was valid. (ADAM-4052)<br><b>!(status)(dataInput)(dataInput)00(cr)</b><br>if the command was valid. (ADAM-4053)<br><b>!(status)(dataOutput)0000(cr)</b><br>if the command was valid. (ADAM-4060/4068)<br><b>?AA(cr)</b> if an invalid command has been issued.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br>!<br>?<br><b>AA</b> (range 00-FF) represents the responding 2-character hexadecimal address of the digital I/O module.<br><b>(status)</b> will tell you if the data (data) from the last Synchronized Sampling command (***) have already been sent. If (status=1), data have only been sent for the first time after a Synchronized Sampling command was issued. If (status=0), then the data have been sent at least once since no Synchronized Sampling command was issued. |

## \$AA4

**(dataOutput)** two-character hexadecimal value which is either the feedback of a digital output channel or a relay.

**(dataInput)** two-character hexadecimal value representing the input values of the digital I/O module.

**(cr)** is the terminating character, carriage return (0Dh).

### Example

command: \$064(cr)

response: !1055100(cr)

The command asks the ADAM-4050 digital I/O module at address 06h to send its digital input data that was gathered during the last Synchronized Sampling command. The module returns the value 1055100 with status equals to 1 which also represents that data have not been sent before. From inspection, the value has dataOutput = 05h (00000101), ON for digital output channels 0 and 2 and OFF for channels 1, 3, 4, 5, 6, 7. It also has dataInput = 51h (01010001) which represents HIGH for digital input channels 0, 4, 6 and LOW for channels 1, 2, 3, 4, 5.

The digital I/O module responds with data = 055100 and status = 1. These mean that the data has been sent for the first time.

command: \$064(cr)

response: !0055100(cr)

The command asks the digital I/O module at address 06h to send its digital input data.

The digital I/O module responds with data = 055100 and status = 0, which means that it has sent the same data at least once before. This may also indicates that a previous Synchronized Sampling command was not received!

## **\$AA2**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Configuration Status command   |
| <b>Description</b> | Returns the configuration parameters of the digital I/O module.  |
| <b>Syntax</b>      | <p><b>\$AA2(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>2</b> is Configuration Status command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> <p>This command requests the return of the configuration data from the digital I/O module at address AA.</p>  |
| <b>Response</b>    | <p><b>!AATTCCFF(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid command has been issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>TT</b> represents the type of code, which is always 40.</p> <p><b>CC</b> represents the baud rate codes.</p> <p>(Refer to Table 7-2 on next page).</p> <p>The hexadecimal number <b>FF</b> which is converted to a 8-bit parameter represents the checksum and protocol status .</p> <p>Bits 3 through 5 and bit 0, 1, 7 are not used, so they are set to 0. (Refer to Figure 7-2 on next page)</p> <p>Bit 6 is the selection of checksum and bit 2 is the selection of protocol (0: advantech, 1: modbus).</p> <p>(Modbus protocol is supported by ADAM-4051, 4055, 4056S, 4056SO, 4068 only)</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |

**\$AA2**

**Example**


command: \$452 (cr)  
response: !45400600 (cr)

The command asks the digital I/O module at address 45h to send its configuration data.

The digital I/O module at address 45h responds with baud rate 9600, no checksum function and module supports for Advantech protocol.

**Table 7-2 Baud Rate Codes**

| Baud Rate Code (Hex) | Baud Rate  |
|----------------------|------------|
| 03                   | 1200 bps   |
| 04                   | 2400 bps   |
| 05                   | 4800 bps   |
| 06                   | 9600 bps   |
| 07                   | 19.2 kbps  |
| 08                   | 38.4 kbps  |
| 09                   | 57.6 kbps  |
| 0A                   | 115.2 kbps |



**Figure 7-2 Data format for FF (8-bit parameter)**

## **\$AA5**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Reset Status command  |
| <b>Description</b> | Requests the Reset Status of the addressed digital I/O module to see whether it has been reset since the last Reset Status command.   |
| <b>Syntax</b>      | <b>\$AA5(cr)</b><br><b>\$</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address whose Reset Status is to be returned.<br><b>5</b> is the Reset Status command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AAS(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid command has been issued.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command.<br><b>?</b> is a delimiter character which indicates an invalid command.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address which is to be calibrated.<br><b>S</b> represents the Status bit that is returned by the digital I/O module. If S=1, the module has been reset since it was issued last time. If S=0, the module has not been reset since the last Reset Status command was not issued.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |

**\$AA5**

**Example**

command: \$395(cr)

response: !390(cr)

The command tells the digital I/O module at address 39h to return its Reset Status.

The digital I/O module at address 39h returns the value S=0. This indicates that the digital I/O module has not been reset or powered on since a Reset Status command was issued last time.



## **\$AAF**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Firmware Version command   |
| <b>Description</b> | The command requests the digital I/O module at address AA to return the version code of its firmware  |
| <b>Syntax</b>      | <b>\$AAF (cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br>F is the Read Firmware Version command.<br>(cr) is the terminating character, carriage return (ODh).   |
| <b>Response</b>    | <b>!AA(Version)(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br>! is a delimiter character which indicates a valid command.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the module.<br>(Version) is the version code of the module's firmware at address AA.<br>(cr) is the terminating character, carriage return (ODh). |

## **\$AAM**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Module Name command  |
| <b>Description</b> | The command requests the digital I/O module at address AA to return its name  |
| <b>Syntax</b>      | <b>\$AAM (cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br>M is the Read Module Name command.<br>(cr) is the terminating character, carriage return (ODh).  |
| <b>Response</b>    | <b>!AA(Module Name)(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, even or if the specified address does not exist.<br>! is a delimiter character which indicates a valid command.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the module.<br>(Module Name) is the name of the module at address AA.<br>For example, 4052<br>(cr) is the terminating character, carriage return (ODh). |

## \$AAX0TTTTDDDD

**Name** Write Safety Value command  
**Description** Force the DO channels to safety status when communication is in time-out and over pre-defined period.

**Syntax** **\$AAX0TTTTDDDD(cr)**  
**\$** is a delimiter character.  
**AA (range 00-FF)** represents the 2-character hexadecimal address that you will access to.  
**X0** is the Write Safety Value command.  
**TTTT** is the time, 100 ms per number.  
**DDDD** is the four-hexadecimal character representing the desired input safety value. The first character D is always 0, and the others are the channels values.

For Example, 017A

First character is always 0

The meaning of 17A is as follows:

|                         |    |    |   |   |   |   |   |   |   |   |   |   |
|-------------------------|----|----|---|---|---|---|---|---|---|---|---|---|
| Digital value           | 0  | 0  | 0 | 1 | 0 | 1 | 1 | 1 | 0 | 1 | 0 |   |
| Adam-4056SO channel no. | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |

17A means that the status of channel 1, 3, 4, 5, 6, 8 is ON; and the rest are OFF.

**(cr)** is the terminating character, carriage return (0Dh).

**Response** **>(cr)** if the command was valid.

**?AA(cr)** if an invalid command has been issued.

There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.

**>** is a delimiter character which indicates a valid command.

**?** is a delimiter character which indicates an invalid command.

**AA** (range 00-FF) represents the responding 2-character hexadecimal address of the module.

**(cr)** is the terminating character, carriage return (0Dh).

**\$AAX1**

**Name** Read Safety Value command  
**Description** Read the time-out setting and pre-defined safety status of DO channels.

**Syntax** **\$AAX1(cr)**  
**\$** is a delimiter character.  
**AA** (range 00-FF) represents the 2-character hexadecimal address that you will access to.  
**X1** is the Read Safety Value command.  
**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!TTTTDDDD(cr)** if the command is valid.  
**?AA(cr)** if an invalid command has been issued.  
**!** is a delimiter character which indicates a valid command.  
**?** is a delimiter character which indicates an invalid command.  
**TTTT** is the time, 100 ms per number.  
**DDDD** is the four-hexadecimal character representing the desired input safety value. The first character D is always 0, and the others are the channels values.

For Example, 017A

First character is always 0

The meaning of 17A is as follows:

|                         |    |    |   |   |   |   |   |   |   |   |   |
|-------------------------|----|----|---|---|---|---|---|---|---|---|---|
| Digital value           | 0  | 0  | 0 | 1 | 0 | 1 | 1 | 1 | 0 | 1 | 0 |
| Adam-4056SO channel no. | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 |

17A means channels 1, 3,4,5, 6, 8 are ON, and the rest are OFF.

**(cr)** is the terminating character, carriage return (0Dh).

## **\$AAX2**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Safety Flag command   |
| <b>Description</b> | Requests the Safety Flag of the addressed digital I/O module to see whether the safety value has been executed since Write Safety Value command was set.   |
| <b>Syntax</b>      | <b>\$AAX2(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br><b>X2</b> is the Read Safety Flag command.   |
| <b>Response</b>    | <b>!XX (cr)</b> if the command is valid.<br><b>XX</b> is two-hexadecimal character – (00: OFF, 01: ON)<br><b>?AA(cr)</b> if an invalid command has been issued.<br>! is a delimiter character which indicates a valid command.<br>? is a delimiter character which indicates an invalid command.<br><b>(cr)</b> is the terminating character, carriage return (ODh). |

**\$AAE0**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read and Clear over Current Status Flag command  |
| <b>Description</b> | Read the Over Current Status Flag and Clear the Flag simultaneously.   |
| <b>Syntax</b>      | <b>\$AAE0(cr)</b><br><b>\$</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br><b>E0</b> is the Read and Clear over Current Status Flag command.<br><b>(cr)</b> is the terminating character, carriage return (ODh).   |
| <b>Response</b>    | <b>!AAX(cr)</b> : if the command is valid.<br><b>?AA(cr)</b> : if an invalid command has been issued.<br><b>X</b> is one-hexadecimal character (range from 0 to 7)<br>X=0: No over current occur<br>X=1: DO0~3 has over current occurred<br>X=2: DO4~7 has over current occurred<br>X=4: DO8~11 has over current occurred<br><b>!</b> is a delimiter character which indicates a valid command<br><b>?</b> is a delimiter character which indicates an invalid command<br><b>(cr)</b> is the terminating character, carriage return (ODh). |

**\$AAP**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read the Low Power Status of Module command  |
| <b>Description</b> | The command requests the module at address AA to return the low power status of module   |
| <b>Syntax</b>      | <b>\$AAP(cr)</b><br><b>\$</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br><b>P</b> is the Read the Low Power Status of Module command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>!AAS(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid command has been issued.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command<br><b>?</b> is a delimiter character which indicates an invalid command<br><b>AA</b> (range 00-FF) represents the calibrated 2-character hexadecimal address of the module.<br><b>S</b> represents the Status bit from the low power status. When the logic equals to 1, it represents low power. When it equals to zero, it means normal.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |

**\$AAS**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Change and Read the Low Power Mode of Module command   |
| <b>Description</b> | The command requests the module at address AA to change and return the status of low power mode of module  |
| <b>Syntax</b>      | <p><b>\$AAS(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>S</b> is the Change and Read the Low Power Mode of Module command</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AAX(cr)</b> if the command was valid.</p> <p><b>?AA(cr)</b> if an invalid command has been issued.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command</p> <p><b>?</b> is a delimiter character which indicates an invalid command</p> <p><b>AA</b> (range 00-FF) represents the calibrated 2-character hexadecimal address of the module.</p> <p><b>X</b> represents the Status bit from the low power status. When the logic is 1, it represents low power. However, if the logic is 0, it is normal</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |



## **\$AAXnnnn**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Watchdog Timer Setting command   |
| <b>Description</b> | This command set the communication watchdog timer (WDT) cycle time.  |
| <b>Syntax</b>      | <b>\$AAXnnnn(cr)</b><br><b>\$</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be read.<br><b>X</b> is Watchdog Timer Setting command.<br><b>nnnn</b> (range 0000~9999) represents the specified value of communication cycle you want to set. (Unit: 0.1 second)<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax error or communication error or if the specified address does not exist.<br><b>!</b> delimiter character indicates a valid command was received.<br><b>?</b> delimiter character indicates the command was invalid.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the analog input module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: \$02X1234(cr)<br>response: !02(cr)<br>The command set the WDT cycle as 1234 in the input module at address 02.  |

***NOTICE: If the value of “nnnn” is 0000, the communication WDT function will be disable.***

## **\$AA Y**

**Name** Read Communication Watchdog Timer Cycle Setting command

**Description** This command read the setting of communication watchdog timer (WDT) cycle time.

**Syntax** **\$AA Y(cr)**

**\$** is a delimiter character.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module which is to be read.

**Y** is the Read Communication Watchdog Timer Cycle Setting command.

**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AA nnnn(cr)** if the command was valid.

**?AA(cr)** if an invalid operation was entered.

There is no response if the module detects a syntax error or communication error or if the specified address does not exist.

**!** delimiter character indicates a valid command was received.

**?** delimiter character indicates the command was invalid.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the analog input module.

**nnnn** (range 0000~9999) represent the specified value of communication cycle you read. (Unit: 0.1 second)

**(cr)** represents terminating character, carriage return (0Dh).

**Example** command: \$02Y(cr)

response: !020030(cr)

The command read the WDT cycle as 0030 in the input module at address 02.


## 7.2 Counter/Frequency Module Command

### 7.2.1 Configuration, Counter Input and Display Command Set

| Command Syntax | Description   | I/O Module     |
|----------------|---|----------------|
| %AANNITCCFF    | Sets the address, input mode, baud rate, checksum status and/or frequency gate time for a specified counter/frequency module                                  | 4080,<br>4080D |
| \$AA2          | Requests the return of the configuration data from the counter/frequency module   | 4080,<br>4080D |
| \$AAF          | Requests the counter/frequency module to return the version code of its firmware  | 4080,<br>4080D |
| \$AAM          | Requests the counter/frequency module to return its name  | 4080,<br>4080D |
| \$AABS         | Set the input signal mode of the specified counter/frequency module to either non-isolated (TTL) or photo-isolated.   | 4080,<br>4080D |
| \$AAB          | Read the input mode of the specified counter/frequency module.  | 4080,<br>4080D |
| #AAN           | Instructs the addressed counter/ frequency module to read the counter or frequency value of counter 0 or counter 1 and return the acquired data.              | 4080,<br>4080D |
| \$AA8V         | Select whether LED will display data from the counter/frequency module directly or from the host computer.  | 4080D          |
| \$AA8          | Read the LED Data Origin status which determines whether LED will display data from the counter/frequency module directly or from the host computer           | 4080D          |
| \$AA9(data)    | The host computer sends data to the addressed module to display on its LED. This command is valid only after selecting to display host computer data (\$AA8V) | 4080D          |

**%AANNTTCFF**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Configuration command  |
| <b>Description</b> | Sets the address, input mode, baud rate, checksum status and frequency gate time for a specified counter/frequency module  |
| <b>Syntax</b>      | <p><b>%AANNTTCFF (cr)</b></p> <p><b>%</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>NN</b> represents the new hexadecimal address of the counter/frequency module. Range is from 00h to FFh.</p> <p><b>TT</b> represents the input mode.<br/> 50h : counter input mode<br/> 51h : frequency measurement mode</p> <p><b>CC</b> represents the baud rate code.<br/> (Refer to Table 7-3 on next page).</p> <p>Hexadecimal value <b>FF</b> which is converted to an 8-bit parameter represents the checksum status and frequency gate time. The layout of the 8-bit parameter is shown in Figure 7-3 below.</p> <p>Bits 0, 1, 3, 4, 5 and 7 are not used and are set to 0.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |



**Figure 7-3 Data format for FF (8-bit parameter)**

**%AANNTTCFF**

**Response**     **!AA(cr)** if the command is valid.  
**?AA(cr)** if an invalid parameter was entered or the INIT\* terminal was not grounded when changing baud rate or checksum setting were attempted.  
 There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.  
**!** is a delimiter character which indicates a valid command.  
**?** is a delimiter character which indicates an invalid command.  
**AA** (range 00-FF) represents the 2-character hexadecimal address of the module.  
**(cr)** is the terminating character, carriage return (0Dh).

**Example**     command: %0120510600(cr)  
 response:    !20(cr)

The ADAM 4080D module is configured by changing address 01 to a new address 20, choosing frequency measurement module, assigning 9600 to baud rate, setting frequency gate time 0.1 second and no checksum checking or generation.

The response indicates that the command was received.

Wait seven seconds to let the new configuration settings take effect before you issue a new command to the module.

**Table 4-7 Baud Rate Codes**

| Baud Rate Code (Hex) | Baud Rate |
|----------------------|-----------|
| 03                   | 1200 bps  |
| 04                   | 2400 bps  |
| 05                   | 4800 bps  |
| 06                   | 9600 bps  |
| 07                   | 19.2 Kbps |
| 08                   | 38.4 Kbps |

***NOTICE: You can change all configuration parameters dynamically except checksum and baud rate parameters. They can only be altered when the INIT\* terminal is grounded.***

**\$AA2**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Configuration Status command  |
| <b>Description</b> | The command requests the return of the configuration data from the counter/frequency module at address AA.  |
| <b>Syntax</b>      | <p><b>\$AA2(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>2</b> is the Configuration Status command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AATTCCFF (cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal that you will access to.</p> <p><b>TT</b> (50h or 51h) represents the type of code. 50h means using module as a counter. 51h means using module as a frequency measurement module.</p> <p><b>CC</b> represents the baud rate code.</p> <p>Hexadecimal value <b>FF</b> which also equals to an 8-bit parameter represents the checksum status and frequency gate time. The layout of the 8-bit parameter is shown in figure 4-5. The bits are not used and are set to 0.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p> <p>(Also see the %AANNTTCCFF configuration command)</p> |

**\$AAF**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Version command  |
| <b>Description</b> | The command requests the analog input module at address AA to return the version code of its firmware.  |
| <b>Syntax</b>      | <b>\$AAF (cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br>F is the Read Version command.<br>(cr) is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(Version)(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br>! is a delimiter character which indicates a valid command.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the module.<br>(Version) is the version code of the module's firmware at address AA.<br>(cr) is the terminating character, carriage return (0Dh). |

**\$AAM**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Module Name command  |
| <b>Description</b> | The command requests the counter/frequency module at address AA to return its name  |
| <b>Syntax</b>      | <b>\$AAM (cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br>M is the Read Module Name command.<br>(cr) is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | !AA(Module Name)(cr) if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br>! is a delimiter character which indicates a valid command.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the module.<br>(Module Name) is the name of the module at address AA.<br>For example, 4080D<br>(cr) is the terminating character, carriage return (0Dh). |



**\$AABS**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Input Mode command  |
| <b>Description</b> | Set the input signal mode of the specified counter/frequency module to either non-isolated (TTL) or photo-isolated.   |
| <b>Syntax</b>      | <p><b>\$AABS(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>B</b> is the Set Input Signal Mode command.</p> <p><b>S</b> indicates the input signal mode. When S = 0, the module is configured to non-isolated (TTL) input. If S = 1, the module is configured to photo-isolated input.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: \$03B0(cr)</p> <p>response: !03(cr)</p> <p>The command configures the counter/frequency modules at address 03 to retrieve a non-isolated input. The module replies by sending its address to indicate that the command was executed.</p>  |

**NOTICE:** *The input mode command is not related to a specific channel. When the input mode is set both channels are changed accordingly.*

**\$AAB**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Input Mode command   |
| <b>Description</b> | Read the input mode of the specified counter/frequency module.  |
| <b>Syntax</b>      | <p><b>\$AAB(cr)</b><br/> <b>\$</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br/> <b>B</b> is the Read Input Mode command.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AAS(cr)</b> if the command is valid.<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>S</b> indicates the input signal mode. When S = 0, the module is configured to non-isolated (TTL) input. If S = 1, the module is configured to photo-isolated input.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$03B(cr)<br/> response: !030(cr)</p> <p>The command requests the counter/frequency module at address 03 to return its input mode. The module replies by setting the input mode to retrieve non-isolated input.</p>   |

**#AAN**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Counter or Frequency Value command  |
| <b>Description</b> | Instructs the addressed counter/frequency module at address AA to read the counter or frequency value of counter 0 or counter 1 and return the acquired data.  |
| <b>Syntax</b>      | <b>#AAN(cr)</b><br># is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br><b>N</b> represents the counter number.<br>N=0 represents counter 0<br>N=1 represents counter 1<br><b>(cr)</b> is the terminating character, carriage return (0Dh).   |
| <b>Response</b>    | <b>&gt;data(cr)</b> if the command is valid.<br><b>?AA(cr)</b> if an invalid operation was entered.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>?</b> is a delimiter character which indicates an invalid command.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>(data)</b> is the value that is retrieved by the module from reading counter 0 or counter 1. The data format consists of eight hexadecimal characters.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: #120(cr)<br>response: >000002FE(cr)<br>The command requests the counter/frequency module at address 12 to read the counter 0 and return the data. The counter/frequency module at address 12 responds with value 000002FE (hexadecimal) of counter 0 which is also equivalent to 766 (decimal).   |

**\$AA8V**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Select LED Data Origin command  |
| <b>Description</b> | Select whether LED will display data from either the host computer or the counter/frequency module directly.  |
| <b>Syntax</b>      | <p><b>\$AA8V(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>8</b> is the Select LED Data Origin command.</p> <p><b>V</b> indicates the origin of the data which is to be displayed on the LED:</p> <p>V=0 sets the LED data origin to the module's counter 0</p> <p>V=1 sets the LED data origin to the module's counter 1</p> <p>V=2 sets the LED data origin to the host computer</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>           |
| <b>Example</b>     | <p>command: \$0182(cr)</p> <p>response: !01(cr)</p> <p>The command sets the counter/frequency modules at address 01 to display data sent by the host computer. After this command has been issued, the host computer can use command \$AA9(data) to send the data to the module.</p>  |

**\$AA8**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read LED Data Origin command   |
| <b>Description</b> | Read the LED Data Origin status which determines whether LED will display data from either the host computer or the counter/frequency module directly.   |
| <b>Syntax</b>      | <p><b>\$AA8(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>8</b> is the Read LED Data Origin command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh)</p>  |
| <b>Response</b>    | <p><b>!AAV(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>V</b> indicates the origin of the data to be displayed on the LED:</p> <p>V=0 sets the LED data origin to the module's counter 0</p> <p>V=1 sets the LED data origin to the module's counter 1</p> <p>V=2 sets the LED data origin to the host computer</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$018(cr)</p> <p>response: !011(cr)</p> <p>The command requests the counter/frequency module at address 01 to return its LED Data Origin status. The module replies that it currently displays data from counter 1.</p>  |

**\$AA9(data)**

**Name** Send Data to LED command

**Description** The host computer sends data to the addressed module to display on its LED.

**Syntax** **\$AA9(data)(cr)**

**\$** is a delimiter character.

**AA** (range 00-FF) represents the 2-character hexadecimal address that you will access to.

**9** is the Send LED Data command.

**(data)** is a floating point numeral consisting of five digits, and there can be a decimal point. Its maximum value is 99999.

**(cr)** is the terminating character, carriage return (0Dh)

**Response** **!AA(cr)** if the command is valid.

**?AA(cr)** if an invalid operation was entered.

There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.

**!** is a delimiter character which indicates a valid command.

**?** is a delimiter character which indicates an invalid command.

**AA** (range 00-FF) represents the 2-character hexadecimal address of a counter/frequency module.

**(cr)** is the terminating character, carriage return (0Dh).

**Example** command: **\$0198999.9(cr)**

response: **!01(cr)**

The command requests the host computer to send 8999.9 to the counter/frequency module at address 01 for LED display. This command is only valid after the command \$0182 has been issued.

## 7.2.2 Counter Setup Command Set

| Command Syntax | Command Name                   | Description  | I/O Module  |
|----------------|--------------------------------|--|-------------|
| \$AAAG         | Set Gate Mode                  | Requests the specified counter/frequency module to set its gate mode to either high, low or disabled         | 4080, 4080D |
| \$AAA          | Read Gate Mode                 | Requests the specified counter/frequency module to return the status of its gate mode                        | 4080, 4080D |
| \$AA3N(data)   | Set Maximum Counter Value      | Sets the maximum value of counter 0 or counter 1 for the specified counter/frequency module                  | 4080, 4080D |
| \$AA3N         | Read Maximum Counter Value     | Reads the maximum value of counter 0 or counter 1 of the specified counter/ frequency module                 | 4080, 4080D |
| \$AA5NS        | Start/Stop Counter             | The command orders the specified counter/frequency module to start or stop counting                          | 4080, 4080D |
| \$AA5N         | Read Counter Start/Stop Status | The addressed counter frequency module returns its status indicating whether counting is enabled or disabled | 4080, 4080D |
| \$AA6N         | Clear Counter                  | The command clears the counter 0 or counter 1 of the specified counter module                                | 4080, 4080D |
| \$AA7N         | Read Overflow Flag             | The addressed module returns the status of the overflow flag of counter 0 or counter 1                       | 4080, 4080D |

**\$AAAG**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Gate Mode command   |
| <b>Description</b> | Request the specified counter/frequency module to set its gate to one of the three states, high, low or disabled.   |
| <b>Syntax</b>      | <p><b>\$AAAG(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>A</b> is the Gate Mode command.</p> <p><b>G</b> determines the gate mode:</p> <p>G = 0 the gate is low</p> <p>G = 1 the gate is high</p> <p>G = 2 the gate is disabled</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: \$01A1(cr)</p> <p>response: !01(cr)</p> <p>The command requests the counter/frequency module at address 01 to set its gate high. The module will reply with an address indicating that it has executed the command.</p>   |



**\$AAA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Gate Mode command  |
| <b>Description</b> | Request the specified counter/frequency module to return its gate status.   |
| <b>Syntax</b>      | <b>\$AAA(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br><b>A</b> is the Read Gate Mode command.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AAG(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>G</b> determines the gate mode.<br>G = 0 the gate is low<br>G = 1 the gate is high<br>G = 2 the gate is disabled.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: \$01A(cr)<br>response: !011(cr)<br>The command requests the counter/frequency module to return its gate status. The module at address 01 replies with gate setting high.   |

**\$AA3N(data)**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Maximum Counter Value command   |
| <b>Description</b> | Set the maximum value for either counter 0 or counter 1 of a specified counter/frequency module.  |
| <b>Syntax</b>      | <p><b>\$AA3N(data)(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>3</b> is the Set Maximum Counter Value command.</p> <p><b>N</b> determines the counter for which the maximum counter value is to be set.</p> <p>N = 0 represents counter 0</p> <p>N = 1 represents counter 1</p> <p><b>(data)</b> is the maximum count value which consists of eight hexadecimal digits. The module will accumulate the input counts until it reaches the maximum value. When the count exceeds the maximum counter value, the counter will stop counting. The programmer should use the command \$AA6N to reset the counter to 1.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: \$24300000ffff(cr)</p> <p>response: !24(cr)</p> <p>The command requests the counter/frequency module at address 24 to set the maximum value for counter 0 to 65535 (0x0000ffff). The module will reply that it has executed the command.</p>  |

**\$AA3N**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Maximum Counter Value command  |
| <b>Description</b> | Read the maximum value of counter 0 or counter 1 for a specified counter/frequency module.  |
| <b>Syntax</b>      | <p><b>\$AA3N(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>3</b> is the Read Maximum Counter Value command.</p> <p><b>N</b> determines the counter for which the maximum counter value is to be set.</p> <p>N = 0 represents counter 0</p> <p>N = 1 represents counter 1</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command. AA (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the maximum counter value which consists of eight hexadecimal digitals.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$2430(cr)</p> <p>response: !240000ffff(cr)</p> <p>The command requests the counter/frequency module at address 24 for the maximum number of counter 0. The module replies the maximum count number of channel 0 with 65535 (0000ffff)</p>  |

**\$AA5NS**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Start/Stop Counter command   |
| <b>Description</b> | Request the counter/frequency module to start or stop the counting for either counter 0 or counter 1.  |
| <b>Syntax</b>      | <p><b>\$AA5NS(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>5</b> is the Start/Stop Counter command.</p> <p><b>N</b> determines the counter that should be either enabled or disabled.</p> <p>N = 0 represents counter 0<br/>N = 1 represents counter 1</p> <p><b>S</b> represents the counter status.</p> <p>S = 0 stops counting<br/>S = 1 starts counting</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid. There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of a counter input module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: \$06501(cr)<br/>response: !06(cr)</p> <p>The command requests the counter 0 of counter/frequency module at address 06 to start. The addressed module replies with its address indicating that the command has been executed. Counter 0 has started.</p>  |

**\$AA5N**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Counter Start/Stop Status command   |
| <b>Description</b> | Requests the addressed counter/frequency module to indicate whether counter 0 or counter 1 is active.  |
| <b>Syntax</b>      | <b>\$AA5N(cr)</b><br>\$ is a delimiter character.<br>AA (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br>5 is the Read Counter Start/Stop Status command.<br>N determines the counter for which the status should be returned.<br>N = 0 represents counter 0<br>N = 1 represents counter 1<br>(cr) is the terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AAS(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br>! is a delimiter character which indicates a valid command.<br>AA (range 00-FF) represents the 2-character hexadecimal address of the module.<br>S represents the counter status.<br>S = 1 indicates the status is counting<br>S = 0 indicates the status is not counting<br>(cr) is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: \$0650(cr)<br>response: !061(cr)<br>The command requests the counter/frequency module at address 06 to return the status of counter 0. The module replies that the counter 0 is in the counting process.  |

**\$AA6N**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Clear Counter command  |
| <b>Description</b> | Clears the counter 0 or counter 1 of the specified counter/frequency module.   |
| <b>Syntax</b>      | <p><b>\$AA6N(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>6</b> is the Clear Counter command.</p> <p><b>N</b> determines the counter which should be cleared.</p> <p>N = 0 represents counter 0</p> <p>N = 1 represents counter 1</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>    |
| <b>Example</b>     | <p>command: \$1361(cr)</p> <p>response: !13(cr)</p> <p>The command requests the counter/frequency module at address 13 to clear counter 1. The module replies with its address indicating that the counter has been cleared.</p>   |

**\$AA7N**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read/Clear Overflow Flag command   |
| <b>Description</b> | The command requests the module to return the status of the overflow flag for either counter 0 or counter 1. Then clear the flag afterwards.   |
| <b>Syntax</b>      | <p><b>\$AA7N(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>7</b> is the Read/Clear Overflow Flag command.</p> <p><b>N</b> determines the channel whose overflow flag status should be read and cleared. When N = 0, it represents counter 0. On the other hand, N = 1 represents counter 1</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AAV(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>V</b> represents the status of the Nth channel's overflow flag.</p> <p>V = 1 means that the overflow flag has been set because the counting has exceeded the maximum count.</p> <p>V = 0 means that the overflow flag has not been set.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$1371(cr)</p> <p>response: !131(cr)</p> <p>The command requests the counter/frequency module at address 13 to return the status of the overflow flag for counter 1 and to reset it. The module replies with the overflow flag for counter 1 indicating overflow. Then it is being reset.</p>  |

### 7.2.3 Digital Filter and Programmable Threshold Command Set

| Command Syntax | Command Name                                  | Description   | I/O Module  |
|----------------|---|---|-------------|
| \$AA4S         | Enable/Disable Digital Filter                 | Enables or disables the digital filter of the addressed counter/frequency module                                | 4080, 4080D |
| \$AA4          | Read Filter Status                            | The addressed counter frequency module returns the status of its digital filter                                 | 4080, 4080D |
| \$AA0H(data)   | Set Minimum Input Signal Width at High Level  | Sets the minimum input signal width at high level for a specified counter/frequency module                      | 4080, 4080D |
| \$AA0H         | Read Minimum Input Signal Width at High Level | Reads the minimum input signal width setting at high level for a specified counter/frequency module             | 4080, 4080D |
| \$AA0L(data)   | Set Minimum Input Signal Width at Low Level   | Sets the minimum input signal width at low level for a specified counter/frequency module                       | 4080, 4080D |
| \$AA0L         | Read Minimum Input Signal Width at Low Level  | Reads minimum input signal width setting at low level for a specified counter/frequency module                  | 4080, 4080D |
| \$AA1H(data)   | Set Non-isolated High Trigger Level           | Sets the high trigger level of non-solated input signals for a specified counter/frequency module               | 4080D       |
| \$AA1H         | Read Non-isolated High Trigger Level          | Requests the addressed counter frequency module to return the high trigger level for non-isolated input signals | 4080D       |
| \$AA1L(data)   | Set Non-isolated Low Trigger Level            | Sets the low trigger level of non-solated input signals for a specified counter/frequency module                | 4080D       |
| \$AA1L         | Read Non-isolated Low Trigger Level           | Requests the addressed counter/frequency module to return the low trigger level for non-isolated input signals  | 4080D       |



**\$AA4S**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Enable/Disable Digital Filter command  |
| <b>Description</b> | Enables or disables the digital filter of the counter/frequency module.  |
| <b>Syntax</b>      | <b>\$AA4S(cr)</b><br>\$ is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br><b>4</b> is the Enable/Disable Filter command.<br><b>S</b> is the digital filter mode.<br>S = 0 means disable filter<br>S = 1 means enable filter<br><b>(cr)</b> is the terminating character, carriage return (0Dh).                              |
| <b>Response</b>    | <b>!AA(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: \$0340(cr)<br>response: !03(cr)<br>The command orders the counter/frequency module at address 03 to disable its digital filter. The module returns its address indicating that it has executed the command successfully.  |

**\$AA4**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Filter Status command   |
| <b>Description</b> | Read the digital filter status of the addressed counter/frequency module.  |
| <b>Syntax</b>      | <p><b>\$AA4(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>4</b> is the Read Filter Status command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AAS(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>S</b> is the digital filter mode.</p> <p>S = 0 means filter is disabled</p> <p>S = 1 means filter is enabled</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$034(cr)</p> <p>response: !030(cr)</p> <p>The command requests the counter/frequency module at address 03 to return whether its digital filter is ON or not. The module returns its address which indicates that its digital filter is disabled.</p>  |

**\$AA0H(data)**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Minimum Input Signal Width at High Level command   |
| <b>Description</b> | Set the minimum input signal width at high level for a specified counter/frequency module to filter the noise.   |
| <b>Syntax</b>      | <p><b>\$AA0H(data)(cr)</b><br/> <b>\$</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br/> <b>0H</b> is the Set Minimum Input Signal Width at High Level command.<br/> <b>(data)</b> is the minimum width at high level. The unit is in <math>\mu\text{sec}</math> (microseconds) and its resolution is 1 <math>\mu\text{sec}</math>. The format is a five digit integer that can range from 2 <math>\mu\text{sec}</math> to 65535 <math>\mu\text{sec}</math>. Out of range values will cause errors.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid. The addressed module stores the value and will recognize the input signal "high" only after the input signal continues "high" and for longer than the specified value.<br/> <b>?AA(cr)</b> if an invalid operation was entered.<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>?</b> is a delimiter character which indicates an invalid command.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$130H00020(cr)<br/> response: !13(cr)<br/> The command requests the counter/frequency module at address 13 to set the minimum input width at high level to 20 <math>\mu\text{sec}</math>. The module stores the value and will identify an input signal to be "high" only if the signal continues to be "high" longer than 20 <math>\mu\text{sec}</math>. This function can be used as a digital filter.</p>  |

**\$AA0H**

**Name** Read Minimum Input Signal Width at High Level command

**Description** Read the minimum input signal width at high level for a specified counter/frequency module.

**Syntax** **\$AA0H(cr)**

**\$** is a delimiter character.

**AA** (range 00-FF) represents the 2-character hexadecimal address that you will access to.

**0H** is the Read Minimum Input Signal Width at High Level command.

**(cr)** is the terminating character, carriage return (0Dh).

**Response** **!AA(data)(cr)** if the command is valid.

**?AA(cr)** if an invalid operation was entered.

There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.

**!** is a delimiter character which indicates a valid command.

**?** is a delimiter character which indicates an invalid command.

**AA** (range 00-FF) represents the 2-character hexadecimal address of the module.

**(data)** is the minimum width at high level. The unit is in  $\mu\text{sec}$  (microseconds) and its resolution is 1  $\mu\text{sec}$ . The format is a five digit integer that ranges from 2  $\mu\text{sec}$  to 65535  $\mu\text{sec}$ .

**(cr)** is the terminating character, carriage return (0Dh).

**Example** command: \$130H(cr)

response: !130020(cr)

The command requests the counter/frequency module at address 13 to read its minimum input signal width at high level. The module replies that its minimum input signal width at high level is 20  $\mu\text{sec}$ .

**\$AA0L(data)**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Minimum Input Signal Width at Low Level command   |
| <b>Description</b> | Set the minimum input signal width at low level for a specified counter/frequency module to filter noise.   |
| <b>Syntax</b>      | <p><b>\$AA0L(data)(cr)</b><br/> <b>\$</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br/> <b>0L</b> is the Set Minimum Input Signal Width at Low Level command.<br/> <b>(data)</b> is the minimum width at low level. The unit is in <math>\mu\text{sec}</math> (microseconds) and its resolution is 1 <math>\mu\text{sec}</math>. The format is a five digit integer that can range from 2 <math>\mu\text{sec}</math> to 65535 <math>\mu\text{sec}</math>. Out of range values will cause errors.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid. The addressed module stores the value and will identify the input signal "low" only if the input signal continues to be "low" longer than the specified time.<br/> <b>?AA(cr)</b> if an invalid operation was entered.<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>?</b> is a delimiter character which indicates an invalid command.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$050L00084(cr)<br/> response: !05(cr)<br/> The command requests the counter/frequency module at address 05 to set the minimum input width at low level to 84 <math>\mu\text{sec}</math>. The module stores the value and will identify an input signal to be "low" only if the signal continues to be "low" longer than 84 <math>\mu\text{sec}</math>. This function can be used as digital filter.</p>  |

**\$AA0L**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Minimum Input Signal Width at Low Level command  |
| <b>Description</b> | Read the minimum input signal width at low level for a specified counter/frequency module to filter noise.  |
| <b>Syntax</b>      | <p><b>\$AA0L(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>0L</b> is the Read Minimum Input Signal Width at Low Level command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the minimum width at low level. The unit is in <math>\mu\text{sec}</math> (microsecond) and its resolution is 1 <math>\mu\text{sec}</math>. The format is a five digit integer that ranges from 2 <math>\mu\text{sec}</math> to 65535 <math>\mu\text{sec}</math>.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$050L(cr)</p> <p>response: !0500084(cr)</p> <p>The command requests the counter/frequency module at address 05 to read its minimum input signal width at low level. The module replies that its minimum input signal width at low level is 84 <math>\mu\text{sec}</math>.</p>  |

**\$AA1H(data)**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Non-isolated High Trigger Level command  |
| <b>Description</b> | Set the high trigger level for non-isolated input signals for a specified counter/frequency module.  |
| <b>Syntax</b>      | <p><b>\$AA1H(data)(cr)</b><br/> <b>\$</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.<br/> <b>1H</b> is the Set Non-isolated High Trigger Level command.<br/> <b>(data)</b> is the high trigger level for non-isolated input<br/> The unit and resolution are both 0.1 V (voltage). The format is a two digit integer that range from 1 to 50 (i.e. 0.1 to 5 V). This high trigger level must at all times be higher than the low trigger level which is set by the \$AA1L(data) command. When the high trigger level is out of range or lower than the low trigger level, an error will occur.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid. The addressed module stores the value and will recognize input signal as “high” only when they exceed the high trigger level<br/> <b>?AA(cr)</b> if an invalid operation was entered.<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>?</b> is a delimiter character which indicates an invalid command.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: \$131H30(cr)<br/> response: !13(cr)<br/> The command requests the counter/frequency module at address 13 to set its non-isolated high trigger level to 3 V. The module stores the value and will identify the input signals to be “high” only after the signals exceed 3 V. This function can be used as a level filter.</p>   |

**\$AA1H**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Non-isolated High Trigger Level command   |
| <b>Description</b> | Read the high trigger level for non-isolated input signals of a specified counter/frequency module.  |
| <b>Syntax</b>      | <p><b>\$AA1H(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>1H</b> is the Read Non-isolated High Trigger Level command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the high trigger level of non-isolated input signals. The unit and resolution are both 0.1 V (voltage). The format is a two digit integer that range from 1 to 50 (i.e. 0.1 V to 5 V).</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$131H(cr)</p> <p>response: !1330(cr)</p> <p>The command requests the counter/frequency module at address 13 to read its non-isolated high trigger level. The module replies that the high trigger level is 3 V.</p>   |



**\$AA1L(data)**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Non-isolated Low Trigger Level command  |
| <b>Description</b> | Set the low trigger level of non-isolated input signals for a specified counter/frequency module.   |
| <b>Syntax</b>      | <p><b>\$AA1L(data)(cr)</b><br/> <b>\$</b> is a delimiter character.<br/> <b>AA (range 00-FF)</b> represents the 2-character hexadecimal address that you will access to.<br/> <b>1L</b> is the Set Non-isolated Low Trigger Level command.<br/> <b>(data)</b> is the low trigger level for non-isolated input signals. The unit and resolution is 0.1 V (voltage). The format is a two digit integer that can range from 1 to 50 (i.e. 0.1 to 5 V). This low trigger level must at all times be lower than the high trigger level, set by \$AA1H(data) command. When the low trigger level is out of range or higher than the high trigger level an error will occur.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid. The addressed module stores the value and will identify input signal as “low” only when it exceeds the low trigger level<br/> <b>?AA(cr)</b> if an invalid operation was entered.<br/> There is no response if the module detects a syntax or communication error, or if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>?</b> is a delimiter character which indicates an invalid command.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: \$051L08(cr)<br/> response: !05(cr)<br/> The command requests the counter/frequency module at address 05 to set its non-isolated low trigger level to 0.8 V. The module stores the value and will identify the TTL input signal to be “low” only if the signal exceeds 0.8 V. This function can be used as a level filter.</p>  |

**\$AA1L**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Read Non-isolated Low Trigger Level command  |
| <b>Description</b> | Read the low trigger level for non-isolated input signals of a specified counter/frequency module.   |
| <b>Syntax</b>      | <p><b>\$AA1L(cr)</b></p> <p><b>\$</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address that you will access to.</p> <p><b>1L</b> is the Read Non-isolated Low Trigger Level command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p><b>?AA(cr)</b> if an invalid operation was entered.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>?</b> is a delimiter character which indicates an invalid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the low trigger level of non-isolated input signal. The unit and resolution is 0.1 V (voltage). The format is a two digit integer that can range from 1 to 50 (i.e. 0.1 V to 5 V).</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: \$051L(cr)</p> <p>response: !0508(cr)</p> <p>The command requests the counter/frequency module at address 05 to read its non-isolated input signal low trigger level. The module replies that its low trigger level is 0.8 V.</p>  |

## 7.2.4 Digital Output and Alarm Command Set

| Command Syntax | Command Name                          | Description   | I/O Module     |
|----------------|---------------------------------------|---|----------------|
| @AAPN(data)    | Set Initial Count Value of Counter N  | Sets the initial count value of the module for counter 0 or counter 1                                       | 4080           |
| @AAGN          | Read Initial Count Value of Counter N | Read the initial count value of counter 0 or counter 1  | 4080           |
| @AAEAN         | Enable Alarm of Counter N             | Enable alarm for the specified counter 0 or counter 1   | 4080           |
| @AADAN         | Disable Alarm of Counter N            | Disable alarm for the specified counter 0 or counter 1  | 4080           |
| @AAPA(data)    | Set Alarm Limit Value of Counter 0    | Download the alarm limit value for counter 0 of the specified module  | 4080           |
| @AASA(data)    | Set Alarm Limit Value of Counter 1    | Download the alarm limit value for counter 1 of the specified module  | 4080           |
| @AARP          | Read Alarm Limit Value of Counter 0   | Ask the module to return the alarm limit value of counter 0   | 4080           |
| @AARA          | Read Alarm Limit Value of Counter 1   | Ask the module to return the alarm limit value of counter 1   | 4080           |
| @AADO(data)    | Set Digital Output Values             | Set the values of the module's two digital outputs (ON or OFF)  | 4080,<br>4080D |
| @AADI          | Read Digital Output and Alarm Status  | Ask the addressed module to return the state of its two digital output channels and the status of its alarm | 4080,<br>4080D |

(Continued on next page)

---

| Command Syntax | Command Name                              | Description  | I/O Module |
|----------------|---|--|------------|
| @AAEAT         | Enable Alarm of Counter 0                 | Enable the alarm of counter 0 in either momentary or latching modes                      | 4080D      |
| @AADA          | Disable Alarm of Counter 0                | Disable all alarm functions of counter 0   | 4080D      |
| @ACA           | Clear Latch Alarm                         | Both alarm states of the counter are set to OFF, no alarm                                | 4080D      |
| @AAPA(data)    | Set Low-Alarm Count Value of Counter 0    | Downloads the low-alarm count value for counter 0 of the specified module                | 4080D      |
| @AASA(data)    | Set High-Alarm Count Value of Counter 0   | Downloads the high-alarm count value for counter 0 of the specified module               | 4080D      |
| @AARP          | Read Low-Alarm Count Value of Counter 0   | Ask the module to return the low-alarm count value for counter 0                         | 4080D      |
| @AARA          | Read High-alarm Count Value for Counter 0 | Requests the addressed counter module to return its high-alarm count value of counter 0. | 4080D      |

**@AAPN(data)**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Set Initial Count Value of Counter 0 or 1 command   |
| <b>Description</b> | Set the initial count value for counter 0 or 1 of the specified counter module at address AA.   |
| <b>Syntax</b>      | <p><b>@AAPN(data)(cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>PN</b> is the Set Initial Count Value of Counter 0 or 1 command.</p> <p>N = 0 represents counter 0</p> <p>N = 1 represents counter 1</p> <p><b>(data)</b> is the initial count value which must consist of eight hexadecimal digits.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Example</b>     | <p>command: @12P000000FF(cr)</p> <p>response: !12(cr)</p> <p>The command sets the initial count value 000000FF for counter 0 of the counter module at address 12. The module replies that the command has been received.</p>  |

**@AAGN**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Initial Count Value of Counter 0 or 1 command  |
| <b>Description</b> | Read the initial count value of counter 0 or 1 of the specified counter module at address AA.   |
| <b>Syntax</b>      | <p><b>@AAGN(data)(cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>GN</b> is the Read Initial Count Value for Counter 0 or 1 command.</p> <p>N = 0 represents counter 0</p> <p>N = 1 represents counter 1</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the initial count value which must consist of eight hexadecimal digits.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @12G0(cr)</p> <p>response: !1200000FF(cr)</p> <p>The command instructs the module at address 12h to return the initial value of counter 0. The module replies that initial count value of counter 0 is 000000FF.</p>  |

**@AAEAN**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Enable Alarm command  |
| <b>Description</b> | Enable Alarm for the specified counter.   |
| <b>Syntax</b>      | <p><b>@AAEAN (cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>EAN</b> is the Enable Alarm command.</p> <p>N = 0 Represents counter 0</p> <p>N = 1 Represents counter 1</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @12EA0(cr)</p> <p>response: !12(cr)</p> <p>The command sets the Alarm Status as 'Enable' for counter 0 of the counter module at address 12h. It means that the digital output will be triggered while the count value of the counter 0 reaches the alarm limit value. The module replies that the command has been received.</p>  |

**@AADAN**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Disable Alarm command   |
| <b>Description</b> | Disable Alarm for the specified counter.  |
| <b>Syntax</b>      | <p><b>@AADAN (cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>DAN</b> is the Disable Alarm Mode command.</p> <p><b>N = 0</b> Represents counter 0</p> <p><b>N = 1</b> Represents counter 1</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of a counter module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: <b>@12DA0(cr)</b></p> <p>response: <b>!12(cr)</b></p> <p>The counter module at address 12h is instructed to disable the alarm functions for counter 0. The module confirms that its alarm functions have been disabled.</p>   |



**@AAPA(data)****@AASA(data)**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Alarm Limit Value of Counter 0 or 1 command  |
| <b>Description</b> | Set the Alarm limit value of counter 0 or 1 of the specified counter module at address AA.   |
| <b>Syntax</b>      | <p><b>@AAPA(data)(cr)</b><br/> <b>@AASA(data)(cr)</b><br/> <b>@</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>PA</b> represents the Set Alarm Limit value for counter 0 command.<br/> <b>SA</b> represents the Set Alarm Limit Value for counter 1 command.<br/> <b>(data)</b> is the alarm limit value which must consist of eight hexadecimal digits.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Example</b>     | <p>command: @\$12PA0000FFFF(cr)<br/> response: !12(cr)</p> <p>The command sets the alarm limit value 0000FFFF for counter 0 of the counter module at address 12h. The module replies that the command has been received.</p>   |

**@AARP****@AARA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Alarm Limit Value of Counter 0 or 1 command  |
| <b>Description</b> | Read the alarm limit value of counter 0 or 1 of the specified counter module at address AA.   |
| <b>Syntax</b>      | <p><b>@AARP(data)(cr)</b></p> <p><b>@AARA(data)(cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>RP</b> represents the Read Alarm Limit Value for counter 0 command.</p> <p><b>RA</b> represents the Read Alarm Limit Value for counter 1 command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the alarm limit value which must consist of eight hexadecimal digits.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: <b>@12RP(cr)</b></p> <p>response: <b>!120000FFFF(cr)</b></p> <p>The command instructs the module at address 12h to return the alarm limit value of counter 0. The module replies that the alarm limit value of counter 0 is 0000FFFF.</p>   |

**@AADO**

|                    |   |    |                      |    |                           |    |                           |    |                 |
|--------------------|---|----|----------------------|----|---------------------------|----|---------------------------|----|-----------------|
| <b>Name</b>        | Set Digital Output command  |    |                      |    |                           |    |                           |    |                 |
| <b>Description</b> | Set the values of the module's two digital outputs (ON or OFF).   |    |                      |    |                           |    |                           |    |                 |
| <b>Syntax</b>      | <p><b>@AADO(data)(cr)</b><br/> <b>@</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>DO</b> is the Set Digital Output command.<br/> <b>(data)</b> is the two-character parameter that sets the state for the two digital output bits of the module, as shown below:</p> <table> <tr> <td>00</td> <td>all D/O bits are OFF</td> </tr> <tr> <td>01</td> <td>bit 0 is ON, bit 1 is OFF</td> </tr> <tr> <td>02</td> <td>bit 0 is OFF, bit 1 is ON</td> </tr> <tr> <td>03</td> <td>all bits are ON</td> </tr> </table> <p><b>(cr)</b> represents terminating character, carriage return (0Dh).</p> | 00 | all D/O bits are OFF | 01 | bit 0 is ON, bit 1 is OFF | 02 | bit 0 is OFF, bit 1 is ON | 03 | all bits are ON |
| 00                 | all D/O bits are OFF  |    |                      |    |                           |    |                           |    |                 |
| 01                 | bit 0 is ON, bit 1 is OFF   |    |                      |    |                           |    |                           |    |                 |
| 02                 | bit 0 is OFF, bit 1 is ON   |    |                      |    |                           |    |                           |    |                 |
| 03                 | all bits are ON   |    |                      |    |                           |    |                           |    |                 |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid<br/> <b>?AA(cr)</b> if an invalid parameter was entered<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.<br/> <b>?</b> is a delimiter character which indicates an invalid command.<br/> <b>AA</b> represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> represents terminating character, carriage return (0Dh).</p>  |    |                      |    |                           |    |                           |    |                 |
| <b>Example</b>     | <p>command: @05DO01(cr)<br/> response: !05(cr)</p> <p>The counter module at address 05h is instructed to set digital output channel 1 to ON and digital output channel 2 to OFF. The module confirms the settings.</p>  |    |                      |    |                           |    |                           |    |                 |

**@AADI**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Digital Output and Alarm State command   |
| <b>Description</b> | The addressed counter module is instructed to return the value of its two digital output channels and the state of its alarm.   |
| <b>Syntax</b>      | <p><b>@AADI(cr)</b><br/> <b>@</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>DI</b> is the Read Digital Output and Alarm Status command.<br/> <b>(cr)</b> represents terminating character, carriage return (0Dh).</p>  |
| <b>Response</b>    | <p><b>!AASOO00(cr)</b> if the command was valid<br/> There is no response if the module detects a syntax error or communication error or if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.<br/> <b>AA</b> represents the 2-character hexadecimal address of the module.<br/> <b>S (for ADAM-4080)</b> is a hexadecimal number that represents the disable or enable status of alarm mode:<br/> 0h: Counter 0 alarm is disabled, counter 1 alarm is disabled<br/> 1h: Counter 0 alarm is enabled, counter 1 alarm is disabled<br/> 2h: Counter 0 alarm is disabled, counter 1 alarm is enabled<br/> 3h: Counter 0 alarm is enabled, counter 1 alarm is enabled<br/> <b>S (for ADAM-4080D)</b> is a hexadecimal number that represents the alarm state of counter 0:<br/> 0h: Alarm of counter 0 is disabled<br/> 1h: Alarm of counter 0 is in MOMENTARY mode<br/> 2h: Alarm of counter 0 is in LATCH mode<br/> <b>OO</b> is a hexadecimal number representing the Digital Output port's channel 0 and 1 status<br/> (00h = D/0 channels 0 and 1 are both OFF, 01h = channel 0 is ON, channel 1 is OFF, 02h = channel 0 is OFF, channel 1 is ON, 03h = channel 0 and 1 are both ON).<br/> <b>(cr)</b> represents the terminating character, carriage return (0Dh).</p> |

**@AADI****Example**

command: @15DI(cr)

response: !1510000(cr)

The counter module at address 15h is instructed to return digital output data and alarm status. The module responds that both digital output channels are OFF and alarm state is MOMENTARY.

command: @05DI(cr)

response: !0530000(cr)

The counter module at address 05H is instructed to return digital output and alarm status. The module responds that both digital output channels are OFF and the alarm status for both counters are ENABLED.

**@AAEAT**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Enable Alarm command   |
| <b>Description</b> | The counter module is instructed to enable its alarm for counter 0 in either Latching or Momentary mode.   |
| <b>Syntax</b>      | <p><b>@AAEAT(cr)</b><br/> <b>@</b> is a delimiter character.<br/> <b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br/> <b>E</b> is the Enable Alarm command.<br/> <b>T</b> indicates the alarm type and can have the value M = Momentary alarm state, or L = Latching alarm state.<br/> <b>(cr)</b> represents terminating character, carriage return (0Dh).</p>         |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command was valid<br/> There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br/> <b>!</b> is a delimiter character which indicates a valid command.<br/> <b>AA</b> represents the 2-character hexadecimal address of the module.<br/> <b>(cr)</b> represents terminating character, carriage return (0Dh)</p> |
| <b>Example</b>     | <p>command: @03EAL(cr)<br/> response: !03(cr)</p> <p>The counter module at address 03h is instructed to enable its alarm for counter 0 in Latching mode.<br/> The module confirms that the command has been received.</p>  |

**NOTICE:** *A counter module requires a maximum of two seconds after it has received an Enable Alarm command to let the settings take effect. During this time, the module can not be addressed to perform any other actions.*

**@AADA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Disable Alarm command   |
| <b>Description</b> | Disable all alarm functions for counter 0 of the addressed counter module.  |
| <b>Syntax</b>      | <b>@AADA(cr)</b><br><b>@</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>DA</b> is the Disable Alarm command.<br><b>(cr)</b> represents terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command.<br><b>AA</b> represents the 2-character hexadecimal address of the module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: @07DA(cr)<br>response: !07(cr)<br>The counter module at address 07h is instructed to disable all alarm functions for channel 0. The module confirms by disabling the alarm functions.  |

**NOTICE:** *A counter module requires a maximum of two seconds after it has received a Disable Alarm command before the settings take effect. During this interval, the module cannot be addressed to perform any other actions.*

**@AACA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Clear Latch Alarm command   |
| <b>Description</b> | Both alarm states (High and Low) of the addressed counter module are set to OFF, no alarm.  |
| <b>Syntax</b>      | <b>@AACA(cr)</b><br><b>@</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>CA</b> is the Clear Latch Alarm command.<br><b>(cr)</b> represents terminating character, carriage return (0Dh).  |
| <b>Response</b>    | <b>!AA(cr)</b> if the command was valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command.<br><b>AA</b> represents the 2-character hexadecimal address of the module.<br><b>(cr)</b> represents terminating character, carriage return (0Dh). |
| <b>Example</b>     | command: <b>@05CA(cr)</b><br>response: <b>!05(cr)</b><br><br>The counter module at address 05h is instructed to set both alarm states (High and Low) to OFF. The module confirms that it has done so.   |



**@AAPA(data)**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Low-alarm Count Value for Counter 0 command  |
| <b>Description</b> | Set the low-alarm count value for counter 0 of the specified counter module.   |
| <b>Syntax</b>      | <b>@AAPA(data)(cr)</b><br><b>@</b> is a delimiter character.<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>PA</b> is the Set Low-alarm Count Value for Counter 0 command.<br><b>(data)</b> is the low-alarm count value which must consist of eight hexadecimal digits. This value should be lower than the high alarm value.<br><b>(cr)</b> is the terminating character, carriage return (0Dh). |
| <b>Response</b>    | <b>!AA(cr)</b> if the command is valid.<br>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.<br><b>!</b> is a delimiter character which indicates a valid command<br><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.<br><b>(cr)</b> is the terminating character, carriage return (0Dh).  |
| <b>Example</b>     | command: @12PA0000FFFF(cr)<br>response: !12(cr)<br>The command sets the low-alarm count number 0000FFFF(hex) for channel 0 of the counter modules at address 12. The addressed module replies that the command has been received.  |

**@AASA(data)**

|                    |  |
|--------------------|--|
| <b>Name</b>        | Set Hi-alarm Count Value of Counter 0 command  |
| <b>Description</b> | Set the high-alarm count value for counter 0 of the specified counter module.  |
| <b>Syntax</b>      | <p><b>@AASA(data)(cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>SA</b> is the Set High-alarm Count Value of Counter 0 command.</p> <p><b>(data)</b> is the high-alarm count value which must consist of eight hexadecimal digits. This value should be higher than the low-alarm count value.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Response</b>    | <p><b>!AA(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>  |
| <b>Example</b>     | <p>command: @12SAF0000000(cr)</p> <p>response: !12(cr)</p> <p>The command sets the low-alarm count number F0000000(hex) for channel 0 of the counter modules at address 12. The addressed module replies that the command has been received.</p>   |

**@AARP**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read Low-alarm Count Value of Counter 0 command   |
| <b>Description</b> | Read the low-alarm value of counter 0 of the specified counter module.  |
| <b>Syntax</b>      | <p><b>@AARP(cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>RP</b> is the Read Low-alarm Count Value of Counter 0 command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character indicating a valid command</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the low-alarm count value which consists of eight hexadecimal digits.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: @12RP(cr)</p> <p>response: !120000FFFF(cr)</p> <p>The command instructs the module at address 12 to return its low-alarm count value. The module replies that counter 0's low-alarm count value is 0000FFFF(hex).</p>   |

**@AARA**

|                    |   |
|--------------------|---|
| <b>Name</b>        | Read High-alarm Count Value for Counter 0   |
| <b>Description</b> | Requests the addressed counter module to return its high-alarm count value of counter 0.  |
| <b>Syntax</b>      | <p><b>@AARA(cr)</b></p> <p><b>@</b> is a delimiter character.</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>RA</b> is the Read High-alarm Count Value for Counter 0 command.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p>   |
| <b>Response</b>    | <p><b>!AA(data)(cr)</b> if the command is valid.</p> <p>There is no response if the module detects a syntax or communication error, or even if the specified address does not exist.</p> <p><b>!</b> is a delimiter character which indicates a valid command</p> <p><b>AA</b> (range 00-FF) represents the 2-character hexadecimal address of the module.</p> <p><b>(data)</b> is the high-alarm count value which consists of eight hexadecimal digits.</p> <p><b>(cr)</b> is the terminating character, carriage return (0Dh).</p> |
| <b>Example</b>     | <p>command: <b>@12RA(cr)</b></p> <p>response: <b>!12F000000(cr)</b></p> <p>The command instructs the module at address 12 to return its high-alarm count value. The module replies that counter 0's high-alarm count value is F0000000(hex).</p>  |

Calibration

8

# Calibration

---


Analog input/output modules are calibrated when you receive them. However, calibration is sometimes required. No screwdriver is necessary because calibration is done in software. Calibration parameters are stored in the ADAM module's onboard EEPROM.

The ADAM modules come with utility software that supports the calibration of analog input and analog output. Aside from the calibration that is carried out through software, the modules incorporate automatic Zero Calibration and automatic Span Calibration at boot-up or reset.

## 8.1 Analog Input Module Calibration


**Models: ADAM-4011, 4011D, 4012, 4016, 4017, 4017+, 4018, 4018+, 4018M, 4019+**

1. **Set modules as initial mode before applying** power to the module and let it warm up for about 30 minutes
2. Assure that the module is correctly installed and is properly configured for the input range that you want to calibrate. You can do this by using the ADAM utility software. (Please refer to Appendix D, Utility Software.)
3. Use a precise voltage source to calibrate the module through +IN and -IN terminals for ADAM-4011, 4011D and 4012. However, for ADAM-4016, the calibrating voltage should be applied to terminals Vin+ and Vin- (or Iin+ and Iin-). At last, Vin0+ and Vin0- are used for calibration in ADAM-4017, 4017+, 4018, 4018+, 4018M, 4019 and 4019+ models.




**Figure 8-1** *Applying Calibration Voltage*

- Execute the Offset Calibration command. This is also done through the ADAM utility software. (Please see “Offset Calibration” option in the Calibration sub-menu of the ADAM utility software).



**Figure 8-2 Zero Calibration**


- Execute the Span Calibration command. This can be done through the ADAM utility software. (Please see “Span Calibration” option in the Calibration sub-menu of the ADAM utility software).



**Figure 8-3 Span Calibration**

# Calibration

- This step is only for ADAM 4011, 4011D, 4018, 4018+, 4018M, 4019, 4019+. Execute the CJC (cold junction sensor) calibration command. This is also done through the ADAM utility software. (Please see “CJC Calibration” option in the Calibration sub-menu of the ADAM utility software).




**Figure 8-4 Cold Junction Calibration**



## 8.2 Analog Input Resistance Calibration

### Model: ADAM-4013

1. Apply power to the module and let it warm up for about 30 minutes.
2. Assure that the module is correctly installed and is properly configured for the input range that you want to calibrate. You can do this by using the ADAM utility software. (Please refer to Appendix D, Utility Software.)
3. Apply the reference Span resistance to the screw terminals using a 4-wire connection. Please refer to Figure 8-5 for the correct wiring diagram and Table 8-2 for the right Span calibration resistance).



**Figure 8-5** Applying calibration resistance

- Use a precision resistance decade box or discrete resistors with values: 10 W, 15 W, 60 W, 140 W, 200 W and 440 W.
4. Apply the reference Offset resistance to the terminals of the module. (Please refer to Figure 8-5 for the correct wiring diagram and Table 8-2 for the right Offset calibration resistance.)
  5. Issue an Offset Calibration command to the module. This can be done by using the Calibrate option in the ADAM utility software (Please see Appendix D, Utility Software)
  6. Issue a Span Calibration command to the module. This can be done through the Calibrate option in the ADAM utility software (Please see Appendix D, Utility Software)

## Calibration

---

**Table 8-2 Calibration Resistance**


| Module I | nput Range Code (Hex) | Input Range                     | Span Calibration Resistance | Offset Calibration Resistance |
|----------|-----------------------|---------------------------------|-----------------------------|-------------------------------|
| 4013 2   | 0                     | Pt, -100~100 °C<br>a = 0.00385  | 140 Ω 60                    | Ω                             |
|          | 21                    | Pt, 0~100 °C<br>a = 0.00385     | 140 Ω 60                    | Ω                             |
|          | 22                    | Pt, 0~200 °C<br>a = 0.00385     | 200 Ω 60                    | Ω                             |
|          | 23                    | Pt, 0~600 °C<br>a = 0.00385     | 440 Ω 60                    | Ω                             |
|          | 24                    | Pt, -100~100 °C<br>a = 0.003916 | 140 Ω 60                    | Ω                             |
|          | 25                    | Pt, 0~100 °C<br>a = 0.003916    | 140 Ω 60                    | Ω                             |
|          | 26                    | Pt, 0~200 °C<br>a = 0.003916    | 200 Ω 60                    | Ω                             |
|          | 27                    | Pt, 0~200 °C<br>a = 0.003916    | 440 Ω 60                    | Ω                             |
|          | 28                    | Ni, -80~100 °C                  | 200 Ω 60                    | Ω                             |
|          | 29                    | Ni, 0~100 °C                    | 200 Ω 60                    | Ω                             |

### 8.3 Analog Input Thermistor module Calibration


#### Model: ADAM-4015T

If you select the range “Thermistor 3K 0~100C”, please follow the calibration steps as below.

1. Short the INIT\* pin to GND and then power up ADAM-4015T. Run ADAM-4000-5000 Utility and search for the module.




2. Click on “Lead Wire Effect Compensation”




# Calibration


3. Set the resistance to “0” and click on “Save”




4. Click on “Zero Cal.”




5. Apply 200.0 ohms resistor with 0.01% accuracy to CH0 and then Click on “Save”



- Click on “Span Cal.”



- Apply 10K ohm s r resistor with 0.01 % accuracy to CH0 and then Click on “Save”




- Finished!


# Calibration

If you select the range “Thermistor 10K 0~100C”, please follow the calibration steps as below.


1. Change the input range to “Thermistor 10K 0~100C” and click on “Update”




2. Click on “Lead Wire Effect Compensation”




- Set the resistance to “0” and click on “Save”



- Click on “Zero Cal.”




- Apply 800.0 ohms resistor with 0.01% accuracy to CH0 and then Click on “Save”




# Calibration

6. Click on “Span Cal.”



7. Apply 30K ohm's resistor with 0.01 % accuracy to CH0 and then Click on “Save”



8. Finished!




## 8.4 Analog Output Calibration

### Model: ADAM-4021/4024

The output current of analog output modules can be calibrated by using a low and high calibrating value. The analog output modules can be configured in one of the two ranges, 0-20 mA and 4-20 mA. Since the low limit of the 0 - 20 mA ranges, 0 mA, is an absolute reference (no power, or immeasurably small power). However, just two levels, 4 mA and 20 mA, are needed for calibration.

1. Apply power to the analog output module and let it warm up for about 30 minutes.
2. Assure that the module is correctly installed, and its configuration is according to your specifications. It should match the output range that you want to calibrate. You can do this by using the ADAM utility software. (Please refer to Appendix D, Utility Software.)
3. Connect either a 5-digit millimeter or voltmeter with a shunt resistor ( $250\Omega$ , 0.01% , and 10ppm) to the screw terminals of the module



**Figure 8-6 Setup for Analog Output Calibration**


## Calibration

---

4. Issue the Analog Data Out command to the module with an output value of 4 mA.
5. Check the actual output value at the terminals. If it does not equal to 4 mA, use the “Trim” option in the “Calibrate” submenu to change the actual output. Trim the module until the millimeter indicates exactly 4 mA. In the case of using a voltage meter with shunt resistor, the voltage meter should indicate exactly 1 V. (When calibrating for 20 mA using voltage meter and shunt resistor, the correct voltage would be 5 V.)
6. Issue the 4 mA Calibration command to indicate that the output is calibrated. The calibrated parameters should be stored in the module's EEPROM.
7. Execute an Analog Data Out command with an output value of 20 mA, and the output will approximately be 20 mA.
8. Continue executing the Trim Calibration command until the output current is equal to exactly 20 mA.
9. Execute the 20 mA Calibration command until the present output is exactly 20 mA. The analog output module will store its calibrated parameters in EEPROM.


**Module: ADAM-4016**

1. Apply power to the strain gauge input module and let it warm up for about 30 minutes.
2. Assure that the module is correctly installed. Then, connect a voltmeter to the screw terminals of the module.



**Figure 8-7 Setup for Voltage Output Calibration**


3. Execute the Zero Calibration command. This is done through the ADAM utility software. (Please see "A/O 0V Calibration" option in the Calibration sub-menu of the ADAM utility software.)



**Figure 8-8 Zero Calibration**

# Calibration

- Execute the Span Calibration command. This can be done through the ADAM utility software. (Please see "A/O 10 V Calibration" option in the Calibration sub-menu of the ADAM utility software.)



**Figure 8-9 Span Calibration**

- Check the actual output value at the terminals. If this does not equal 0 V or 10 V, use the Trim Calibration command to change the output value. This is done through the ADAM utility software. (Use the arrow key to adjust the output value after executing the "A/O 0V Calibration" or "A/O 10 V Calibration". Right and Up keys mean increasing, and Left and Down keys mean decreasing).

Technical Specifications

A

## Technical Specifications

---

### A.1 ADAM-4011 Thermocouple Input Module

**Table A-1 ADAM-4011 Specifications**


|  |  |
|--|--|
| T/C channel number   | 1  |
| Input range  | J, K, T, E, R, S and B Thermocouple<br>$\pm 15$ mV, $\pm 50$ mV, $\pm 100$ mV, $\pm 500$ mV,<br>$\pm 1$ V, $\pm 2.5$ V and $\pm 20$ mA |
| Output speed (in bps)  | RS-485 (2-Wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K  |
| Maximum distance   | 4000 ft. (1200 m.)   |
| Accuracy   | $\pm 0.05\%$ or better   |
| Zero drift   | $\pm 6\mu\text{V}/^\circ\text{C}$  |
| Span drift   | $\pm 25$ ppm/ $^\circ\text{C}$   |
| Isolation-rated voltage  | 3000 V <sub>DC</sub>   |
| CMR @ 50/60 Hz   | 150 dB   |
| NMR @ 50/60 Hz   | 100 dB   |
| Resolution   | 16-bit   |
| Sampling rate  | 10 samples/second  |
| Input impedance  | Voltage: 2 M $\Omega$ , Current: 125 $\Omega$  |
| Digital output<br>Sink current<br>Power dissipation                | 2 channels open collector to 30 V<br>30 mA maximum load<br>300 mW  |
| Digital input<br>Logic level 0<br>Logic level 1<br>Pull up current | 1 channel<br>+1 V maximum<br>+3.5 to +30 V<br>0.5 mA   |
| Event counter<br>Max. input frequency<br>Min. pulse width          | 50 Hz<br>1 msec  |
| Support protocol   | ADAM ASCII   |
| Watchdog timer   | 1.6 second (System)  |
| Power supply   | +10 to +30 V <sub>DC</sub> (non-regulated)   |
| Power consumption  | 1.4 W @ 24 V <sub>DC</sub>   |
| Burn-out detection   | Yes  |

**Table A-2 ADAM-4011 Range Accuracy for Thermocouple**

| Input Range Code (Hex) | Input Range                      | Typical Accuracy | Maximum Error | Units |
|------------------------|----------------------------------|------------------|---------------|-------|
| 0E                     | J thermocouple<br>0 to 760 °C    | ±0.5             | ±0.75         | °C    |
| 0F                     | K thermocouple<br>0 to 1370 °C   | ±0.5             | ±0.75         | °C    |
| 10                     | T thermocouple<br>-100 to 400 °C | ±0.5             | ±0.75         | °C    |
| 11                     | E thermocouple<br>0 to 1000 °C   | ±0.5             | ±0.75         | °C    |
| 12                     | R thermocouple<br>500 to 1750 °C | ±0.6             | ±1.5          | °C    |
| 13                     | S thermocouple<br>500 to 1750 °C | ±0.6             | ±1.5          | °C    |
| 14                     | B thermocouple<br>500 to 1800 °C | ±1.2             | ±2.0          | °C    |

# Technical Specifications

Figure A-1 ADAM-4011 Function Diagram





## A.2 ADAM-4011D Thermocouple Input Module with LED Display

**Table A-3 ADAM-4011D Specifications**

|                         |   |
|-------------------------|---|
| T/C channel number      | 1   |
| Input range             | J, K, T, E, R, S and B Thermocouple<br>±15 mV, ±50 mV, ±100 mV, ±500mV,<br>±1 V, ±2.5 V and ±20mA |
| Output speed (in bps)   | RS-485 (2-Wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K                         |
| Maximum distance        | 4000 ft. (1200 m.)  |
| Accuracy                | ±0.05% or better  |
| Zero drift              | ±6 $\mu\text{V}/^\circ\text{C}$   |
| Span drift              | ±25 ppm/ $^\circ\text{C}$   |
| Isolation-rated voltage | 3000 V <sub>DC</sub>  |
| CMR @ 50/60 Hz          | 150 dB  |
| NMR @ 50/60 Hz          | 100 dB  |
| Resolution              | 16-bit  |
| Sampling rate           | 10 samples/second   |
| Input impedance         | Voltage: 2 M $\Omega$ , Current: 125 $\Omega$   |
| LED indicator           | 5 digit readout   |
| Digital output          | 2 channels open collector to 30 V   |
| Sink current            | 30 mA maximum load  |
| Power dissipation       | 300 mW  |
| Digital input           | 1 channel   |
| Logic level 0           | +1 V maximum  |
| Logic level 1           | +3.5 to +30 V   |
| Pull up current         | 0.5 mA  |
| Event counter           |   |
| Max. input frequency    | 50 Hz   |
| Min. pulse width        | 1 msec  |
| Support protocol        | ADAM ASCII  |
| Watchdog timer          | 1.6 second (System)   |
| Power supply            | +10 to +30 V <sub>DC</sub> (non-regulated)  |
| Power consumption       | 1.4 W @ 24 V <sub>DC</sub>  |
| Burn-out detection      | Yes   |


## Technical Specifications

---

**Table A-4 ADAM-4011D Range Accuracy for Thermocouple**

| Input Range Code (Hex) | Input Range                      | Typical Accuracy | Maximum Error | Units |
|------------------------|----------------------------------|------------------|---------------|-------|
| 0E                     | J thermocouple<br>0 to 760 °C    | ±0.5             | ±0.75         | °C    |
| 0F                     | K thermocouple<br>0 to 1370 °C   | ±0.5             | ±0.75         | °C    |
| 10                     | T thermocouple<br>-100 to 400 °C | ±0.5             | ±0.75         | °C    |
| 11                     | E thermocouple<br>0 to 1000 °C   | ±0.5             | ±0.75         | °C    |
| 12                     | R thermocouple<br>500 to 1750 °C | ±0.6             | ±1.5          | °C    |
| 13                     | S thermocouple<br>500 to 1750 °C | ±0.6             | ±1.5          | °C    |
| 14                     | B thermocouple<br>500 to 1800 °C | ±1.2             | ±2.0          | °C    |

Figure A-2 ADAM-4011D Function Diagram



## Technical Specifications


---

### A.3 ADAM-4012 Analog Input Module

**Table A-5 ADAM-4012 Specifications**

|  |  |
|--|--|
| AI channel number  | 1  |
| Input range  | $\pm 150$ mV, $\pm 500$ mV, $\pm 1$ V, $\pm 5$ V, $\pm 10$ V and $\pm 20$ mA |
| Output speed (in bps)  | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K, 57.6K, 115.2K       |
| Maximum distance   | 4000 ft. (1200 m.)   |
| Accuracy   | $\pm 0.05\%$ or better   |
| Zero drift   | $\pm 6$ $\mu$ V/ $^{\circ}$ C  |
| Span drift   | $\pm 25$ ppm/ $^{\circ}$ C   |
| Isolation-rated voltage  | 3000 V <sub>DC</sub>   |
| CMR @ 50/60 Hz   | 150 dB   |
| NMR @ 50/60 Hz   | 100 dB   |
| Resolution   | 16-bit   |
| Sampling rate  | 10 samples/second  |
| Input impedance  | Voltage: 20 M $\Omega$ , Current: 125 $\Omega$                               |
| Digital output<br>Sink current<br>Power dissipation                | 2 channels open collector to 30 V<br>30 mA maximum load<br>300 mW            |
| Digital input<br>Logic level 0<br>Logic level 1<br>Pull up current | 1 channel<br>+1 V maximum<br>+3.5 to +30 V<br>0.5 mA                         |
| Event counter<br>Max. input frequency<br>Min. pulse width          | <br>50 Hz<br>1 msec  |
| Support protocol   | ADAM ASCII   |
| Watchdog timer   | 1.6 second (System)  |
| Power supply   | +10 to +30 V <sub>DC</sub> (non-regulated)                                   |
| Power consumption  | 1.2 W @ 24 V <sub>DC</sub>   |

Figure A-3 ADAM-4012 Function Diagram



## Technical Specifications


---

### A.4 ADAM-4013 RTD Input Module

**Table A-6 ADAM-4013 Specifications**

|                         |   |
|-------------------------|---|
| RTD channel number      | 1   |
| Input type              | Pt or Ni RTD  |
| Output speed (in bps)   | RS-485 (2-Wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K |
| Maximum distance        | 4000 ft. (1200 m.)  |
| Accuracy                | $\pm 0.1\%$ or better   |
| Zero drift              | $\pm 3\mu\text{V}/^\circ\text{C}$   |
| Span drift              | $\pm 25\text{ ppm}/^\circ\text{C}$  |
| Input connections       | 2, 3 or 4 wires   |
| Isolation-rated voltage | 3000 V <sub>DC</sub>  |
| CMR @ 50/60 Hz          | 150 dB  |
| NMR @ 50/60 Hz          | 100 dB  |
| Sampling rate           | 10 samples/second   |
| Input impedance         | 2 M $\Omega$  |
| Support protocol        | ADAM ASCII  |
| Watchdog timer          | 1.6 second (System)   |
| Power supply            | +10 to +30 V <sub>DC</sub> (non-regulated)                                |
| Power consumption       | 0.7 W @ 24 V <sub>DC</sub>  |

Figure A-4 ADAM-4013 Function Diagram



## Technical Specifications

---


### A.5 ADAM-4016 Analog Input/Output Module

**Table A-7 ADAM-4016 Specifications**

|                             |  |
|-----------------------------|--|
| AI channel number           | 1  |
| AI range                    | $\pm 15$ mV, $\pm 50$ mV, $\pm 100$ mV, $\pm 500$ mV and $\pm 20$ mA   |
| Output Speed (bps)          | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K, 57.6K, 115.2K |
| Maximum distance            | 4000 ft. (1200 m)  |
| Input impedance             | Voltage: 2 M $\Omega$ , Current: 125 $\Omega$                          |
| AI isolation voltage        | 3000 V <sub>DC</sub>   |
| AI resolution               | 16-bit   |
| AI sampling rate            | 10 samples/second  |
| AI accuracy                 | $\pm 0.05\%$ or better   |
| AI zero drift               | $\pm 6$ $\mu$ V / $^{\circ}$ C   |
| AI span drift               | $\pm 25$ ppm/ $^{\circ}$ C   |
| AI CMR @ 50/60 Hz           | 150 dB   |
| AI NMR @ 50/60 Hz           | 100 dB   |
| AO channel number           | 1  |
| AO range                    | 0~10 V   |
| AO drive current            | 30 mA  |
| AO isolation voltage        | 3000 V <sub>DC</sub>   |
| AO accuracy                 | 0.05% of FSR   |
| AO drift                    | $\pm 50$ ppm/ $^{\circ}$ C   |
| Digital output Sink current | 4 channels open collector to 30 V<br>30 mA maximum load                |
| Power dissipation           | 300 mW   |
| Support protocol            | ADAM ASCII   |
| Watchdog timer              | 1.6 second (System)  |
| Power requirements          | +10 to +30 V <sub>DC</sub> (non-regulated)                             |
| Power consumption           | 2.2 W @ 24 V <sub>DC</sub>   |



Figure A-5 ADAM-4016 Function Diagram



## Technical Specifications


---

### A.6 ADAM-4017/4017+ 8-Channel Analog Input Module

**Table A-8 ADAM-4017/4017+ Specifications**

|                    |  |
|--------------------|--|
| AI channel number  | <b>ADAM-4017:</b><br>6 differential and 2 single-ended<br><b>ADAM-4017+:</b><br>8 differential   |
| Input type         | mV, V and mA   |
| Input range        | <b>ADAM-4017:</b><br>±150 mV, ±500 mV, ±1 V, ±5 V, ±10 V<br>and ±20 mA<br><b>ADAM-4017+:</b><br>±150 mV, ±500 mV, ±1 V, ±5 V, ±10 V,<br>±20 mA and 4~20 mA |
| Output speed (bps) | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K  |
| Maximum distance   | 4000 ft. (1200 m)  |
| Isolation voltage  | 3000 V <sub>DC</sub>   |
| Resolution         | 16-bit   |
| Sampling rate      | 10 samples/second (total)  |
| Bandwidth          | 13.1 Hz  |
| Accuracy           | ±0.1% or better  |
| Zero drift         | ±6 µV/°C   |
| Span drift         | ±25 ppm/°C   |
| CMR @ 50/60 Hz     | 120 dB   |
| NMR @ 50/60 Hz     | 100 dB   |
| Input impedance    | Voltage: 20 MΩ, Current: 120 Ω   |
| Support protocol   | ADAM ASCII ( <b>ADAM-4017 &amp; 4107+</b> )<br>MODBUS/RTU ( <b>ADAM-4017+ only</b> )   |
| Watchdog timer     | <b>ADAM-4017:</b> System (1.6 second)<br><b>ADAM-4017+:</b><br>System (1.6 second) and communication   |
| Power requirements | +10 to +30 V <sub>DC</sub> (non-regulated)   |
| Power consumption  | 1.2 W @ 24 V <sub>DC</sub>   |

**Figure A-6 ADAM-4017/4017+ Function Diagram**  
*The use of a 125 ohm external resistor is when only 4017 needs one. The resistor is contained internally for the ADAM-4017+ and doesn't need to be include externally.*



## Technical Specifications

---

### A.7 ADAM-4018/4018+ 8-channel Analog Input Module

**Table A-9 ADAM-4018/4018+ Specifications**

|                    |  |
|--------------------|--|
| AI channel number  | <b>ADAM-4018:</b><br>6 differential and 2 single-ended<br><b>ADAM-4018+:</b><br>8 differential   |
| Input type         | Thermocouple with mV, V, or mA   |
| Input range        | J, K, T, E, R, S and B Thermocouple<br><b>ADAM-4018:</b><br>±15 mV, ±50 mV, ±100 mV, ±500 mV,<br>±1 V, ±2.5 V and ±20 mA<br><b>ADAM-4018+:</b><br>±20 mA and 4~20 mA |
| Output speed (bps) | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K  |
| Maximum distance   | 4000 ft. (1200 m)  |
| Isolation voltage  | 3000 V <sub>DC</sub>   |
| Resolution         | 16-bit   |
| Sampling rate      | 10 samples/second (total)  |
| Bandwidth          | 13.1 Hz  |
| Accuracy           | ±0.1% or better  |
| Zero drift         | ±6 μV/°C   |
| Span drift         | ±25 ppm/°C   |
| CMR @ 50/60 Hz     | 120 dB   |
| NMR @ 50/60 Hz     | 100 dB   |
| Input impedance    | Voltage: 20 MΩ, Current: 120 Ω   |
| Support protocol   | ADAM ASCII ( <b>ADAM-4018 &amp; 4108+</b> )<br>MODBUS/RTU ( <b>ADAM-4018+ only</b> )   |
| Watchdog timer     | <b>ADAM-4018:</b> System (1.6 second)<br><b>ADAM-4018+:</b><br>System (1.6 second) and communication   |
| Power requirements | +10 to +30 V <sub>DC</sub> (non-regulated)   |
| Power consumption  | 0.8 W @ 24 V <sub>DC</sub>   |
| Burn-out detection | All T/C input ( <b>ADAM-4018+ only</b> )   |


**Table A-10 ADAM-4018/4018+ Range Accuracy for Thermocouple**

| Input Range Code (Hex) | Input Range                      | Typical Accuracy | Maximum Error | Units |
|------------------------|----------------------------------|------------------|---------------|-------|
| 0E                     | J thermocouple<br>0 to 760 °C    | ±1.0             | ±1.5          | °C    |
| 0F                     | K thermocouple<br>0 to 1370 °C   | ±1.0             | ±1.5          | °C    |
| 10                     | T thermocouple<br>-100 to 400 °C | ±1.0             | ±1.5          | °C    |
| 11                     | E thermocouple<br>0 to 1000 °C   | ±1.0             | ±1.5          | °C    |
| 12                     | R thermocouple<br>500 to 1750 °C | ±1.2             | ±2.5          | °C    |
| 13                     | S thermocouple<br>500 to 1750 °C | ±1.2             | ±2.5          | °C    |
| 14                     | B thermocouple<br>500 to 1800 °C | ±2.0             | ±3.0          | °C    |

**NOTE:** Because the CJC sensor of ADAM-4018 is located in the side of channel 0 to 4, the measurement will have the difference  $\pm 1$  °C between channel 0 ~ 4 and channel 5 ~ 7.

# Technical Specifications

Figure A-7 ADAM-4018/4018+ Function Diagram



**A.8 ADAM-4018M 8-channel Analog Input Data Logger**

**Table A-11 ADAM-4018M Specifications**

|                      |  |
|----------------------|--|
| AI channel number    | 6 differential and 2 single-ended  |
| Input type           | mV, V and mA   |
| Input range          | J, K, T, E, R, S and B Thermocouple<br>±15 mV, ±50 mV, ±100 mV, ±500 mV, and<br>±20 mA |
| Output speed (bps)   | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K              |
| Maximum distance     | 4000 ft. (1200 m)  |
| Isolation voltage    | 500 V <sub>DC</sub>  |
| Resolution           | 16-bit   |
| Sampling rate        | 10 samples/sec(total)  |
| Bandwidth            | 13.1 Hz  |
| Accuracy             | ±0.1% or better  |
| Zero drift           | ±6 μV/°C   |
| Span drift           | ±25 ppm/°C   |
| CMR @ 50/60 Hz       | 120 dB   |
| NMR @ 50/60 Hz       | 100 dB   |
| Input impedance      | Voltage: 20 MΩ, Current: 120 Ω   |
| Storage capacity     | 128 KB Flash memory  |
| Standard log         | 38,000 samples (total)   |
| Event log            | 16,300 samples (total)   |
| Mixed log            | 16,300 data samples and 9,300 event<br>samples (total)                                 |
| Storage type         | Write to end of memory, or circular memory   |
| Logging mode         | Standard log, Event log or Mixed log   |
| Sampling interval    | 2 second to 18 hours   |
| Measurement duration | 330 minutes to 20 years  |
| Support protocol     | ADAM ASCII   |
| Watchdog timer       | 1.6 second (System)  |
| Power requirements   | +10 to +30 V <sub>DC</sub> (non-regulated)   |
| Power consumption    | 1.8 W @ 24 V <sub>DC</sub>   |

## Technical Specifications

---


**Table A-12 ADAM-4018M Range Accuracy for Thermocouple**

| Input Range Code (Hex) | Input Range                      | Typical Accuracy | Maximum Error | Units |
|------------------------|----------------------------------|------------------|---------------|-------|
| 0E                     | J thermocouple<br>0 to 760 °C    | ±1.0             | ±1.5          | °C    |
| 0F                     | K thermocouple<br>0 to 1370 °C   | ±1.0             | ±1.5          | °C    |
| 10                     | T thermocouple<br>-100 to 400 °C | ±1.0             | ±1.5          | °C    |
| 11                     | E thermocouple<br>0 to 1000 °C   | ±1.0             | ±1.5          | °C    |
| 12                     | R thermocouple<br>500 to 1750 °C | ±1.2             | ±2.5          | °C    |
| 13                     | S thermocouple<br>500 to 1750 °C | ±1.2             | ±2.5          | °C    |
| 14                     | B thermocouple<br>500 to 1800 °C | ±2.0             | ±3.0          | °C    |

**NOTE:** Because the CJC sensor of ADAM-4018M is located in the side of channel 0 to 4, the measurement will have the difference  $\pm 1$  °C between channel 0 ~ 4 and channel 5 ~ 7.



Figure A-8 ADAM-4018M Function Diagram



## Technical Specifications


---

### A.9 ADAM-4019+ 8-Channels Universal Analog Input Module

**Table A-13 ADAM-4019+ Specifications**

|                    |   |
|--------------------|---|
| AI channel number  | 8   |
| Input type         | V, mV, mA and T/C   |
| Input range        | V: $\pm 1$ V, $\pm 2.5$ V, $\pm 5$ V, $\pm 10$ V<br>mV: $\pm 100$ mV, $\pm 500$ mV<br>mA: $\pm 20$ mA (with $120 \Omega$ resistor)<br>4~20 mA (with $120 \Omega$ resistor)<br>Thermocouple:<br>J 0 to $760^\circ\text{C}$<br>K 0 to $1370^\circ\text{C}$<br>T $-100$ to $400^\circ\text{C}$<br>E 0 to $1400^\circ\text{C}$<br>R 500 to $1750^\circ\text{C}$<br>S 500 to $1750^\circ\text{C}$<br>B 500 to $1800^\circ\text{C}$ |
| Isolation voltage  | $3000 V_{\text{DC}}$  |
| Resolution         | 16-bit  |
| Sampling rate      | 10 samples/sec (total)  |
| Input impedance    | $20 M\Omega$  |
| Accuracy           | $\pm 0.1\%$ or better   |
| Zero drift         | $\pm 6 \mu\text{V}/^\circ\text{C}$  |
| CMR @ 50/60 Hz     | 120 dB  |
| NMR @ 50/60 Hz     | 100 dB  |
| Span drift         | $\pm 25$ ppm/ $^\circ\text{C}$  |
| Support protocol   | ADAM ASCII and MODBUS/RTU   |
| Watchdog timer     | System (1.6 second) and communication   |
| Power requirements | +10 to +30 $V_{\text{DC}}$ (non-regulated)  |
| Power consumption  | 1.0 W @ 24 $V_{\text{DC}}$  |
| Burn-out detection | +4~20mA and all Thermocouple input  |

Figure A-9 ADAM-4019+ Function Diagram



## Technical Specifications

---

### A.10 ADAM-4021/4024 Analog Output Module

**Table A-14 ADAM-4021/4024 Specifications**

|  |  |
|--|--|
| Input speed (bps)                              | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K,<br>57.6K, 115.2K  |
| Maximum distance                               | 4000 ft. (1200 m)  |
| AO channel number                              | <b>ADAM-4021:</b> 1<br><b>ADAM-4024:</b> 4   |
| Output type                                    | mA, V  |
| Output range                                   | 0~20 mA, 4~20 mA and $\pm 10$ V  |
| Accuracy                                       | <b>ADAM-4021:</b><br>$\pm 0.1\%$ of FSR for current output<br>$\pm 0.2\%$ of FSR for voltage output<br><b>ADAM-4024:</b><br>$\pm 0.1\%$ of FSR for current output<br>$\pm 0.1\%$ of FSR for voltage output |
| Resolution                                     | 12-bit   |
| Readback accuracy                              | $\pm 0.1\%$ of FSR ( <b>ADAM-4021 only</b> )   |
| Zero drift<br>voltage output<br>current output | $\pm 30 \mu\text{V}/^\circ\text{C}$<br>$\pm 0.2 \mu\text{A}/^\circ\text{C}$  |
| Span temperature coefficient                   | $\pm 25 \text{ ppm}/^\circ\text{C}$  |
| Isolation rated voltage                        | 3000 V <sub>DC</sub>   |
| Programmable output slope                      | 0.125 to 128 mA/second<br>0.0625 to 64 V/second  |
| Current load resistor                          | 0 to 500 $\Omega$ (source)   |
| Bandwidth                                      | 100 samples/second   |
| Output impedance                               | 0.5 $\Omega$   |

*(Table continued on next page)*

|                   |  |
|-------------------|--|
| Support protocol  | <b>ADAM-4021:</b><br>ADAM ASCII<br><b>ADAM-4024:</b><br>ADAM ASCII and MODBUS/RTU                      |
| Watchdog timer    | <b>ADAM-4021:</b><br>System (1.6 second)<br><b>ADAM-4024:</b><br>System (1.6 second) and communication |
| Power supply      | +10 to +30 V <sub>DC</sub> (non-regulated)   |
| Power consumption | <b>ADAM-4021:</b><br>1.4 W @ 24 V <sub>DC</sub><br><b>ADAM-4024:</b><br>3.0 W @ 24 V <sub>DC</sub>     |

# Technical Specifications

**Figure A-10 ADAM-4021 Function Diagram**





Figure A-11 ADAM-4024 Function Diagram



## Technical Specifications

---


### A.11 ADAM-4050 Digital I/O Module

**Table A-15 ADAM-4050 Specifications**

|  |   |
|--|---|
| DI/O channel number  | 7 digital inputs<br>8 digital outputs                                     |
| Input/Output speed (bps)   | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K,<br>38.4K, 57.6K, 115.2K |
| Maximum distance   | 4000 ft. (1200 m)   |
| Digital output Sink-current<br>Power dissipation                         | Open collector to 30 V<br>30 mA maximum<br>300 mW                         |
| Digital input level<br>Logic level 0<br>Logic level 1<br>Pull-up current | +1 V maximum<br>+3.5 to +30 V<br>0.5 mA, 10K resistor to +5 V             |
| Support protocol   | ADAM ASCII  |
| Watchdog timer   | 1.6 second (System)   |
| Power supply   | +10 to +30 V <sub>DC</sub> (non-regulated)                                |
| Power consumption  | 0.4 W @ 24 V <sub>DC</sub>  |



Figure A-12 ADAM-4050 Function Diagram



## Technical Specifications

### A.12 ADAM-4051/4052 Isolated Digital Input Module

**Table A-16 ADAM-4051/4502 Specifications**


|  |  |
|--|--|
| DI/O channel number  | <b>ADAM-4501:</b> 16 digital inputs<br><b>ADAM-4052:</b> 8 digital inputs<br>(6 fully independent isolated channels, and 2 isolated channels with common ground) |
| Input/Output speed (bps)                                   | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K,<br>38.4K, 57.6K, 115.2K  |
| Maximum distance   | 4000 ft. (1200 m)  |
| Digital input level  |  |
| <b>ADAM-4051:</b><br><b>Dry Contact:</b><br>Logic level 0: | Close to GND   |
| Logic level 1:   | Open   |
| <b>Wet Contact:</b><br>Logic level 0:                      | +3V maximum  |
| Logic level 1:   | +10 to 50V   |
| <b>ADAM-4052:</b><br>Logic level 0:                        | +1V maximum  |
| Logic level 1:   | +3 to 30V  |
| Input resistance   | <b>ADAM-4051:</b> 5.2 k $\Omega$<br><b>ADAM-4052:</b> 3 k $\Omega$   |
| Isolation voltage  | <b>ADAM-4051:</b> 2500 V <sub>DC</sub><br><b>ADAM-4052:</b> 5000 V <sub>RMS</sub>  |
| Over-voltage protect                                       | 70 V <sub>DC</sub> ( <b>ADAM-4051 only</b> )   |
| Support protocol   | <b>ADAM-4051:</b><br>ADAM ASCII and MODBUS/RTU<br><b>ADAM-4052:</b><br>ADAM ASCII  |

(Table continued on next page)

|                   |   |
|-------------------|---|
| Watchdog timer    | <b>ADAM-4051:</b><br>System (1.6 second) and<br>communication<br><b>ADAM-4052:</b><br>System (1.6 second) |
| Power supply      | +10 to +30 V <sub>DC</sub> (non-regulated)  |
| Power consumption | <b>ADAM-4051:</b> 1.0 W @ 24 V <sub>DC</sub><br><b>ADAM-4052:</b> 0.4 W @ 24 V <sub>DC</sub>              |

# Technical Specifications

Figure A-13 ADAM-4051/4052 Function Diagram




**A.13 ADAM-4053 16-channel Digital Input Module**

**Table A-17 ADAM-4053 Specifications**

|   |   |
|---|---|
| DI/O channel number   | 16 digital inputs   |
| Input/Output speed (bps)  | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K,<br>38.4K, 57.6K, 115.2K |
| Maximum distance  | 4000 ft. (1200 m)   |
| Digital input level<br><b>Dry Contact:</b><br>logic level 0:<br>logic level 1:<br><b>Wet Contact:</b><br>logic level 0:<br>logic level 1: | Close to GND<br>Open<br><br>+2V maximum<br>+4 to +30 V                    |
| Effective distance<br><b>(Dry contact only)</b>   | 500 m maximum   |
| Support protocol  | ADAM ASCII  |
| Watchdog timer  | 1.6 second (System)   |
| Power supply  | +10 to +30 V <sub>DC</sub> (non-regulated)                                |
| Power consumption   | 1.0 W @ 24 V <sub>DC</sub>  |

# Technical Specifications

Figure A-14 ADAM-4053 Function Diagram




**A.14 ADAM-4055 Isolated Digital Input/Output Module**

**Table A-18 ADAM-4055 Specifications**

|   |   |
|---|---|
| DI/O channel number   | 8 digital inputs<br>8 digital outputs   |
| Input/Output speed (bps)  | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K, 57.6K, 115.2K                      |
| Maximum distance  | 4000 ft. (1200 m)   |
| Isolation voltage   | 2500 V <sub>DC</sub>  |
| Opto-isolator response time   | 25 μs   |
| Over-voltage protect  | 70 V <sub>DC</sub>  |
| ESD (Electro Static Discharge)  | 2000 V <sub>DC</sub>  |
| Digital input level<br><b>Dry Contact:</b><br>Logic level 0:<br>Logic level 1:<br><b>Wet Contact:</b><br>Logic level 0:<br>Logic level 1: | Open<br>Close to GND<br><br>+3V maximum<br>+10 to 50V                                       |
| Digital output<br>Sink-current<br>Power dissipation   | Open collector to 40 V<br>200 mA maximum<br>Channel: 1W maximum<br>Total: 2.2W (8 channels) |
| LED Indicator:  | On: Active<br>Off: Non-active   |
| Support protocol  | ADAM ASCII and MODBUS/RTU   |
| Watchdog timer  | System (1.6 second) and communication   |
| Power supply  | +10 to +30 V <sub>DC</sub> (non-regulated)  |
| Power consumption   | 1.0 W @ 24 V <sub>DC</sub>  |

# Technical Specifications

Figure A-15 ADAM-4055 Function Diagram






---

**A.15 ADAM-4056S 12-channel Sink Type Isolated Digital Output Module****Table A-19 ADAM-4056S Specifications**

|                          |  |
|--------------------------|--|
| DO channel number        | 12 digital outputs (sink type)   |
| Input/Output speed (bps) | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K, 57.6K, 115.2K |
| Maximum distance         | 4000 ft. (1200 m)  |
| Digital output           | Open Collector to +40V<br>200 mA maximum                               |
| Power dissipation        | Channel: 1W maximum<br>Total: 2.2W (8 channels)                        |
| Isolation voltage        | 5000 V <sub>DC</sub>   |
| Support protocol         | ADAM ASCII and MODBUS/RTU  |
| LED Indicator            | On: Active<br>Off: Non-active  |
| Watchdog timer           | System (1.6 second) and communication                                  |
| Power supply             | +10 to +30 V <sub>DC</sub> (non-regulated)                             |
| Power consumption        | 1.0 W @ 24 V <sub>DC</sub>   |

# Technical Specifications

Figure A-16 ADAM-4056S Function Diagram




**A.16 ADAM-4056SO 12-channel Source Type Isolated Digital Output Module****Table A-20 ADAM-4056SO Specifications**

|                          |  |
|--------------------------|--|
| DO channel number        | 12 digital outputs (source type)                                       |
| Input/Output speed (bps) | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K, 38.4K, 57.6K, 115.2K |
| Maximum distance         | 4000 ft. (1200 m)  |
| Digital output           | VCC: +10~ +35V<br>1A (per Channel)                                     |
| Isolation voltage        | 5000 V <sub>DC</sub>   |
| Support protocol         | ADAM ASCII and MODBUS/RTU  |
| LED Indicator            | On: Active<br>Off: Non-active  |
| Watchdog timer           | System (1.6 second) and communication                                  |
| Power supply             | +10 to +30 V <sub>DC</sub> (non-regulated)                             |
| Power consumption        | 1.0 W @ 24 V <sub>DC</sub>   |

# Technical Specifications

Figure A-17 ADAM-4056SO Function Diagram




**A.17 ADAM-4060 Relay Output Module**

**Table A-21 ADAM-4060 Specifications**

|                               |   |
|-------------------------------|---|
| DO channel number             | 4 channel relay<br>(2 form A, 2 form C)                                   |
| Input speed (bps)             | RS-485 (2-wire)<br>1200, 2400, 4800, 9600, 19.2K,<br>38.4K, 57.6K, 115.2K |
| Maximum distance              | 4000 ft. (1200 m)   |
| Contact rating<br>(Resistive) | AC: 0.6 A@125 V<br>0.3 A@250 V<br>DC: 2 A@30 V<br>0.6 A@ 110 V            |
| Breakdown voltage             | 500 V <sub>AC</sub> (50/60 Hz)  |
| Relay on time (typical)       | 3 ms  |
| Relay off time (typical)      | 2 ms  |
| Total switching time          | 10 ms   |
| Insulation resistance         | 1 GΩ minimum at 500 V <sub>DC</sub>                                       |
| Support protocol              | ADAM ASCII  |
| Watchdog timer                | 1.6 second (System)   |
| Power supply                  | +10 to +30 V <sub>DC</sub> (non-regulated)                                |
| Power consumption             | 0.8 W @ 24 V <sub>DC</sub>  |

## Figure A-18 ADAM-4060 Function Diagram



## A.18 ADAM-4068/4069 8-channel Relay Output Module


**Table A-22 ADAM-4068/4069 Specifications**

|                               |   |
|-------------------------------|---|
| DO channel number             | 8 channel relay<br>(4 form A, 4 form C)   |
| Contact rating<br>(Resistive) | <b>ADAM-4068:</b><br>AC: 0.6A @ 125V<br>0.3A @ 250V<br>DC: 2A @ 30V<br>0.6 @ 110V<br><b>ADAM-4069:</b><br>AC: 5A @ 240V<br>DC: 5A @ 30V |
| Breakdown voltage             | <b>ADAM-4068:</b><br>500 V <sub>AC</sub> (50/60 Hz)<br><b>ADAM-4069:</b><br>1000 V <sub>AC</sub> (50/60 Hz)                             |
| Insulation resistance         | 1 GΩ minimum at 500 V <sub>DC</sub>   |
| Relay on time (typical)       | <b>ADAM-4068:</b> 3 ms<br><b>ADAM-4069:</b> 5 ms  |
| Relay off time (typical)      | <b>ADAM-4068:</b> 4 ms<br><b>ADAM-4069:</b> 5.6 ms  |
| Support protocol              | ADAM ASCII and MODBUS/RTU   |
| Watchdog timer                | System (1.6 second) and communication   |
| Power supply                  | +10 to +30 V <sub>DC</sub> (non-regulated)  |
| Power consumption             | <b>ADAM-4068:</b><br>0.6 W @ 24 V <sub>DC</sub><br><b>ADAM-4069:</b><br>2.2 W @ 24 V <sub>DC</sub>                                      |

# Technical Specifications

---

**Figure A-19 ADAM-4068/4069 Function Diagram**






## **A.19 ADAM-4080 Counter/Frequency Input Module**

**Table A-23 ADAM-4080 Specifications**

|                                   |  |
|-----------------------------------|--|
| Input channel number              | 2 independent 32-bit counters              |
| Input frequency                   | 50 kHz maximum                             |
| Input mode                        | Isolated or non-isolated                   |
| Isolation input level             |  |
| Logic level 0                     | +1 V maximum                               |
| Logical level 1                   | +3.5 V to +30 V                            |
| Isolation voltage                 | 2500 VRMS                                  |
| Non-isolation input level         | Programmable threshold                     |
| Logic level 0                     | 0 to +5 V (default = 0.8 V)                |
| Logic level 1                     | 0 to +5 V (default = 2.4 V)                |
| Input pulse width                 | >10 $\mu$ sec                              |
| Maximum count                     | 4,294,967,295 (32 bits)                    |
| Programmable digital noise filter | 2 $\mu$ sec to 65 msec                     |
| Alarming                          | Alarm comparators on each counter          |
| Preset type                       | Absolute or relative                       |
| Frequency measurement             |  |
| Range                             | 5 Hz to 50 KHz                             |
| Programmable built-in gate time   | 1.0/0.1 sec                                |
| Digital output channels           | 2 channels open collector to 30 V          |
| Sink current                      | 30 mA max. load                            |
| Power dissipation                 | 300 mW                                     |
| Support protocol                  | ADAM ASCII                                 |
| Watchdog timer                    | 1.6 second (System)                        |
| Power requirements                | +10 to +30 V <sub>DC</sub> (non-regulated) |
| Power consumption                 | 2.0 W@ 24 V <sub>DC</sub>                  |

# Technical Specifications

**Figure A-20 ADAM-4080 Function Diagram**




## A.20 ADAM-4080D Counter/Frequency Input Module with LED Display

**Table A-24 ADAM-4080D Specifications**

|                                   |  |
|-----------------------------------|--|
| Input channels                    | 2 independent 32-bit counters                              |
| Input frequency                   | 50 kHz maximum   |
| Input mode                        | Isolated or non-isolated                                   |
| Isolation input level             |  |
| Logic level 0                     | +1 V max   |
| Logical level                     | +3.5 V to +30 V  |
| Isolation voltage                 | 2500 V <sub>RMS</sub>                                      |
| Non-isolation input level         |  |
| Logic level 0                     | Programmable threshold                                     |
| Logic level 1                     | 0 to +5 V (default = 0.8 V)<br>0 to +5 V (default = 2.4 V) |
| Input pulse width                 | >10 $\mu$ sec  |
| Maximum count                     | 4,294,967,295 (32 bits)                                    |
| Programmable digital noise filter | 2 $\mu$ sec to 65 msec                                     |
| Alarming                          | High and Low comparators on counter 0                      |
| Frequency Measurement Range       | 5 Hz to 50 KHz   |
| Programmable built-in gate time   | 1.0/0.1 sec  |
| Display                           | LED indicator 5-digit readout; CH 0 or CH 1 (programmable) |
| Digital Output Channels           | 2 channels Open collector to 30 V                          |
| Sink current                      | 30 mA max. load  |
| Power dissipation                 | 300 mW   |
| Support protocol                  | ADAM ASCII   |
| Watchdog timer                    | 1.6 second (System)  |
| Power requirements                | +10 to +30 V <sub>DC</sub> (non-regulated)                 |
| Power consumption                 | 2.0 W @ 24 V <sub>DC</sub>                                 |

# Technical Specifications

## Figure A-21 ADAM-4080D Function Diagram



Data Formats and I/O Ranges

**B**

# Data Formats and I/O Ranges

---

## B.1 Analog Input Formats

The ADAM analog input modules can be configured to transmit data to the host in one of the following data formats:

- Engineering Units
- Percent of FSR
- Twos complement hexadecimal
- Ohms

### B.1.1 Engineering Units

Data can be represented in engineering units by assigning bits 0 and 1 of the data format/checksum/integration time parameter with value 00.

This format presents data in standard units such as degrees, volts, millivolts and milliamps. When the value in engineering format is converted to computer language, it is presented in seven characters. These characters may include sign and decimals. However, the number of characters can not exceed seven.

Data is grouped into a plus (+) or minus (-) sign, followed by five decimal digits and a decimal point. The input range which is employed determines the resolution or the number of decimal places used as illustrated in the following examples:

#### Example 1

The input value is -2.65 and the corresponding analog input module is configured for a range of  $\pm 5$  V. The response to the Analog Data In command is: -2.6500 (cr)

#### Example 2

The input value is 305.5°C, and the analog input module is configured for a type J thermocouple whose range is (0°C to 760°C). The response to the Analog Data In command is: +305.50 (cr)

#### Example 3

The input value is +5.653 V. The analog input module is configured for a  $\pm 5$  V range. When the engineering unit format is used, the ADAM Series analog input modules are configured so that they automatically provide an over-range capability. The response to the Analog Data In command in this case is: +5.6530 (cr)

### B.1.2 Percent of FSR

This mode is used by setting bits 0 and 1 of the data format/checksum /integration time parameter to 01. The format used in Percent of FSR consists of a plus (+) or minus (-) sign followed by five decimal digits including a decimal point. The maximum possible resolution is 0.01% with the decimal point fixed.

Data are given as the ratio of the input signal to the full-scale range.

#### Example 1

The input value is +2.0 V. The input module is configured for a range of  $\pm 5$  V. The response to the Analog Data In command is as follows:

+040.00 (cr)

The full calibrated voltage range ranges from -100% to 100% as voltage input ranges are always bipolar. A  $\pm 5$  V input would range from  $-5$  V (-100%) to  $5$  V (100%).

In this example the input is represented by +40% of the full-scale range which equals to  $(+40/100) \times 5 \text{ V} = +2.0 \text{ V}$  the actual input value.

#### Example 2

The input value is  $652.5^\circ\text{C}$ , and a type E thermocouple ( $0^\circ\text{C}$  to  $1000^\circ\text{C}$ ) is configured in the analog input module. The response to the Analog Data In command is:

+065.25 (cr)

The result shows that the value of the input ( $652.5^\circ\text{C}$ ) is 65.25% of the full-scale range ( $1000^\circ\text{C}$ ).

Thermocouple input ranges are always assumed to be bipolar with zero being the point of symmetry. This holds true regardless of the specified range of operation. For example, when we use a type J thermocouple ( $0^\circ\text{C}$  to  $760^\circ\text{C}$ ),  $760^\circ\text{C}$  corresponds to +100% and  $0^\circ\text{C}$  corresponds to 0%. Even if  $0^\circ\text{C}$  lies outside of the specified operation range for the thermocouple, zero will remain as the point of symmetry. For instance, a type B thermocouple is specified for operation from  $+500^\circ\text{C}$  to  $+1800^\circ\text{C}$ . In this case  $+1800^\circ\text{C}$  corresponds to + 100% and  $500^\circ\text{C}$  corresponds to +27.77%.

## Data Formats and I/O Ranges

---

The percentage is related to the full span of the configured range. For instance, a nickel RTD is specified for  $-80^{\circ}\text{C}$  to  $+100^{\circ}\text{C}$ . Then, the lower value of  $-80^{\circ}\text{C}$  equals to 0% of span and the upper value of  $+100^{\circ}\text{C}$  equals to 100% of span.

In the FSR mode, an over-range feature is automatically invoked by the ADAM analog input modules if the value exceeds the uppermost value of the input range. For instance, an analog module which is configured for a  $\pm 5\text{ V}$  range has one of the values reading  $+ 5.5\text{V}$ . The resulting value would then be 110%.

The readings must fall within the input range for accuracy assurance. Although they are typically linear readings, anything which falls between  $\pm 100\%$  and  $\pm 115\%$  limits may not be accurate. Furthermore, readings beyond these limits are neither accurate nor linear.

### B.1.3 Twos complement hexadecimal

Twos Complement Hexadecimal format presents the data in ASCII hexadecimal form providing a rapid communication, high resolution and easy conversion to computer-compatible integer format.

In order to indicate twos complement hexadecimal, bits 0 and 1 of the data format/checksum/integration time parameter must be set to 10. This format displays data in the form of a 4-character hexadecimal string.

This string represents a 16-bit twos complement binary value. Positive full scale is denoted as 7FFF ( $+32,767$ ) while negative full scale is represented by the value 8000 ( $-32,768$ ). The resolution is digit one at the least significant bit (LSB) of 16 bits.

#### Example

The input value is  $-1.234\text{ V}$ . An analog input module is configured for a  $\pm 5\text{ V}$  range. The value returned is: E069 (cr)

This value is equivalent to the signed integer  $-8087$ .

Input ranges with voltage and milliamp values are used with the full calibrated voltage range from 8000 to 7FFF. For instance, an ADAM-4011 module is given a  $\pm 5\text{ V}$  input range. In this case,  $-5\text{ V}$  is represented as 8000h and  $+5\text{ V}$  is denoted as 7FFFh.

When thermocouple input ranges are used, an input range which is bipolar and symmetric at zero is assumed. The following table provides several examples.



| Thermocouple Type | Temperature Range (Degrees) | Temperature Range (Hex) |
|-------------------|-----------------------------|-------------------------|
| J                 | 0° C to 760° C              | 0000h - 7FFFh           |
| T                 | -100° C to 400° C           | E000h - 7FFFh           |
| R                 | 500° C to 1750° C           | 2492h - 7FFFh           |

The given span of the specified range is used to determine the RTD input ranges for twos complement hexadecimal values. For an example, if the nickel RTD is specified for the range -80° C to +100° C, the corresponding values in hexadecimal notation would be 8000h to 7FFFh.

### B.1.4 Ohms

To indicate ohms, set bits 0 and 1 of the data format/checksum/integration time parameter to 11.

The ohms format allows you to read the value of the RTD resistance in ohms. It consists of a “+” or “-” sign followed by five decimal digits and a decimal point. The resolution (position of the decimal point) of Platinum-Nickel RTDs is 10 mΩ. (two decimal places).

For example, a 100 Ω platinum RTD specified for -100° C to +100° C has +100° C corresponding to +138.50 Ω and -100° C corresponding to +060.60 Ω.

The measurable resistance values are as given below:

The format is **Type, Bottom Tem. (ohm) ~ Top Temp. (ohm)**

|                |                            |
|----------------|----------------------------|
| BA1            | -200(7.95) ~ 600(145.85)   |
| PT-100 (0.385) | -50(80.31) ~ +150(157.31)  |
| PT-100 (0.392) | -50(79.96) ~ +150(158.29)  |
| PT-100 (0.385) | 0(100.00) ~ +100(138.50)   |
| PT-100 (0.392) | 0(100.00) ~ +100(139.16)   |
| PT-100 (0.385) | 0(100.00) ~ +200(175.84)   |
| PT-100 (0.392) | 0(100.00) ~ +200(177.13)   |
| PT-100 (0.385) | 0(100.00) ~ +400(247.04)   |
| PT-100 (0.392) | 0(100.00) ~ +400(249.56)   |
| PT-100 (0.385) | -200(18.49) ~ +200(175.84) |
| PT-100 (0.392) | -200(18.49) ~ +200(177.13) |
| PT-1000        | -40(842.7) ~ +160(1610.4)  |
| Balco-500      | -30(397.05) ~ +120(723.44) |
| Ni604-518      | -80(410.73) ~ +100(917.33) |
| Ni604-518      | 0(604) ~ +100(917.33)      |
| Ni508A         | 0(507) ~ 100(772)          |
| Ni508B         | -50(400.14) ~ 200(1099.89) |

# Data Formats and I/O Ranges

## B.2 Analog Input Ranges

| Range Code (hex) | Input Range Description | Data Formats      | +F.S.   | Zero    | -F.S.   | Displayed Resolution |
|------------------|-------------------------|-------------------|---------|---------|---------|----------------------|
| 00               | ± 15 mV                 | Engineering Units | +15.000 | ±00.000 | -15.000 | 1 µv                 |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 01               | ± 50 mV                 | Engineering Units | +50.000 | ±00.000 | -50.000 | 1 µv                 |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 02               | ± 100 mV                | Engineering Units | +100.00 | ±000.00 | -100.00 | 10 µv                |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 03               | ± 500 mV                | Engineering Units | +500.00 | ±000.00 | -500.00 | 10 µv                |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 04               | ± 1 V                   | Engineering Units | +100.00 | ±0.0000 | -1.0000 | 100.00 µv            |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 05               | ± 2.5 V                 | Engineering Units | +2.5000 | ±0.0000 | -2.5000 | 100.00 µv            |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 06               | ± 20 mV                 | Engineering Units | +20.000 | ±00.000 | -20.000 | 1 µv                 |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |
| 07               | ± 4~20mA                | Engineering Units | +20.000 | ±00.000 | -20.000 | 1 µA                 |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 0.01%                |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 1 LSB*               |

## Appendix B

| Range Code (hex) | Input Range Description | Data Formats      | +F.S.   | Zero    | -F.S.   | Displayed  |
|------------------|-------------------------|-------------------|---------|---------|---------|------------|
| 08               | ± 10 mV                 | Engineering Units | +10.000 | ±00.000 | -10.000 | Resolution |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 1 µv       |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 0.01%      |
| 09               | ± 5 V                   | Engineering Units | +5.0000 | ±0.0000 | -5.0000 | 1 LSB*     |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 100.00 µv  |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 0.01%      |
| 0A               | ± 1 V                   | Engineering Units | +1.0000 | ±0.0000 | -1.000  | 1 LSB*     |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 100.00 µv  |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 0.01%      |
| 0B               | ± 500 mV                | Engineering Units | +500.00 | ±000.00 | -500.00 | 1 LSB*     |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 10 µv      |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 0.01%      |
| 0C               | ± 150 mV                | Engineering Units | +150.00 | ±000.00 | -150.00 | 1 LSB*     |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 10 µv      |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 0.01%      |
| 0D               | ± 20 mV                 | Engineering Units | +20.000 | ±00.000 | -20.000 | 1 LSB*     |
|                  |                         | % of FSR          | +100.00 | ±000.00 | -100.00 | 1 µv       |
|                  |                         | Twos Complement   | 7FFF    | 0000    | 8000    | 0.01%      |

| Range Code (hex) | Input Range Description             | Data Formats      | Maximum Specified Signal | Minimum Specified Signal | Displayed Resolution |
|------------------|-------------------------------------|-------------------|--------------------------|--------------------------|----------------------|
| 0E               | Type J Thermocouple<br>0°C to 760°C | Engineering Units | +760.000                 | +000.00                  | 0.01°C               |
|                  |                                     | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |                                     | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |

## Data Formats and I/O Ranges

| Range Code (hex) | Input Range Description  | Data Formats      | Maximum Specified Signal | Minimum Specified Signal | Displayed Resolution |
|------------------|--|-------------------|--------------------------|--------------------------|----------------------|
| 0F               | Type K Thermocouple<br>0°C to 1370°C                             | Engineering Units | +1370.0                  | +0000.0                  | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
| 10               | Type T Thermocouple<br>-100°C to 400°C                           | Engineering Units | +400.00                  | -100.00                  | 0.01°C               |
|                  |  | % of FSR          | +100.00                  | -0.25.00                 | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | E000                     | 1 LSB*               |
| 11               | Type E Thermocouple<br>0°C to 1000°C                             | Engineering Units | +1000.0                  | +0000.0                  | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
| 12               | Type R Thermocouple<br>500°C to 1750°C                           | Engineering Units | +1750.0                  | +0500.0                  | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +028.57                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 2492                     | 1 LSB*               |
| 13               | Type S Thermocouple<br>500°C to 1750°C                           | Engineering Units | +1750.0                  | +0500.0                  | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +028.57                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 2492                     | 1 LSB*               |
| 14               | Type B Thermocouple<br>500°C to 1800°C                           | Engineering Units | +1800.0                  | +0500.0                  | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +027.77                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 2381                     | 1 LSB*               |
| 20               | 100.00 Ω<br>Platinum RTD<br>$\alpha = .00385$<br>-100°C to 100°C | Engineering Units | +100.00                  | -100.000                 | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 8000                     | 1 LSB*               |
|                  |  | Ohms              | +138.50                  | +060.60                  | 10 mΩ                |
| 21               | 100.00 Ω<br>Platinum RTD<br>$\alpha = .00385$<br>0°C to 100°C    | Engineering Units | +100.000                 | +000.00                  | 0.1°C                |
|                  |  | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |  | Ohms              | +138.50                  | +100.00                  | 10 mΩ                |

## Appendix B

| Range Code (hex) | Input Range Description   | Data Formats      | Maximum Specified Signal | Minimum Specified Signal | Displayed Resolution |
|------------------|---|-------------------|--------------------------|--------------------------|----------------------|
| 22               | 100.00 $\Omega$<br>Platinum RTD<br>$\alpha = .00385$<br>0°C to 200°C    | Engineering Units | +200.00                  | +000.00                  | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |   | Ohms              | +175.84                  | +100.00                  | 10 m $\Omega$        |
| 23               | 100.00 $\Omega$<br>Platinum RTD<br>$\alpha = .00385$<br>0°C to 600°C    | Engineering Units | +600.00                  | +000.00                  | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |   | Ohms              | +313.59                  | +100.00                  | 10 m $\Omega$        |
| 24               | 100.00 $\Omega$<br>Platinum RTD<br>$\alpha = .00392$<br>-100°C to 100°C | Engineering Units | +00.00                   | -100.00                  | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 8000                     | 1 LSB*               |
|                  |   | Ohms              | +139.16                  | +060.60                  | 10 m $\Omega$        |
| 25               | 100.00 $\Omega$<br>Platinum RTD<br>$\alpha = .00392$<br>0°C to 100°C    | Engineering Units | +100.00                  | +000.00                  | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |   | Ohms              | +139.16                  | +100.00                  | 10 m $\Omega$        |
| 26               | 100.00 $\Omega$<br>Platinum RTD<br>$\alpha = .00392$<br>0°C to 200°C    | Engineering Units | +200.00                  | +000.00                  | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |   | Ohms              | +177.13                  | +100.00                  | 10 m $\Omega$        |
| 27               | 100.00 $\Omega$<br>Platinum RTD<br>$\alpha = .00392$<br>0°C to 600°C    | Engineering Units | +600.00                  | +000.00                  | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |   | Ohms              | +317.28                  | +100.00                  | 10 m $\Omega$        |
| 28               | 120 $\Omega$<br>Nickel RTD<br>-80°C to 100°C                            | Engineering Unit  | +100.000                 | -80.00                   | 0.01°C               |
|                  |   | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |   | Twos Complement   | 7FFF                     | 8000                     | 1 LSB*               |
|                  |   | Ohms              | +200.64                  | +066.60                  | 10 m $\Omega$        |

## Data Formats and I/O Ranges

---

| Range Code (hex) | Input Range Description  | Data Formats      | Maximum Specified Signal | Minimum Specified Signal | Displayed Resolution |
|------------------|--|-------------------|--------------------------|--------------------------|----------------------|
| 29               | 100.00 $\Omega$<br>Nickel RTD<br>$\alpha = .00392$<br>0°C to 100°C | Engineering Units | +100.00                  | +000.00                  | 0.01°C               |
|                  |  | % of FSR          | +100.00                  | +000.00                  | 0.01%                |
|                  |  | Twos Complement   | 7FFF                     | 0000                     | 1 LSB*               |
|                  |  | Ohms              | +200.64                  | +120.00                  | 10 m $\Omega$        |

NOTE: \* Resolution is one LSB of 16 bits

### B.3 Analog Output Formats

You can configure ADAM analog output modules to receive data from the host in one of the following data formats:

- Engineering Units
- Percent of FSR
- Twos complement hexadecimal

Data for ADAM modules can be used in any one of the following data formats:

#### B.3.1 Engineering Units

This format is chosen by setting bits 0 and 1 of the data format/slew rate/checksum parameter to 00.

Data are presented in natural units such as milliamps. When the value in engineering format is converted to computer language, it is presented in six characters. These characters are ordered as two decimal digits, a decimal point, and then three decimal digits. As a result, the resolution is 5  $\mu$ A.

For example, an analog output module (address 01h) is configured for a 0 to 20 mA range. If the output value is + 4.762 mA, the format of the Analog Data Out command would be #0104.762(cr).

#### B.3.2 Percent of Span

The Percent of Span format is employed by setting bits 0 and 1 of the data format/slew rate/checksum parameter to 01.

This format consists of a “+” or “-” sign, three decimal digits, a decimal point and two decimal digits. Data are presented as the value sent by the output signal relative to the span of the output (percent of span).

The maximum resolution is 0.2% of the span (5  $\mu$ A for the 0 to 20 mA output range); therefore, the desired output value is 10 mA. The format of the Analog Data Out command is as follows:

#01+050.00 (cr). It indicates that the output is at 50% of the span, and the decimal point is fixed.

#### B.3.3 Hexadecimal

This format is selected by setting bits 0 and 1 of the data format/slew rate/checksum parameter to 10.

ASCII's condensed hexadecimal representation of data provides high resolution. The format consists of a 3-character hexadecimal string representing a 12-bit binary value. The resolution for the 0 to 20mA output range equals to .025% of the span, which is also equivalent to 5 $\mu$ A. The corresponding value for 000 is 0mA; likewise, the value FFF corresponds to 20mA.

## Data Formats and I/O Ranges

---

### B.4 Analog Output Ranges

| Range Code (hex) | Input Range Description | Data Formats       | Maximum Specified Signal | Minimum Specified Signal | Output Resolution |
|------------------|-------------------------|--------------------|--------------------------|--------------------------|-------------------|
| 30               | 0 to 20 mA              | Engineering Units  | 20.000                   | 00.000                   | 5 $\mu$ A         |
|                  |                         | % of FSR           | +100.00                  | +000.00                  | 5 $\mu$ A         |
|                  |                         | Hexadecimal Binary | FFF                      | 000                      | 5 $\mu$ A         |
| 31               | 4 to 20 mA              | Engineering Units  | 20.000                   | 04.000                   | 5 $\mu$ A         |
|                  |                         | % of FSR           | +100.00                  | +000.00                  | 5 $\mu$ A         |
|                  |                         | Hexadecimal Binary | FFF                      | 000                      | 5 $\mu$ A         |
| 32               | 0 to 10 V               | Engineering Units  | 20.000                   | 00.000                   | 2.442 mA          |
|                  |                         | % of FSR           | +100.00                  | +000.00                  | 2.442 mA          |
|                  |                         | Hexadecimal Binary | FFF                      | 000                      | 2.442 mA          |




Technical Diagrams

C

# Technical Diagrams

---


## C.1 ADAM Dimensions



**Figure C-1 ADAM Modules Dimensions**

## C.2 Installation


### C.2.1 DIN-Rail Mounting



**Figure C-2** *DIN-Rail Adapter*

# Technical Diagrams

---



**Figure C-3 DIN-Rail Mounting**

C.2.2 Panel Mounting





Figure C-4 Panel Mounting Bracket Dimensions

# Technical Diagrams

---



**Figure C-5 Panel Mounting**

C.2.3 Piggyback Stack




Figure C-6 Piggyback Stack

Utility Software

D



# Utility Software

---

## D.1 ADAM-4000 Utility Software

Together with the ADAM modules you will find a utility disk containing utility software with the following capabilities:

- Module configuration
- Module calibration
- Data Input and Output
- Alarm settings
- Autoscan of connected modules
- Terminal emulation

The following text will give you a brief instruction how to use the program.

### Search the installed modules

The main screen consists of a menu bar at the top side of the screen and a status field which displays information about the connected modules. When the modules are connected well, you have to start the program and search the modules by clicking the search icon as below. Please do check the COM port and related settings are correct.




Figure D-1 Search screen

**NOTICE:** When changing configuration, calibration or alarm parameters, you should always make sure that a window appears notifying you that the target module has confirmed the changes.

An asterisk sign “\*” before the modules address indicates that the module is in the INIT\* state

### Configuration

Click the searched module, which you would like to configure. You will find Set up page and related settings. An example is shown in Figure D-2 for an ADAM-4011 module.




Figure D-2 Configuration Screen

Here there are three major areas, General Setting, Data Area and AI Calibration. You may change the settings by selecting the preferred items and then clicking Update button.

The Checksum and Baud rate options need special attention since they can only be changed when an ADAM module is in the INIT\* state. To place a module in INIT state, its INIT terminal should be connected to its GND terminal (see Baud rate and Checksum in Chapter 2). When the ADAM module is not in INIT mode, an error message will appear.

# Utility Software

---

After you have made all necessary changes to the module configuration, the utility will display the process data automatically.

## Calibration

Please note only analog input and output modules can be calibrated. For example, A DAM-4011 module has Zero, Span and D C J C Calibration items. To learn what steps should be taken to calibrate both input and output modules, please refer to Chapter 8 Calibration.

## Terminal Function

When you would like to send and receive commands on the RS-485 line directly, you can use this Terminal function in this utility.




Figure D-3 Terminal Function

You can type the ADAM ASCII command in the text box and click Send button for testing the commands which are listed in Chapter 4 Command Set.





Figure D-4 Terminal Function

Notice: User can refer our help file to see more details for explanation of Utility operation.



# Utility Software

---

## D.2 The procedure for ADAM-4000 series installation guide

When user first time gets ADAM-4000 modules, he can refer following procedure to configure and operate. Especially note that new ADAM-4000 modules will have default factory settings with Address setting 1, and data format 9600, N, 8, 1. **Redefine the address to avoid ID conflict if two or more new modules are used in the same network.**

### Standard Installation Procedures


#### 1. Prepare the install environment

- Host computer
- Isolated RS-232/RS-485 Converter
- ADAM module

#### 2. Install ADAM-4000-5000 utility in host computer

#### 3. Wiring for ADAM-4000 module

##### Power supply & Communication Wiring



- #### 4. Move hardware switch to Initial mode
- (For some older Adam models, **use an external wire to connect the INIT\* terminal to the GND terminal.** Booting the module while connecting the INIT\* terminal with the module's GND terminal forces the configuration into a known state called the INIT\* state.)

## INIT\* state defaults:

Baud rate: 9600

Address: 00h

Checksum: disabled

Forcing the module in INIT\* state does not change any parameters in the module's EEPROM. When the module is in the INIT\* state with its INIT\* and GND terminals shorted, all configuration settings can be changed, and the module will respond to all other commands normally.

Notice:


### Init Mode

When the switch is set to the initial mode, the module will operate with its factory settings. (Address 0 with data format 9600, N, 8, 1).

### Normal Mode

When the switch is set to the normal mode, the module will operate with user-defined settings. A power reset will not alter these settings.

## 5. Connect computer to the ADAM I/O module using a RS-232 to RS-485, or USB to RS-485 converter.



## Utility Software

---

### **6. Use software to configure settings**

According to user's application to set parameter like as address, baudrate, data format, checksum, protocol...and so on.

#### **Changing Baud rate and Checksum**

Refer to Chapter 2 section 2.3.

#### **Changing the protocol from ADAM ASCII to Modbus**

Some ADAM-4000 modules support both ADAM ASCII and Modbus protocols, and the factory default setting of these modules is ADAM ASCII protocol. If you would like to configure the modules to Modbus protocol, please refer to Appendix H which describes how to change the protocol in ADAM utility.

### **7. Save changes and reset power on ADAM module for settings to take effect.**

RS-485 Network

E



## RS-485 Network

---

EIA RS-485 is industry's most widely used bidirectional, balanced transmission line standard. It is specifically developed for industrial multi-drop systems that should be able to transmit and receive data at high rates or over long distances.

The specifications of the EIA RS-485 protocol are as follows:

- Max line length per segment: 1200 meters (4000 feet)
- Throughput of 10 Mbaud and beyond
- Differential transmission (balanced lines) with high resistance against noise
- Maximum 32 nodes per segment
- Bi-directional master-slave communication over a single set of twisted pair cables
- Parallel connected nodes, true multi-drop

ADAM modules are fully isolated and use just a single set of twisted pair wires to send and receive! Since the nodes are connected in parallel they can be freely disconnected from the host without affecting the functioning of the remaining nodes. In industry shielded twisted pair is preferable due to the high noise ratio of the environment.

When nodes communicate through the network, no sending conflicts can occur since a simple command/response sequence is used. There is always one initiator (with no address) and many slaves (with address). In this case the master is a personal computer that is connected with its serial, RS-232, port to an ADAM RS-232/RS-485 converter. The slaves are the ADAM I/O modules. When modules are not transmitting data, they are in listen mode. The host computer initiates a command/response sequence with one of the modules. Commands normally contain the address of the module the host wants to communicate with. The module with the matching address carries out the command and sends its response to the host.

## E.1 Basic Network Layout

Multi-drop RS-485 implies that there are two main wires in a segment. The connected modules tap from these two lines with so called drop cables. Thus all connections are parallel and connecting or disconnecting of a node doesn't affect the network as a whole. Since ADAM modules use the RS-485 standard, and use an ASCII-based commands set, they can connect and communicate with all ASCII-based computers and terminals. The basic layouts that can be used for an RS-485 network are:

### Daisychain

The last module of a segment is a repeater. It is directly connected to the main-wires thereby ending the first segment and starting the next segment. Up to 32 addressable modules can be daisychained. This limitation is a physical one. When using more modules per segment the IC driver current rapidly decreases, causing communication errors. Totally the network can hold up to 256 addressable modules. The limitation for this number is the two number hexadecimal address codes that know 256 combinations. The ADAM converter, ADAM repeaters and the host computer are non addressable units and therefore are not included in these numbers.





Figure E-1 *Daisychaining*

# RS-485 Network

## Star Layout


In this scheme the repeaters are connected to drop-down cables from the main wires of the first segment. A tree structure is the result. This scheme is not recommended when using long lines since it will cause a serious amount of signal distortion due to a signal reflection in a several line endings.



**Figure E-2 Star Structure**

## Random


This is a combination of daisychain and hierarchical structure



**Figure E-3 Random Structure**

## E. 2 Line Termination

Each discontinuity in impedance causes reflections and distortion. When an impedance discontinuity occurs in the transmission line the immediate effect is signal reflection. This will lead to signal distortion. Specially at line ends this mismatch causes problems. To eliminate this discontinuity terminate the line with a resistor.




**Figure E-4 Signal Distortion**

The value of the resistor should be as close as possible to the characteristic impedance of the line. Although receiver devices add some resistance to the whole of the transmission line, normally it is sufficient that the resistor impedance should equal the characteristic impedance of the line.

### Example:

Each input of the receivers has a nominal input impedance of  $18\text{ k}\Omega$  feeding into a diode transistor-resistor biasing network that is equivalent to an  $18\text{ k}\Omega$  input resistor tied to a common mode voltage of  $2.4\text{ V}$ . It is this configuration which provides the large common range of the receiver required for RS-485 systems! (See Figure E-5 below)

## RS-485 Network



**Figure E-5 Termination resistor locations**

Because each input is biased to 2.4 V, the nominal common mode voltage of balanced RS-485 systems, the 18 k $\Omega$  on the input can be taken as being in series across the input of each individual receiver.

If thirty of these receivers are put closely together at the end of the transmission line, they will tend to react as thirty 36k $\Omega$  resistors in parallel with the termination resistor. The overall effective resistance will need to be close to the characteristics of the line.

The effective parallel receiver resistance  $R_p$  will therefore be equal to:

$$R_p = 36 \times 10^3 / 30 = 1200 \text{ } \Omega$$

While the termination receptor  $R_T$  will equal:

$$R_T = R_O / [1 - R_O/R_p]$$

Thus for a line with a characteristic impedance of 100  $\Omega$  resistor, the termination resistor  $R_T$  should be:

$$R_T = 100 / [1 - 100/1200] = 110 \text{ } \Omega$$

Since this value lies within 10% of the line characteristic impedance.


Thus as already stated above the line termination resistor  $R_T$  will normally equal the characteristic impedance  $Z_O$ .

The star connection causes a multitude of these discontinuities since there are several transmission lines and is therefore not recommended.

**NOTICE:** *The recommended wiring method that causes a minimum amount of reflection is daisy chaining where all receivers tap from one transmission line and needs to be terminated only twice.*

### E.3 RS-485 Data Flow Control

The RS-485 standard uses a single pair of wires to send and receive data. This line sharing requires some method to control the direction of the data flow. RTS (Request To Send) and CTS (Clear To Send) are the most commonly used method.



**Figure E-6 RS-485 data flow control with RTS**

#### Intelligent RS-485 Control

ADAM-4510 and ADAM-4520 are both equipped with an I/O circuit which can automatically sense the direction of the data flow. No handshaking with the host (like RTS, Request to Send) is necessary to receive data and forward it in the correct direction. You can use any software written for half-duplex RS-232 with an ADAM network without modification. The RS-485 control is completely transparent to the user.

How to use the Checksum feature

F

## How to use the Checksum feature

---

A checksum helps you detect communication errors between the host and module. This feature adds two extra checksum characters to the command or response string; therefore, it reduces the throughput.

### F.1 Checksum Enable/Disable

In order to enable configuration of a module's checksum feature, its INIT\* terminal should be shorted to its GND terminal. Then, the module should be rebooted. The checksum feature is enabled by setting bit 6 of the data format/checksum parameter to 1. On the other hand, the checksum is disabled by setting the parameter to 0. Whenever the checksum feature is used, all the connected devices including the host computer should be in enable mode.

The checksum is represented by a 2-character ASCII hexadecimal format and is transmitted just prior to the carriage return. The checksum equals to the result after performing modulus-256 (100h) of all the ASCII values' sum preceding the checksum. If the checksum is missing or incorrect, the module will not respond.

#### Example 1

The following example is an Analog Data In command and response when the checksum is enabled:

**Command:** #0588(CR)

**Response:** +3 .56719D(CR)

The input value of the module at address 05h is +3.5671 V. (The data format is in engineering units.) The command checksum (88h) is the sum of the ASCII values for the following characters: #, 0, and 5. The response checksum (9Dh) is the sum of the ASCII values for the following characters: ">", "+", "3", ".", "5", "6", "7", and "1".



### Example 2

This example explains how to calculate the checksum value of a Read High alarm limit command string:

Case 1. (If the Checksum feature is **disabled**)

**Command:** \$07RH(cr)

**Response:** !07+2.0500(cr) when the command is valid.

Case 2. (If the Checksum feature is **enabled**)

**Command:** \$07RH25(cr)

**Response:** !07+2.0500D8(cr)

where:

25 represents the checksum of this command, and

D8 represents the checksum of the response.

The checksum of the command string is derived as shown below:

$$25h = (24h + 30h + 37h + 52h + 48h) \text{ MOD } 100h$$

The hexadecimal ASCII codes for \$, 0, 7, R, H are 24h, 30h, 37h, 52h and 48h respectively. The sum of these ASCII codes is 125h, and the result equals to 25h after modulus-256(100h) execution.

## How to use the Checksum feature

---

**Table F-1** *Printable ASCII Characters*

| HEX | ASCII | HEX | ASCII | HEX | ASCII | HEX | ASCII |
|-----|-------|-----|-------|-----|-------|-----|-------|
| 21  | !     | 40  | @     | 5F  | _     | 7E  | ~     |
| 22  | ""    | 41  | A     | 60  | '     |     |       |
| 23  | #     | 42  | B     | 61  | a     |     |       |
| 24  | \$    | 43  | C     | 62  | b     |     |       |
| 25  | %     | 44  | D     | 63  | c     |     |       |
| 26  | &     | 45  | E     | 64  | d     |     |       |
| 27  | '     | 46  | F     | 65  | e     |     |       |
| 28  | (     | 47  | G     | 66  | f     |     |       |
| 29  | )     | 48  | H     | 67  | g     |     |       |
| 2A  | *     | 49  | I     | 68  | h     |     |       |
| 2B  | +     | 4A  | J     | 69  | i     |     |       |
| 2C  | ,     | 4B  | K     | 6A  | j     |     |       |
| 2D  | -     | 4C  | L     | 6B  | k     |     |       |
| 2E  | .     | 4D  | M     | 6C  | l     |     |       |
| 2F  | /     | 4E  | N     | 6D  | m     |     |       |
| 30  | 0     | 4F  | O     | 6E  | n     |     |       |
| 31  | 1     | 50  | P     | 6F  | o     |     |       |
| 32  | 2     | 51  | Q     | 70  | p     |     |       |
| 33  | 3     | 52  | R     | 71  | q     |     |       |
| 34  | 4     | 53  | S     | 72  | r     |     |       |
| 35  | 5     | 54  | T     | 73  | s     |     |       |
| 36  | 6     | 55  | U     | 74  | t     |     |       |
| 37  | 7     | 56  | V     | 75  | u     |     |       |
| 38  | 8     | 57  | W     | 76  | v     |     |       |
| 39  | 9     | 58  | X     | 77  | w     |     |       |
| 3A  | :     | 59  | Y     | 78  | x     |     |       |
| 3B  | ;     | 5A  | Z     | 79  | y     |     |       |
| 3C  | <     | 5B  | [     | 7A  | z     |     |       |
| 3D  | =     | 5C  | \     | 7B  | {     |     |       |
| 3E  | >     | 5D  | ]     | 7C  |       |     |       |
| 3F  | ?     | 5E  | ^     | 7D  | }     |     |       |

## **ADAM-4000 I/O Modbus Mapping Table**

# G

## ADAM-4000 I/O Modbus Mapping Table

---

The model list of ADAM-4000 I/O series support Modbus protocol

|    | Model       | Description   |
|----|-------------|---|
| 1  | ADAM-4015   | 6-channel RTD Input Module                            |
|    | ADAM-4015T  | 6-channel Thermistor Input Module                     |
| 2  | ADAM-4017+  | 8-channel Analog Input Module                         |
| 3  | ADAM-4018+  | 8-channel Thermocouple Input Module                   |
| 4  | ADAM-4019+  | 8-Channels Universal Analog Input Module              |
| 5  | ADAM-4024   | 4-channel Analog Output Module                        |
| 6  | ADAM-4051   | 16-channel Isolated Digital Input with LED Module     |
| 7  | ADAM-4055   | 16-channel Isolated Digital I/O with LED Module       |
| 8  | ADAM-4056S  | 12 channel Sink-type Isolated Digital Output Module   |
| 9  | ADAM-4056SO | 12 channel Source-type Isolated Digital Output Module |
| 10 | ADAM-4068   | 8 Relay Output Module                                 |
| 11 | ADAM-4069   | 8 Power Relay Output Module                           |

**1. ADAM-4015 6-channel RTD Input Module and  
ADAM-4015T 6-channel Thermistor Input Module**

| <b>ADDR 0X</b> | <b>Channel</b> | <b>Item</b>     | <b>Attribute</b> | <b>Memo</b> |
|----------------|----------------|-----------------|------------------|-------------|
| 00201          | 0              | Burn-out Signal | R                | 1:Burn-out  |
| 00202          | 1              | Burn-out Signal | R                |             |
| 00203          | 2              | Burn-out Signal | R                |             |
| 00204          | 3              | Burn-out Signal | R                |             |
| 00205          | 4              | Burn-out Signal | R                |             |
| 00206          | 5              | Burn-out Signal | R                |             |
| 00207          | 6              | Burn-out Signal | R                |             |
| 00208          | 7              | Burn-out Signal | R                |             |

| <b>ADDR 4X</b> | <b>Channel</b> | <b>Item</b>    | <b>Attribute</b> | <b>Memo</b> |
|----------------|----------------|----------------|------------------|-------------|
| 40001          | 0              | Current Value  | R                |             |
| 40002          | 1              | Current Value  | R                |             |
| 40003          | 2              | Current Value  | R                |             |
| 40004          | 3              | Current Value  | R                |             |
| 40005          | 4              | Current Value  | R                |             |
| 40006          | 5              | Current Value  | R                |             |
| 40007          | 6              | Current Value  | R                |             |
| 40008          | 7              | Current Value  | R                |             |
|                |                |                |                  |             |
| 40201          | 0              | Type Code      | R/W              | 0x00 0x0e   |
| 40202          | 1              | Type Code      | R/W              |             |
| 40203          | 2              | Type Code      | R/W              |             |
| 40204          | 3              | Type Code      | R/W              |             |
| 40205          | 4              | Type Code      | R/W              |             |
| 40206          | 5              | Type Code      | R/W              |             |
| 40207          | 6              | Type Code      | R/W              |             |
| 40208          | 7              | Type Code      | R/W              |             |
|                |                |                |                  |             |
| 40211          |                | Module Name 1  | R                | 0x40 0x18   |
| 40212          |                | Module Name 2  | R                | 0x50 0x00   |
| 40213          |                | Version 1      | R                | 0xa2 0x00   |
| 40214          |                | Version 2      | R                | 0x00 0x00   |
|                |                |                |                  |             |
| 40221          |                | Channel Enable | R/W              | 0x00 0xff   |

# ADAM-4000 I/O Modbus Mapping Table

---

## 2. ADAM-4018+ 8-channel Thermocouple Input Module

| ADDR 0X | Channel | Item            | Attribute | Memo       |
|---------|---------|-----------------|-----------|------------|
| 00201   | 0       | Burn-out Signal | R         | 1:Burn-out |
| 00202   | 1       | Burn-out Signal | R         |            |
| 00203   | 2       | Burn-out Signal | R         |            |
| 00204   | 3       | Burn-out Signal | R         |            |
| 00205   | 4       | Burn-out Signal | R         |            |
| 00206   | 5       | Burn-out Signal | R         |            |
| 00207   | 6       | Burn-out Signal | R         |            |
| 00208   | 7       | Burn-out Signal | R         |            |

| ADDR 4X | Channel | Item           | Attribute | Memo      |
|---------|---------|----------------|-----------|-----------|
| 40001   | 0       | Current Value  | R         |           |
| 40002   | 1       | Current Value  | R         |           |
| 40003   | 2       | Current Value  | R         |           |
| 40004   | 3       | Current Value  | R         |           |
| 40005   | 4       | Current Value  | R         |           |
| 40006   | 5       | Current Value  | R         |           |
| 40007   | 6       | Current Value  | R         |           |
| 40008   | 7       | Current Value  | R         |           |
|         |         |                |           |           |
| 40201   | 0       | Type Code      | R/W       | 0x00 0x0e |
| 40202   | 1       | Type Code      | R/W       |           |
| 40203   | 2       | Type Code      | R/W       |           |
| 40204   | 3       | Type Code      | R/W       |           |
| 40205   | 4       | Type Code      | R/W       |           |
| 40206   | 5       | Type Code      | R/W       |           |
| 40207   | 6       | Type Code      | R/W       |           |
| 40208   | 7       | Type Code      | R/W       |           |
|         |         |                |           |           |
| 40211   |         | Module Name 1  | R         | 0x40 0x18 |
| 40212   |         | Module Name 2  | R         | 0x50 0x00 |
| 40213   |         | Version 1      | R         | 0xa2 0x00 |
| 40214   |         | Version 2      | R         | 0x00 0x00 |
|         |         |                |           |           |
| 40221   |         | Channel Enable | R/W       | 0x00 0xff |

### 3. ADAM-4017+ 8-channel Analog Input Module

| ADDR 4X | Channel | Item           | Attribute | Memo      |
|---------|---------|----------------|-----------|-----------|
| 40001   | 0       | Current Value  | R         |           |
| 40002   | 1       | Current Value  | R         |           |
| 40003   | 2       | Current Value  | R         |           |
| 40004   | 3       | Current Value  | R         |           |
| 40005   | 4       | Current Value  | R         |           |
| 40006   | 5       | Current Value  | R         |           |
| 40007   | 6       | Current Value  | R         |           |
| 40008   | 7       | Current Value  | R         |           |
|         |         |                |           |           |
| 40201   | 0       | Type Code      | R/W       |           |
| 40202   | 1       | Type Code      | R/W       |           |
| 40203   | 2       | Type Code      | R/W       |           |
| 40204   | 3       | Type Code      | R/W       |           |
| 40205   | 4       | Type Code      | R/W       |           |
| 40206   | 5       | Type Code      | R/W       |           |
| 40207   | 6       | Type Code      | R/W       |           |
| 40208   | 7       | Type Code      | R/W       |           |
|         |         |                |           |           |
| 40211   |         | Module Name 1  | R         | 0x40 0x17 |
| 40212   |         | Module Name 2  | R         | 0x50 0x00 |
| 40213   |         | Version 1      | R         | 0xa2 0x00 |
| 40214   |         | Version 2      | R         | 0x00 0x00 |
|         |         |                |           |           |
| 40221   |         | Channel Enable | R/W       | 0x00 0xff |

# ADAM-4000 I/O Modbus Mapping Table

---

## 4. ADAM-4019+ 8-Channels Universal Analog Input Module

| ADDR 0X | Channel | Item            | Attribute | Memo                 |
|---------|---------|-----------------|-----------|----------------------|
| 00201   | 0       | Burn-out Signal | R         | 0: Non<br>1:Burn-out |
| 00202   | 1       | Burn-out Signal | R         |                      |
| 00203   | 2       | Burn-out Signal | R         |                      |
| 00204   | 3       | Burn-out Signal | R         |                      |
| 00205   | 4       | Burn-out Signal | R         |                      |
| 00206   | 5       | Burn-out Signal | R         |                      |
| 00207   | 6       | Burn-out Signal | R         |                      |
| 00208   | 7       | Burn-out Signal | R         |                      |

| ADDR 4X | Channel | Item           | Attribute | Memo      |
|---------|---------|----------------|-----------|-----------|
| 40001   | 0       | Current Value  | R         |           |
| 40002   | 1       | Current Value  | R         |           |
| 40003   | 2       | Current Value  | R         |           |
| 40004   | 3       | Current Value  | R         |           |
| 40005   | 4       | Current Value  | R         |           |
| 40006   | 5       | Current Value  | R         |           |
| 40007   | 6       | Current Value  | R         |           |
| 40008   | 7       | Current Value  | R         |           |
|         |         |                |           |           |
| 40201   | 0       | Type Code      | R/W       |           |
| 40202   | 1       | Type Code      | R/W       |           |
| 40203   | 2       | Type Code      | R/W       |           |
| 40204   | 3       | Type Code      | R/W       |           |
| 40205   | 4       | Type Code      | R/W       |           |
| 40206   | 5       | Type Code      | R/W       |           |
| 40207   | 6       | Type Code      | R/W       |           |
| 40208   | 7       | Type Code      | R/W       |           |
|         |         |                |           |           |
| 40211   |         | Module Name 1  | R         | 0x40 0x19 |
| 40212   |         | Module Name 2  | R         | 0x42 0x00 |
| 40213   |         | Version 1      | R         | 0xa1 0x00 |
| 40214   |         | Version 2      | R         | 0x00 0x00 |
|         |         |                |           |           |
| 40221   |         | Channel Enable | R/W       | 0x00 0xff |



**5. ADAM-4024 4-channel Analog Output Module**

| <b>ADDR 0X</b> | <b>Channel</b> | <b>Item</b>             | <b>Attribute</b> | <b>Memo</b> |
|----------------|----------------|-------------------------|------------------|-------------|
| 00001          | 0              | Emergency DI Input Flag | R                |             |
| 00002          | 1              | Emergency DI Input Flag | R                |             |
| 00003          | 2              | Emergency DI Input Flag | R                |             |
| 00004          | 3              | Emergency DI Input Flag | R                |             |

| <b>ADDR 4X</b> | <b>Channel</b> | <b>Item</b>          | <b>Attribute</b> | <b>Memo</b>      |
|----------------|----------------|----------------------|------------------|------------------|
| 40001          | 0              | Current Output Value | R/W              |                  |
| 40002          | 1              | Current Output Value | R/W              |                  |
| 40003          | 2              | Current Output Value | R/W              |                  |
| 40004          | 3              | Current Output Value | R/W              |                  |
|                |                |                      |                  |                  |
| 40201          | 0              | Type Code            | R/W              |                  |
| 40202          | 1              | Type Code            | R/W              |                  |
| 40203          | 2              | Type Code            | R/W              |                  |
| 40204          | 3              | Type Code            | R/W              |                  |
|                |                |                      |                  |                  |
| 40211          |                | Module Name 1        | R                | 0x40 0x24        |
| 40212          |                | Module Name 2        | R                | 0x00 0x00        |
| 40213          |                | Version 1            | R                | 0xa2 0x00        |
| 40214          |                | Version 2            | R                | 0x00 0x00        |
| 40215          |                | Comm Safety Enable   | R                | Enable:0x00 0x01 |
| 40216          |                | Comm Safety Flag     | R                | Occur:0x00 0x01  |

# ADAM-4000 I/O Modbus Mapping Table

---

## 6. ADAM-4051 16-channel Isolated Digital Input with LED Module

| ADDR 0X | Channel | Item            | Attribute | Memo |
|---------|---------|-----------------|-----------|------|
| 00001   | 0       | DI Input Signal | R         |      |
| 00002   | 1       | DI Input Signal | R         |      |
| 00003   | 2       | DI Input Signal | R         |      |
| 00004   | 3       | DI Input Signal | R         |      |
| 00005   | 4       | DI Input Signal | R         |      |
| 00006   | 5       | DI Input Signal | R         |      |
| 00007   | 6       | DI Input Signal | R         |      |
| 00008   | 7       | DI Input Signal | R         |      |
| 00009   | 8       | DI Input Signal | R         |      |
| 00010   | 9       | DI Input Signal | R         |      |
| 00011   | 10      | DI Input Signal | R         |      |
| 00012   | 11      | DI Input Signal | R         |      |
| 00013   | 12      | DI Input Signal | R         |      |
| 00014   | 13      | DI Input Signal | R         |      |
| 00015   | 14      | DI Input Signal | R         |      |
| 00016   | 15      | DI Input Signal | R         |      |

| ADDR 4X | Channel | Item          | Attribute | Memo      |
|---------|---------|---------------|-----------|-----------|
| 40211   |         | Module Name 1 | R         | 0x40 0x55 |
| 40212   |         | Module Name 2 | R         | 0x00 0x00 |
| 40213   |         | Version 1     | R         | 0xa2 0x00 |
| 40214   |         | Version 2     | R         | 0x00 0x00 |

**7. ADAM-4055 16-channel Isolated Digital I/O with LED Module**

| ADDR 0X | Channel | Item            | Attribute | Memo |
|---------|---------|-----------------|-----------|------|
| 00001   | 0       | DI Input Signal | R         |      |
| 00002   | 1       | DI Input Signal | R         |      |
| 00003   | 2       | DI Input Signal | R         |      |
| 00004   | 3       | DI Input Signal | R         |      |
| 00005   | 4       | DI Input Signal | R         |      |
| 00006   | 5       | DI Input Signal | R         |      |
| 00007   | 6       | DI Input Signal | R         |      |
| 00008   | 7       | DI Input Signal | R         |      |
|         |         |                 |           |      |
| 00017   | 0       | DO Output Value | R/W       |      |
| 00018   | 1       | DO Output Value | R/W       |      |
| 00019   | 2       | DO Output Value | R/W       |      |
| 00020   | 3       | DO Output Value | R/W       |      |
| 00021   | 4       | DO Output Value | R/W       |      |
| 00022   | 5       | DO Output Value | R/W       |      |
| 00023   | 6       | DO Output Value | R/W       |      |
| 00024   | 7       | DO Output Value | R/W       |      |

| ADDR 4X | Channel | Item               | Attribute | Memo                |
|---------|---------|--------------------|-----------|---------------------|
| 40211   |         | Module Name 1      | R         | 0x40 0x55           |
| 40212   |         | Module Name 2      | R         | 0x00 0x00           |
| 40213   |         | Version 1          | R         | 0xa2 0x00           |
| 40214   |         | Version 2          | R         | 0x00 0x00           |
| 40215   |         | Comm Safety Enable | R         | Enable:0x00<br>0x01 |
| 40216   |         | Comm Safety Flag   | R         | Occur:0x00 0x01     |

# ADAM-4000 I/O Modbus Mapping Table

---

## 8. ADAM-4056S 12 channel Sink-type Isolated Digital Output Module

| ADDR 0X | Channel | Item                 | Attribute | Memo |
|---------|---------|----------------------|-----------|------|
| 00017   | 0       | Digital Output Value | R/W       |      |
| 00018   | 1       | Digital Output Value | R/W       |      |
| 00019   | 2       | Digital Output Value | R/W       |      |
| 00020   | 3       | Digital Output Value | R/W       |      |
| 00021   | 4       | Digital Output Value | R/W       |      |
| 00022   | 5       | Digital Output Value | R/W       |      |
| 00023   | 6       | Digital Output Value | R/W       |      |
| 00024   | 7       | Digital Output Value | R/W       |      |
| 00025   | 8       | Digital Output Value | R/W       |      |
| 00026   | 9       | Digital Output Value | R/W       |      |
| 00027   | 10      | Digital Output Value | R/W       |      |
| 00028   | 11      | Digital Output Value | R/W       |      |

| ADDR 4X | Channel | Item               | Attribute | Memo             |
|---------|---------|--------------------|-----------|------------------|
| 40211   |         | Module Name 1      | R         | 0x40 0x56        |
| 40212   |         | Module Name 2      | R         | 0x53 0x00        |
| 40213   |         | Version 1          | R         | 0xA1 0x00        |
| 40214   |         | Version 2          | R         | 0x00 0x00        |
| 40215   |         | Comm Safety Enable | R         | Enable:0x00 0x01 |
| 40216   |         | Comm Safety Flag   | R         | Occur: 0x00 0x01 |

**9. ADAM-4056SO 12 channel Source-type Isolated Digital Output Module**

| <b>ADDR 0X</b> | <b>Channel</b>      | <b>Item</b>          | <b>Attribute</b> | <b>Memo</b> |
|----------------|---------------------|----------------------|------------------|-------------|
| 00017          | 0                   | Digital Output Value | R/W              |             |
| 00018          | 1                   | Digital Output Value | R/W              |             |
| 00019          | 2                   | Digital Output Value | R/W              |             |
| 00020          | 3                   | Digital Output Value | R/W              |             |
| 00021          | 4                   | Digital Output Value | R/W              |             |
| 00022          | 5                   | Digital Output Value | R/W              |             |
| 00023          | 6                   | Digital Output Value | R/W              |             |
| 00024          | 7                   | Digital Output Value | R/W              |             |
| 00025          | 8                   | Digital Output Value | R/W              |             |
| 00026          | 9                   | Digital Output Value | R/W              |             |
| 00027          | 10                  | Digital Output Value | R/W              |             |
| 00028          | 11                  | Digital Output Value | R/W              |             |
| 00029          | Over Current CH0-3  | Over Current Flag    | R/W              |             |
| 00030          | Over Current CH4-7  | Over Current Flag    | R/W              |             |
| 00031          | Over Current CH8-11 | Over Current Flag    | R/W              |             |

| <b>ADDR 4X</b> | <b>Channel</b> | <b>Item</b>        | <b>Attribute</b> | <b>Memo</b>      |
|----------------|----------------|--------------------|------------------|------------------|
| 40211          |                | Module Name 1      | R                | 0x40 0x56        |
| 40212          |                | Module Name 2      | R                | 0x53 0x4F        |
| 40213          |                | Versoin 1          | R                | 0xA1 0x00        |
| 40214          |                | Versoin 2          | R                | 0x00 0x00        |
| 40215          |                | Comm Safety Enable | R                | Enable:0x00 0x01 |
| 40216          |                | Comm Safety Flag   | R                | Occur: 0x00 0x01 |


# ADAM-4000 I/O Modbus Mapping Table

---

## 10. ADAM-4068 8 Relay Output Module

| ADDR 0X | Channel | Item               | Attribute | Memo |
|---------|---------|--------------------|-----------|------|
| 00017   | 0       | Relay Output Value | R/W       |      |
| 00018   | 1       | Relay Output Value | R/W       |      |
| 00019   | 2       | Relay Output Value | R/W       |      |
| 00020   | 3       | Relay Output Value | R/W       |      |
| 00021   | 4       | Relay Output Value | R/W       |      |
| 00022   | 5       | Relay Output Value | R/W       |      |
| 00023   | 6       | Relay Output Value | R/W       |      |
| 00024   | 7       | Relay Output Value | R/W       |      |

| ADDR 4X | Channel | Item               | Attribute | Memo             |
|---------|---------|--------------------|-----------|------------------|
| 40211   |         | Module Name 1      | R         | 0x40 0x68        |
| 40212   |         | Module Name 2      | R         | 0x00 0x00        |
| 40213   |         | Version 1          | R         | 0xa2 0x00        |
| 40214   |         | Version 2          | R         | 0x00 0x00        |
| 40215   |         | Comm Safety Enable | R         | Enable:0x00 0x01 |
| 40216   |         | Comm Safety Flag   | R         | Occur:0x00 0x01  |




## 11. ADAM-4069 8 Power Relay Output Module

| ADDR 0X | Channel | Item               | Attribute | Memo |
|---------|---------|--------------------|-----------|------|
| 00017   | 0       | Relay Output Value | R/W       |      |
| 00018   | 1       | Relay Output Value | R/W       |      |
| 00019   | 2       | Relay Output Value | R/W       |      |
| 00020   | 3       | Relay Output Value | R/W       |      |
| 00021   | 4       | Relay Output Value | R/W       |      |
| 00022   | 5       | Relay Output Value | R/W       |      |
| 00023   | 6       | Relay Output Value | R/W       |      |
| 00024   | 7       | Relay Output Value | R/W       |      |

| ADDR 4X | Channel | Item               | Attribute | Memo             |
|---------|---------|--------------------|-----------|------------------|
| 40211   |         | Module Name 1      | R         | 0x40 0x69        |
| 40212   |         | Module Name 2      | R         | 0x00 0x00        |
| 40213   |         | Version 1          | R         | 0xa1 0x01        |
| 40214   |         | Version 2          | R         | 0x00 0x00        |
| 40215   |         | Comm Safety Enable | R         | Enable:0x00 0x01 |
| 40216   |         | Comm Safety Flag   | R         | Occur:0x00 0x01  |

**Changing Configuration to Modbus Protocol**





## Changing Configuration to Modbus Protocol

---

The ADAM-4000 Modbus version modules may come from the factory set for which ADAM ASCII protocol are set as the default protocol.

If the module is connected to a Modbus network, the Modbus network may not recognize the module. This may be caused by the incorrect settings. ADAM-4000 module should be set-up for Modbus protocol instead of ADAM ASCII protocol.

Please follow the steps as below for configuring an ADAM-4000 module to Modbus protocol.

1. Configure the ADAM-4000 Module with the ADAM-4000 utility (latest ADAM-4000 utility can be found at [www.advantech.com](http://www.advantech.com) service & support.)
2. Initialize the ADAM-4000 on a RS-485 network (the preferred method is one module at a time on the RS-485 network).
3. With the module powered off, turn the switch in the “Init” position. (For some older Adam models, use an external wire to connect the INIT\* terminal to the GND terminal)
4. Power up the module
5. Wait 10 seconds for the module to initialize.
6. Using the ADAM-4000 utility, search (scan) for the module to change the protocol. (Initial COM settings: 9600 baud, N-8-1)
7. The utility will identify the module from the search function.
8. The ADAM-4000 utility will now permit the serial data protocol to be changed to the Modbus protocol.
9. The address and COM port settings can also be changed at this time.
10. To access the module, click on the module icon in the utility.
11. Update the settings by pressing the “Update” button.
12. Power off the module.
13. Turn the switch back to NORMAL\* position. (For the older Adam models, remove the wire between the INIT\* and GND terminals)
14. The module is now ready to be placed in the Modbus network.